



Original Permit No. 45/261

Amendment No. 1

AMENDMENT TO APPLICATION FOR PERMIT

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

Portland, Maine, March 20, 1946

The undersigned hereby applies for an amendment to Permit No. 45/261 pertaining to the building or structure described in the original application in accordance with the Laws of the State of Maine, the Building Code of the City of Portland, plans and specifications, if any, submitted herewith, and the following specifications:

Location 73 Deering Street

Within Fire Limits? Yes Dist. No. 1B

Owner's or Lessee's name and address Mrs. Delata White, 73 Deering Street

Contractor's name and address Edward Dugan

Plans filed as part of this Amendment no No. of Sheets 1

Is any plumbing work involved in this work? no Is any electrical work involved in this work? no

Increased cost of work no Additional fee 25

Framing Lumber: Kind? no Dressed or Full Size? no

Description of Proposed Work

To eliminate enclosure around third floor stair well and to eliminate direct access to fire escape from bedroom of third floor apartment on east side-defective location and arrangement of means of egress with relation to each other and the persons they are intended to serve to be compensated for by approved standard automatic fire detection and alarm system to cover entire cellar, and all public halls and stair halls above the cellar.

Approved:

Chief of Fire Department

Signature of Owner

Mrs. Delata White

Commissioner of Public Works

Approved:

3/21/46 - [Signature]

Inspector of Buildings