

Memorandum from Department of Building Inspection, Portland, Maine.

73 Deering St. - Building permit for alterations to two offices on second floor
for Joseph White by W. B. Sturdee - 5/14/53

Building permit for lowering ceilings of two offices in the second story of the building at 73 Deering St. and to partition off a new toilet room there is issued herewith subject to the following conditions:-

1. Permit is issued on the basis that there is to be no increase in the number of suites of doctor's offices in the building.
2. The supporting of the new tile ceilings on 2x4's spaced four feet apart is extremely questionable. These 2x4's should not be spaced more than two feet on centers and in any case not farther apart than is recommended by the manufacturers of the ceiling tile.
3. After framing for support of ceiling, as well as the studding for the new partitions, has been put in place and before any ceiling tile or wallboard is applied, notification is to be given this department for an inspection. No "closing-in" is to be done until authorization to do so has been given on a green tag left at the job.

Copy to: Mr. Joseph White
73 Deering St.

MS/G

(Signed) Warren McDonald
Inspector of Buildings