



Portland Fire Department

4/1/2019

HENRY T LACKEY
66 DEERING ST
PORTLAND, ME 04101
ht.lackey@gmail.com

HENRY T LACKEY
66 DEERING ST
PORTLAND, ME 04101
ht.lackey@gmail.com

CERTIFIED MAIL

RE: 66 DEERING ST
PORTLAND, ME

047 C005001

Page 1 of 2

**NOTICE OF VIOLATION
AND ORDER TO CORRECT**

To Whom it May Concern,

The City of Portland inspected the above-referenced property on 12/6/2016 and found violations of the City of Portland Code of Ordinances, which are listed on the attached page(s). You are hereby ordered to correct these violations by the dates given on the attached.

A reinspection of your property will take place on 4/3/2019 10:00:00AM .

Please contact the Fire Prevention Bureau at 874-8400 if you have any question about your reinspection. If the violations are not corrected at the time of reinspection, you will be charged a \$150 failed reinspection fee.

If you do not correct the attached violations, then this matter may be referred to the City of Portland Corporation Counsel for legal action, including civil penalties and other legal remedies.

Thank you for keeping the City of Portland safe.

Sincerely,

Captain John Brennan
Fire Prevention Bureau
City of Portland

NON-COMPLIANCE VIOLATION LIST

NAME	CODE DESCRIPTION	COMMENTS	Deadline
NFPA 101-31.2.2.1	1-hour fire rated doors and assemblies required, including self-closing and self-latching mechanisms.	From apts. Into hallways	12/6/2017