#### DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

BWB40 LLC /Derosier Plumbing & Heating

Located at

40 DEERING ST

**PERMIT ID:** 2014-00379

**ISSUE DATE:** 03/10/2014

CBL: 047 C016001

has permission to Install a HTP Pioneer PHR-160 In basement

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Tammy Munson

Fire Official

more than 16 individuals)

**Building Official** 

### THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning
Single Family handicap dwelling unit (no

**Building Inspections** 

Fire Department

# BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

# Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

#### **REQUIRED INSPECTIONS:**

Final Inspection

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

Permit No: Date Applied For: CBL: City of Portland, Maine - Building or Use Permit 02/25/2014 2014-00379 047 C016001 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716 Proposed Use: **Proposed Project Description:** Single Family handicap dwelling unit Install a HTP Pioneer PHR-160 In basement Reviewer: Robert Wiener **Dept:** Historic Status: Approved w/Conditions **Approval Date:** 03/05/2014 Ok to Issue: **Note:** Visbility from Deering Street is limited. **Conditions:** 1) Historic preservation staff understands that the only exterior alteration is to be a replacement for the existing metal chimney cap on the rear chimney. 02/27/2014 **Dept:** Zoning Status: Approved Reviewer: Marge Schmuckal **Approval Date:** Note: Ok to Issue: **Conditions:** Dept: Building Status: Approved w/Conditions Reviewer: Tammy Munson 03/05/2014 **Approval Date:** Ok to Issue: Note: **Conditions:** 1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. The installation must comply with the State of Maine Gas Regulations. **Dept:** Fire **Status:** Approved w/Conditions Reviewer: Craig Messinger **Approval Date:** 03/10/2014 Ok to Issue: Note: **Conditions:** 1) Carbon Monoxide is detection required in accordance with NFPA 720, Standard for Installation of Carbon Monoxide (CO) Detection and Warning Equipment, 2009 edition

- 2) All outstanding code violations shall be corrected prior to final inspection.
- 3) Shall meet the requirements the most recent NFPA 30 Flammable and Combustible Liquids Co