Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 05/20/16

SPACE RESERVED FOR CITY OF PORTLAND, MAINE ELECTRONIC STAMP.

1 E-1 FLOOR PLAN - EMERGENCY LIGHTING

SCALE: 1/8" = 1'-0"

FLOOR PLAN - EMERGENCY LIGHTING NOTES

1. EXIT SIGNS AND EMERGENCY BATTERY UNITS SHALL BE FED FROM A LOCAL UNSWITCHED LIGHTING CIRCUIT.
2. CONFIRM EXISTING EMERGENCY HEAD LOCATIONS AND RELOCATE IF NECESSARY FOR CODE COMPLIANT COVERAGE. VERIFY BATTERY CAPACITY OF EXISTING BATTERY UNITS BEFORE ADDING ADDITIONAL REMOTE HEAD LOADS. ADD ADDITIONAL BATTERY UNITS IF REQUIRED.
3. EXISTING WIRING MAY BE REUSED IF CODE COMPLIANT.
4. EXISTING EXIT SIGNS SHALL BE DISCONNECTED AND REMOVED.
5. EXISTING BASEMENT LAYOUT TO REMAIN AS IS. GENERAL CONTRACTOR TO REVIEW EMERGENCY LIGHTING AND SUPPLEMENT/REPLACE AS REQUIRED BY CODE.

EMERGENCY LIGHTING LEGEND

	EXISTING SINGLE HEAD EMERGENCY LIGHTS TO BE REMOVED
	CEILING MOUNTED EMERGENCY LIGHT UNIT - ISOLITE BRH-2-12V-H8W
EBU	WALL MOUNTED EMERGENCY LIGHT UNIT - ISOLITE ELMR WITH (2) H5W HEADS
EBU	CEILING MOUNTED EMERGENCY LIGHT UNIT - ISOLITE ERT-12V-100 WITH (2) H8W-SD-NC HEADS
EBU	WALL MOUNTED EMERGENCY LIGHT UNIT - ISOLITE ELP-12V-100 WITH (2) H8W-SD-NC HEADS
WP	EXTERIOR WALL MOUNTED EMERGENCY LIGHT HEADS - ISOLITE BRH-2-12V-H12W-WP
	INTERIOR WALL MOUNTED EMERGENCY LIGHT HEADS - ISOLITE BRH-2-12V-H8W
	EXIT LIGHT - ISOLITE - MATCH EXISTING STYLE AND PROVIDE WITH BATTERY BACKUP
ETR	EXISTING TO REMAIN
ETBR	EXISTING EMERGENCY HEADS AND CABLING TO BE REMOVED

STATE OF MAINE
VICTOR E. RENO
8050
REGISTERED PROFESSIONAL ENGINEER

BRUCE RONAYNE HAMILTON ARCHITECTS

ARCHITECTURE
LAND PLANNING
INTERIOR DESIGN
3D VISUALIZATION

833 TURNPIKE ROAD
P.O. BOX 104
NEW IPSWICH
NEW HAMPSHIRE 03071

RENO ENGINEERING & LIGHT DESIGN
MARLOW, NH 03456
603-446-9426, 603-446-3731 (F)
EMAIL: renoengineering@highlighdesign.com

Project Number: 1523

THIS DESIGN AND THE DRAWINGS THEREFORE PREPARED FOR THIS PROJECT, ARE THE PROPERTY OF THE ARCHITECT, BRUCE RONAYNE HAMILTON, ARCHITECTS INC., AND, THE DESIGN AND/OR DRAWINGS MAY NOT BE USED IN WHOLE OR IN PART FOR ANY USE OTHER THAN FOR THE ORIGINAL PROJECT FOR WHICH THE DESIGN AND/ OR DRAWINGS WERE PREPARED, WITHOUT THE WRITTEN CONSENT AND PERMISSION OF THE ARCHITECT, BRUCE RONAYNE HAMILTON ARCHITECTS, INC.
NO BUILDING PERMIT SHALL BE ISSUED BY ANY BUILDING DEPARTMENT, UNLESS THIS DOCUMENT BEARS THE ORIGINAL SEAL AND SIGNATURE OF THE ARCHITECT, BRUCE RONAYNE HAMILTON ARCHITECTS INC.

REV. NO.	DESCRIPTION OF REV.	REV. DATE
1	ISSUED FOR GC BIDDING/BUILDING PERMIT	3-21-16

PROJECT: RITE AID STORE #3298
713 CONGRESS STREET
PORTLAND, MAINE

SUBJECT: EMERGENCY LIGHTING PLAN

JOB NO.: 1632
SCALE: 1/8"=1'-0"
DATE: 3-21-16
DRAWN BY: RELD

SHEET NO. E-1