

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



CITY OF PORTLAND

BUILDING PERMIT

This is to certify that
CUNNINGHAM SECURITY
10 PRINCES POINT RD
YARMOUTH, ME 04096

For installation at
727 CONGRESS ST

Job ID: 2012-08-4634-FAFS


CBL: 047- C-025-001

has permission to add wireless heat detectors to existing fire alarm system

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise closed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be


Fire Prevention Officer

58

Code Enforcement Officer / Plan Reviewer

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY
PENALTY FOR REMOVING THIS CARD

BUILDING PERMIT INSPECTION PROCEDURES

Please call 874-8703 or 874-8693 (ONLY)

or email: buildinginspections@portlandmaine.gov

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**

Final Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Director of Planning and Urban Development
Jeff Levine

Job ID: 2012-08-4634-FAFS
add wireless heat detectors to existing fire alarm

For installation at:
727 CONGRESS ST

CBL: 047- C-025-001

Conditions of Approval:

Fire

The installation shall comply with the following:

- City of Portland Chapter 10, Fire Prevention and Protection;
- NFPA 1, *Fire Code* (2009 edition), as amended by City Code;
- NFPA 101, *Life Safety Code* (2009 edition), as amended by City Code;
- City of Portland Fire Department Rules and Regulations;
- NFPA 72, *National Fire Alarm and Signaling Code* (2010 edition), as amended by Fire Department Rules and Regulations; and
- NFPA 70, *National Electrical Code* (2011 edition) as amended by the State of Maine.

The fire alarm system shall be certified by a master fire alarm company and have a new fire alarm inspection sticker.

In field installation shall be installed per code as conditions dictate.

Heat detectors shall be installed within each room of the dwelling units except bathrooms not exceeding 55 ft² and closets not exceeding 24 ft².

A locked clear cover shall be installed over the existing fire alarm annunciator.

Records cabinet, FACP, annunciator(s), and pull stations shall be keyed alike.

Central Station monitoring for addressable fire alarm systems shall be by point.

All fire alarm records required by NFPA 72 should be stored in an approved cabinet located at the FACP labeled "FIRE ALARM RECORDS".

Installation of a Fire Alarm system requires a Knox Box to be installed per city ordinance.

System acceptance and commissioning must be coordinated with the Fire Department. Call 874-8703 to schedule.

Fire Alarm system shall be maintained. If system is to be off line over 4 hours a fire watch shall be in place. Dispatch notification required 874-8576.

A master box connection is not authorized for this building.

City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, FAX: (207) 8716

Job No: 2012-08-4634-FAFS	Date Applied: 8/7/2012	CBL: 047- C-025-001	
Location of Construction: 727 CONGRESS ST	Owner Name: CONGRESS PLACE WEST LLC	Owner Address: 10 DANA STREET, SUITE 400 PORTLAND, ME 04102	Phone:
Business Name:	Contractor Name: Cunningham Security Systems	Contractor Address: 10 PRINCESS POINT RD YARMOUTH MAINE 04096	Phone: 846-3350
Lessee/Buyer's Name:	Phone:	Permit Type: FIRE ALARM	Zone: B-2b
Past Use: 8 residential condos	Proposed Use: Same: 8 residential condos – to install fire alarm system in basement	Cost of Work: \$7,000.00	CEO District:
		Fire Dept: 8/8/12 <input checked="" type="checkbox"/> Approved w/ conditions <input type="checkbox"/> Denied <input type="checkbox"/> N/A	Inspection: Use Group: Type:
		Signature: <i>[Signature]</i> (58)	Signature:
Proposed Project Description: Fire Alarm		Pedestrian Activities District (P.A.D.)	
Permit Taken By: Gayle		Zoning Approval	

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building Permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False informatin may invalidate a building permit and stop all work.</p>	<p>Special Zone or Reviews</p> <p><input type="checkbox"/> Shoreland</p> <p><input type="checkbox"/> Wetlands</p> <p><input type="checkbox"/> Flood Zone</p> <p><input type="checkbox"/> Subdivision</p> <p><input type="checkbox"/> Site Plan</p> <p><input type="checkbox"/> Maj <input type="checkbox"/> Min <input type="checkbox"/> MM</p> <p>Date: <i>OK</i> 8/7/12</p>	<p>Zoning Appeal</p> <p><input type="checkbox"/> Variance</p> <p><input type="checkbox"/> Miscellaneous</p> <p><input type="checkbox"/> Conditional Use</p> <p><input type="checkbox"/> Interpretation</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Denied</p> <p>Date:</p>	<p>Historic Preservation</p> <p><input checked="" type="checkbox"/> Not in Dist or Landmark</p> <p><input type="checkbox"/> Does not Require Review</p> <p><input type="checkbox"/> Requires Review</p> <p><input type="checkbox"/> Approved</p> <p><input type="checkbox"/> Approved w/Conditions</p> <p><input type="checkbox"/> Denied</p> <p>Date: <i>[Signature]</i></p>
	CERTIFICATION		

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE

66

2012 08 4634



Fire Alarm Permit

If you or the property owner owes real estate or property taxes or user charges on any property within the city, payment arrangements must be made before permits of any kind are accepted.

B-2h

Installation address: 727 Congress Street CBL: 47-c-25-1

Exact location: (within structure) Basement Condos

Type of occupancy(s) (NFPA & ICC): Condominium 8 Residential DU #2012-04-374

Building owner: Congress Place West LLC - 10 Dana St, Suite 400 / 04102

System Designer (point of contact): Cunningham Security Systems

Designer phone: 207-846-3350 E-mail: mmajor@cunninghamsecurity.com

Installing contractor: Cunningham Security Systems Certificate of Fitness No: 1004

Contractor phone: 207-846-3350 E-mail: mmajor@cunninghamsecurity.com

This is a new application: YES NO New AES Master Box: YES NO
(Include Master Box approval form)

Amendment to an existing permit: YES NO Permit no: _____

The following documents shall be provided with this application:

- Floor plans
- Wiring diagram
- Annunciator details
- Input/ Output Matrix
- Equipment data sheets
- Electrical Permit Pulled (check alarm/com)
- Scope of Work
- 11 1/2 x 17s
- pdf copy (may be e-mailed)
- Designer qualifications
- Battery/ voltage drop calcs

Master box approval only: YES NO
(If yes check *New AES Master Box* above)

COST OF WORK: 6,100.00

PERMIT FEE: _____
(\$10 PER \$1,000 + \$30 FOR THE FIRST \$1,000)

RECEIVED

AUG 07 2012

Dept. of Building Inspections
City of Portland Maine

The designer shall be the responsible party for this application. Download a new copy of this application at www.portlandmaine.gov/fire for every submittal. Submit all plans in electronic PDF in addition to readable 11 1/2 x 17s to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with the *City of Portland Technical Standard for Signaling Systems for the Protection of Life and Property*, available at www.portlandmaine.gov/fire.

Applicant signature: [Signature] Date: 8/6/12

CUNNINGHAM

Security Systems

10 Princes Point Road • Yarmouth, Maine 04096
(207) 846-3350 • Fax (207) 846-6080 • (800) 210-0257

8/7/12

Lieutenant Benjamin Wallace, Jr.
Portland Fire Department
380 Congress Street
Portland Maine 04101

Please find attached a permit application for the property located at 727 Congress Street and referred to Longfellow Place. The existing alarm system was installed by Protection One prior to our involvement with the building. It is a current model Honeywell Vista alarm panel with a keypad annunciator. There are hard wired initiation devices and occupant notification devices in the common areas only. The scope of the new work will include the installation of Honeywell wireless heat detectors that are UL listed for use with the panel. We will also be expanding the capacity of the system to allow for the 40 new heat detectors. The heat detectors shall be fully supervised by the system for trouble and alarm conditions and when activated shall cause the occupant notification devices to sound. All alarm, supervisory and trouble conditions shall continue to be transmitted to the supervising central station. As a part of our due diligence and annual testing, we have fully tested the battery capacity and metered the voltage drop and everything works within the range of acceptability.

Thank you and please do not hesitate to call with any questions.

Sincerely,



Michelle Perkins, Operations Manager

Planning • Installation • Monitoring • Service
Visit our web site at: www.cunninghamsecurity.com

VISTA-128FBP/V128FBP-24

COMMERCIAL PARTITIONED FIRE AND
BURGLARY ALARM CONTROL PANEL



Now UL864 9th Edition Approved

Designed to integrate seamlessly with CCTV, access control and Honeywell's full range of fire and burglary components, the new VISTA-128FBP provides the ultimate protection of life and property. The UL Listed commercial fire and burglary control panel supports up to eight partitions and up to 128 zones/points using hardwired, wireless and V-Plex®

addressable technologies. A diverse line of Honeywell initiating devices, notification circuits, communication devices, keypads, RF receivers and relays are also supported. The VISTA-128FBP has been designed to mount quickly and easily in an attack resistant cabinet, and is available in 12V and 24V models.

FEATURES

- Eight hardwired zones standard, expandable to 120 V-Plex addressable points/zones or 128 wireless points/zones
- Can control eight separate areas independently (8 partitions)
- Supports commercial wireless fire and burglary devices
- Stores up to 512 events
- Accommodates 150 user codes and up to 250 access card holders using VistaKey
- Supports V-Plex addressable VistaKey access control (1 to 8 doors)
- Two on-board notification (bell) circuits delivering 2.3A @ 12V or 3.4A @ 24V
- Automatic smoke detector sensitivity maintenance testing
- Four-wire smoke reset using onboard J2 output trigger
- Supports Dynamic Signaling for AlarmNet Communicators
- Supports Remote Control via the Internet*
- Supports Internet Alarm Reporting*
- Supports Graphical User Interface Consoles
- Listed to UL864 9th Edition
- Upload/download via Ethernet*
- Carbon monoxide (CO) zone support

* When used with AlarmNet devices.

VISTA-128FBP/V128FBP-24

COMMERCIAL PARTITIONED FIRE AND
BURGLARY ALARM CONTROL PANEL

Honeywell

ADDITIONAL FEATURES

- Notification Appliance Circuits (two):
 - Programmable
 - Temporal code compliant
 - Individually silenceable
- Programmable on-board auxiliary relay
- False alarm reduction features:
 - Exit error logic
 - Exit delay reset
 - Cross zoning
 - Call waiting defeat
 - Recent close report
- Supports commercial hardwired, addressable V-Plex polling loop and wireless zones
- Hardwired zones
 - Provides eight style B hardwired zones
 - EOLR supervised for Fire and UL burglary installations
 - Supports N.O. or N.C. sensors
 - Individually assignable to any eight partitions
 - Up to ~~32~~¹⁶ two-wire smoke detectors each on zone one and two (~~64~~³² total)
- Up to 50 two-wire glassbreak detectors on zone eight
- Patented addressable V-Plex polling loop technology
 - Supports 120 two-wire zones points
 - Global polling technology for faster processing
 - Supervised by panel
 - Zones individually assignable to partitions, notification circuit (bell) output or auxiliary relay
 - 4,000 ft. capability without the use of shielded cable
 - Extender/Isolation bus modules
 - Eight zone – Class A and B expander module
 - Eight zone – Class B expander module
 - One zone supervised contact monitor module
- UL Listed wireless expansion
 - Supports up to 128 wireless zones/points
- Supervised by control for check-in signals
- Tamper protection for transmitters
- Individually assignable up to eight partitions
- Supports commercial wireless smoke detectors
- Access Control integration
 - Full integration with PassPoint Access Control System Complete Gateway interface of VISTA and access functions
- Up to eight doors using VistaKey V-Plex Access Control
- Event reporting
- Local printer of access or VISTA related events
- Communication
 - Phone mapping by zone response type
 - Panel operation during download

SPECIFICATIONS

Applications

The VISTA-128FBP control is well suited for a variety of applications as an integrated fire and burglary control. A diverse line of Honeywell initiating devices supports this extremely powerful control. Some of the applications supported are: medical and professional buildings, churches or synagogues, office buildings, schools, strip malls, larger residences and factory or warehouse environments.

Electrical

- Primary power: 18VAC @ 72VA Honeywell No. 1451
- Control panel quiescent current draw: 300mA
- Backup battery:
 - 12VDC, 12AH min to 34.4AH max
 - Lead acid battery (gel type)
- Alarm power: 12VDC, 1.7A max for each notification (bell) circuit output Total 2.3A @ 12V
- Aux. standby pwr: 12VDC, 1A max
- Total power: 2.3A at 12VDC, 3.4A at 24VDC from all sources
- Standby time: 24 hours with 1A standby load using 34.4AH battery

- Fusing: Battery input, aux. and notification (bell) circuit outputs are protected using PTC circuit protectors. All outputs are power limited.
- Optional 24-volt power supply, PS 24 supplies two 24 VFW, 1.7A full wave rectified, unfiltered outputs

Main Dialer

- Line seize: Double Pole
- Ringer equiv.: 0.7B
- Formats: ADEMCO Low Speed, ADEMCO 4+2 Express, ADEMCO High Speed, ADEMCO Contact ID, Sescoa and Radionics
- Dual phone line capability (using 5140DLM module)

Cabinet dimensions

- 18" H x 14.5" W x 4.3" D

Environmental

- Storage temp: 14° F to 158° F
(-10° C to 70° C)
- Operating temp: 32° F to 122° F
(0° C to 50° C)
- Humidity: 85% RH

- EMI: Meets or exceeds the following requirements:
 - FCC Part 15, Class B Device
 - FCC Part 68
 - IEC EMC Directive

Agency Listings

- UL609 Grade A Local Mercantile Premises and Mercantile Safe and Vault
- UL611/1610 Grades A, AA, Central Station
- UL365 Grades A, AA Police Connect
- UL864/NFPA72 Local, Central Station and Remote Station
- UL985
- Factory Mutual
- California State Fire Marshal
- MEA
- CAN/ULC S304 – Central and Monitoring Station Burglar Alarm Unit
- CAN/ULC S527 – Central Unit for Fire Alarm Systems
- CAN/ULC S303 – Local Burglar Alarm Unit
- CAN/ULC S525 – Audible Signal Appliances

VISTA-128FBP/V128FBP-24

COMMERCIAL PARTITIONED FIRE AND BURGLARY ALARM CONTROL PANEL

COMPATIBLE DEVICES

Auxiliary Devices

- 6160CR-2 – Red Alpha Keypad
- 4204 – Relay Module, four form C contacts
- 4204CF – Two supervised output circuits
- 5881 Series RF receiver
- 5883H RF receiver
- 6220S – System printer used with 4100SM serial module
- 6160CR-2 – Red Fire Keypad
- 6160 – Burglary Keypad

Two-Wire Smoke Detectors

Conventional

- System Sensor
- ESL
- DSC

Horn/Strobes

- System Sensor
- Wheelock
- Gentex

Manual Pull Stations

- 5140MPS-1
- 5140MPS-2

V-Plex (Addressable) Devices

- 4208U Loop Expansion Module – eight zones
- 4101SN Single Relay/Zone Module

- 4208SNF Class A/B Expander Module
- 4190SN Remote Point Module – two zones
- 4193SN Two-Zone Serial Interface Module
- VSI Module
- 4293SN One-Zone Serial Interface Module

V-Plex Extender/Isolation Modules

- 4297 Extender/Isolator Module
- VSI Isolator Module

V-Plex Smoke Detectors:

- 5193SD
- 5193SDT

V-Plex Passive Infrared Detectors

- 998MX
- IS2500SN
- DT7500SN

V-Plex (Addressable) Contacts

- 4939SN-WH
- 4944SN-WH
- 4959SN

V-Plex Glassbreak Detectors

- FG1625SN

Optional 24V Power Supply

- PS24 – 24V power supply – 3.4A

Commercial Wireless Devices

- 5808W3 – Photoelectric Smoke/Heat Detector
- 5806W3 – Photoelectric Smoke Detector
- 5809 – Wireless Heat Detector
- 5817CB – Wireless Commercial Transmitter
- 5869 – Hold-Up Transmitter
- 5881ENHC – RF Receiver
- 5883H – RF Receiver

Access Control

- VistaKey V-Plex (addressable) Access Control
- VistaKey-SK Starter Kit
- VistaKey-EX Expansion Kit

Alarm Communications

- 7845i-ENT – Internet/Intranet Communicator
- 7845GSM – Digital Cellular Communicator
- 7845i-GSM – Internet and Digital Cellular Communicator
- GSMCF/iGSMCF – Commercial Fire Communication Kits (when available)

Product specifications subject to change.

ORDERING

V128FBP-9

Commercial Fire and Partitioned Burglary Alarm Control Panel 12V Model

V128FBP9-24

Commercial Fire and Partitioned Burglary Alarm Control Panel 24V Model

For more information: www.honeywell.com/security/hsc

Automation and Control Solutions
Honeywell Security & Communications
2 Corporate Center Dr. Suite 100
Melville, NY 11747
1.800.467.5875
www.honeywell.com

Honeywell

LVSTA128FBPD/D
September 2009
© 2009 Honeywell International Inc.

SECURITY ACCESS AND SURVEILLANCE
SECTION 13850

VISTA-128FBP
ARCHITECT AND ENGINEER SPECIFICATION
FOR
SECURITY SYSTEM

ADEMCO Group
165 Eileen Way
Syosset, New York 11791

1-800-645-7568

**SECTION 13850
DETECTION AND ALARM**

PART 1 GENERAL

1.01 SUMMARY

- A. Section Includes
 - 1. Control Panel
 - 2. Associated Equipment
- B. Products Installed But Not Supplied Under This Section
 - 1. Section 16140 - Wiring Devices
 - 2. Section 16530 - Emergency Lighting
- C. Related Sections
 - 1. Section 13700 - Security Access and Surveillance
 - 2. Section 13800 - Building Automation and Control

1.02 REFERENCES

- A. Underwriters Laboratories (UL):
 - 1. UL 268 – Smoke Detectors for Fire Protective Signaling Systems
 - 2. UL 365 – Police Station Connected Burglar Alarm Units and Systems
 - 3. UL 609 – Local Burglar Alarm Units and Systems
 - 4. UL 611 – Central Station Burglar-Alarm Units
 - 5. UL 636 – Holdup Alarm Units and Systems
 - 6. UL 684 – Local, Central Station, and Remote Station
 - 7. UL 864 – Control Units for Fire Protective Signaling Systems
 - 8. UL 985 – Household Fire Warning System Units
 - 9. UL 1023 – Household Burglar-Alarm System Units
 - 10. UL 1076 – Proprietary Burglar-Alarm Units and Systems
 - 11. UL 1610 – Central-Station Burglar-Alarm Units
- B. Federal Communications Commission (FCC):
 - 1. Code of Federal Regulations Title 47 - Part 15 – Radio Frequency Devices
 - 2. Code of Federal Regulations Title 47 - Part 68 – Connection of Terminal Equipment to the Telephone Network
- C. National Fire Protection Association (NFPA):
 - 1. NFPA70 – National Electrical Code.

2. NFPA 72 – National Fire Protection Code

1.03 SYSTEM DESCRIPTION

- A. The system shall be a Fire/Burglary/Access Control/CCTV Switching System that includes the following capabilities:
1. Listed for UL Commercial Fire and Burglary.
 2. Supports up to 128 zones.
 3. Supports up to eight (8) separate partitions.
 4. Supports up to 150 users.
 5. Supports commercial wireless devices.
 6. Provides integrated security, access control, and CCTV switching and commercial fire capability.
 7. Provides supervision of peripheral devices.
 8. Supports up to 96 optional relay outputs.
 9. Supports long-range radio (LRR) communication.
 10. Provides scheduling capability to allow for automated operations.
 11. Supports up to eight (8) alphanumeric paging devices.
 12. Supports panel linking.
 13. Supports alarm reporting via Internet.
 14. Interfaces with automation software.
 15. Monitors smoke detector maintenance signals.
 16. Capable of being installed using existing wiring.

1.04 SUBMITTALS

- A. Submittals shall include manufacturer data sheets for all major system components.

1.05 QUALITY ASSURANCE

- A. The alarm manufacturer shall be certified as being compliant with ISO9001.

PART 2 PRODUCTS

2.01 SYSTEM PERFORMANCE

- A. Control Panel - The control panel shall be an eight (8)-partition, UL commercial fire and burglary control panel that supports up to 128 zones using basic

hardwired, polling loop, and wireless zones. It shall also provide supervision of two (2) notification appliance output circuits (NAC), RF receivers, and relay modules. In addition, the control shall provide the ability to schedule time-driven events, and allow certain operations to be automated by pressing a single button. The system shall be capable of interfacing with an ECP long-range radio (LRR) unit that can send Contact ID messages, and alphanumeric paging devices. The control shall provide integrated access control and CCTV-switching capability with the use of a single downloader and database.

1. Basic Hardwired Zones - The control shall provide eight (8) style-B hardwire zones with the following characteristics:
 - a. EOLR supervision (optional for zones 3-8): Shall support N.O. or N.C. sensors (EOLR supervision required for UL installations).
 - b. Zones/Points shall be individually assignable to one of eight (8) partitions.
 - c. Support up to 32 two-wire smoke detectors on two selected zones (64 total).
 - d. Support four-wire smoke or heat detectors on any zone (power to four-wire smoke detectors must be supervised with an EOL device).
 - e. Support up to 50 two-wire latching glass break detectors on one selected zone.
 - f. Individually assignable to Notification Appliance (NAC) outputs and/or auxiliary relays.

2. Optional Expansion Zones
 - a. Polling Loop Expansion – The control shall support up to 120 additional hardwire zones using a built-in two-wire polling (multiplex) loop interface. The polling loop shall provide power and data to remote point modules, and constantly monitor the status of all zones on the loop. Maximum current draw shall not exceed 128 mA. The polling loop zones shall have the following characteristics:
 - (1) Interface with RPM (Remote Point Module) devices that provide Class B, Style Y (e.g., 4208U/4208SN) or a combination of Class B, Style Y, and Class A, Style Z (e.g., 4208SNF) zones.
 - (2) Individually assignable to one of eight (8) partitions.
 - (3) Individually assignable to NAC outputs or auxiliary relays.
 - (4) Supervised by the control panel.
 - (5) A 12,000 ft (3658 m) wire run capability without using shielded cable.

- (6) Each RPM (Remote Point Module) enclosure shall be tamper protected.
 - b. Wireless Expansion – The control shall support up to 128 wireless zones using a 5800 series RF receiver (fewer if using hardware and/or polling loop zones). Wireless zones shall have the following characteristics:
 - (1) Supervised by control panel for check-in signals (except certain non-supervised transmitters).
 - (2) Tamper-protection for supervised zones.
 - (3) Individually assignable to one of the partitions.
 - (4) Individually assignable to bell outputs and or auxiliary relays.
 - (5) Support wireless devices listed for Commercial Burglary using the 5881ENHC RF Receiver.
3. Partitions – The control shall provide the ability to operate eight (8) separate areas, each functioning as if it had its own control. Partitioning features shall include:
 - a. A Common Lobby partition (1-8), which can be programmed to perform the following functions:
 - (1) Arm automatically when the last partition that shares the common lobby is armed.
 - (2) Disarm when the first partition that shares the common lobby is disarmed.
 - b. A Master partition (9), used strictly to assign keypads for the purpose of viewing the status of all eight (8) partitions at the same time (master keypads).
 - c. Assignable by zone.
 - d. Assignable by keypad/annunciator.
 - e. Assignable by relay to one or all eight (8) partitions.
 - f. Ability to display fire and/or burglary and panic and/or trouble conditions at all other partitions' keypads (selectable option).
 - g. Certain system options selectable by partition, such as entry/exit delay and subscriber account number.
4. User Codes – The control shall accommodate 150 user codes, all of which can operate any or all partitions. Certain characteristics must be assignable to each user code, as follows:
 - a. Authority level (Master, Manager, or several other Operator levels). Each User Code (other than the installer code) shall be

- capable of being assigned the same or a different level of authority for each partition that it will operate.
- b. Opening/Closing central station reporting option.
 - c. Specific partitions that the code can operate.
 - d. Global arming capability (ability to arm all partitions the code has access to in one command).
 - e. Use of an RF (button) to arm and disarm the system (RF key must first be enrolled into the system).
5. Peripheral Devices – The control shall support up to 30 addressable ECP devices, which can be any combination of keypads, RF receivers, relay modules, annunciator modules, and interactive phone modules. Peripheral devices have the following characteristics:
- a. Each device set to an individual address according to the device's instructions.
 - b. Each device enabled in system programming.
 - c. Each device's address shall be supervisable (via a programming option).
6. Keypad/Annunciator – The control shall accommodate up to 16 keypads or six (6) touch-screen (i.e.; advanced user interface) keypads. The keypads shall be capable of the following:
- a. Performing all system arming functions.
 - b. Being assigned to any partition.
 - c. Providing four programmable single-button function keys, which can be used for:
 - (1) Panic Functions –activated by wired and wireless keypads; reported separately by partition.
 - (2) Keypad Macros –32 keypad macro commands per system (each macro is a series of keypad commands). Assignable to the A, B, C, and D keys by partition.
7. Optional Output Relays - A total of 96 relay outputs shall be accommodated using relay modules. Each relay module shall provide four (4) Form C (normally open and normally closed) relays for general-purpose use or two (2) Class-B, Style-Y supervised notification appliance circuit outputs, when using the 4204CF module. The relays shall be capable of being:
- a. Programmed to activate in response to system events.
 - b. Programmed to activate using time intervals.

- c. Activated manually using a relay command mode.
 - d. Assigned an alpha descriptor.
 - e. Used for Class B, Style-Y supervised bell outputs (4204CF module).
 - f. A combination of 4204 (ECP) and 4101SN (polling loop) relays.
8. Optional Vista Interactive Phone Module – The control shall support the ADEMCO 4285/4286 VIP Modules, which permit access to the security system in order to perform the following functions:
- a. Obtain system status information.
 - b. Arm and disarm the security system.
 - c. Control relays.
9. Optional LED Annunciator – The control shall support the ADEMCO FSA-8 and FSA-24 annunciators, which are capable of:
- a. Visually identifying a zone or point that is in alarm or trouble.
 - b. Programmable for system silence/reset.
 - c. Up to 96 LEDs may be used in one system.
 - d. A total of four (4) FSA-24 or 12 FSA-8 annunciators may be used in one system.
 - e. An optional keyswitch, FSAKSM module, shall be available for UL listed Silence and Reset capability.
10. Notification Appliance Circuits (NAC) – The Control Panel shall internally provide two supervised NAC outputs for operating fire and burglar alarm notification appliances. It shall also support additional supervised bell outputs when using 4204CF relay modules. Each NAC output shall be rated at 10-14 VDC, 1.7 amp max power limited. Total alarm current draw when using two NAC outputs shall not exceed 2.3 amps for battery independent operation.
11. Auxiliary Relay – A built-in Form C relay shall be provided. The relay contacts shall be rated at 28 VAC/VDC, 2.8 amps maximum. The relay shall support:
- a. Alarm activation.
 - b. Trouble/supervisory activation.
 - c. Reset of four-wire smoke detectors.
 - d. Battery saving feature.
12. Integrated Access Control – The control shall be capable of the following:

- a. Providing a command that activates relays to allow access doors to open (e.g., lobby door), lights to be turned on or off, etc.
 - b. Becoming a fully integrated access control system by using numerous VistaKey Single-Door Access Control Modules.
 - c. Supporting up to eight (8) VistaKey Access Control Modules. The VistaKey Access Control Modules shall use the same Compass Downloader as the Vista-128FBP and shall be programmable from the Compass Downloader or the Keypad/Annunciators.
 - d. Assigning any number of access control relays to each partition (up to 96 for the system).
 - e. Supporting up to 250 access card holders using VistaKey.
 - f. Connecting to the ADEMCO PassPoint Access Control System via the Vista Gateway Module (VGM).
13. CCTV Switching – The System shall be capable of supporting the VistaView 100 CCTV Switching System. The CCTV system shall be fully integrated and be event driven by Fire, Burglary or Access events. When cameras are not event driven, they shall be driven by an automatic preset dwell time. The system shall also be capable of:
- a. Activating the CCTV system via a Form-C relay output.
 - b. Operating up to 60 camera inputs and 30 video outputs.
14. Commercial Wireless Equipment – The Control shall be compatible with UL Listed Commercial Wireless Fire & Security equipment including:
- a. ADEMCO 5881ENHC Commercial Fire/Burg Receiver. - The receiver shall be capable of receiving as many points as the control panel is rated for. Up to two (2) receivers may be used on any system. Receivers may be remotely located anywhere on the system Keypad/Annunciator bus.
 - b. ADEMCO 5808LST Wireless Photoelectric Smoke and Heat Detector - The device shall be UL 268 listed and shall have Maintenance Alert capability and Automatic Drift Compensation.
 - c. ADEMCO 5809 Wireless 135D Fixed Temperature and Rate of Rise Heat Detector - The device shall be UL 521 listed for commercial applications.
 - d. ADEMCO 5817CB Wireless Universal Contact Monitoring Transmitter - This device shall be capable of making any conventional UL listed contact device a wireless device. The device shall be UL listed for commercial fire and burglary applications as follows: UL 864, 985 for fire and UL 365, 609, 1023, 1076 and 1610 for security and nurse call.

- e. ADEMCO 5869 Wireless Hold Up Switch/Transmitter - This device shall be UL 636 listed for commercial burglary applications.
15. Optional Keypad – The control shall support the ADEMCO 4146 Keypad on any one of the system's eight (8) partitions. If used, zone 7 is no longer available as a protection zone.
 16. Voltage Triggers – The system shall provide voltage triggers, which change state for different conditions. Used with long-range radio (LRR) equipment or other devices such as a remote keypad sounder, keypad ARMED and READY LEDs, or a printer to print the system's event log.
 17. Event Log – The System shall maintain a log of different event types (enabled in programming). The event log shall provide the following characteristics:
 - a. Stores up to 512 events.
 - b. Viewable at the keypad or through the use of Compass software.
 - c. Printable on a serial printer using a 4100SM Module including zone alpha descriptors.
 - d. Stores PassPoint access control events.
 - e. Sends printed events to up to eight (8) alphanumeric pagers.
 18. Scheduling - Provides the following scheduling capabilities:
 - a. Open/close schedules (for control of arming/disarming and reporting).
 - b. Holiday schedules (allows different time windows for open/close schedules).
 - c. Timed events (for activation of relays, auto-bypassing and un-bypassing, auto-arming and disarming, etc.).
 - d. Access schedules (for limiting system access to users by time)
 - e. End User Output Programming Mode (provides 20 timers for relay control).
 - f. The system shall automatically adjust for daylight savings time.
 19. Communication Features - Supports the following formats and features for the primary and secondary central station receivers:
 - a. Formats
 - (1) ADEMCO Low Speed (Standard or Expanded).
 - (2) Sescoa/Radionics.
 - (3) ADEMCO Express.

- (4) ADEMCO High Speed.
 - (5) ADEMCO Contact ID.
 - b. Backup reporting – The system shall support backup reporting via the following:
 - (1) Secondary phone number.
 - (2) ECP long-range radio (LRR) interface.
 - (3) Option to select long range radio (LRR) or dialup as the primary reporting method (dynamic signaling feature).
 - c. Internet reporting – The system shall be capable of communicating with the central station via the internet using Alarmnet-i. It shall provide the user with the ability to control the system via a browser interface (i.e., AOL, Netscape, Internet Explorer). All packet data transmitted to the monitoring station shall be encrypted with a minimum of 1024 bits of encryption.
- 20. Audio Alarm Verification Option - Provides a programmable Audio Alarm Verification (AAV) option that can be used in conjunction with an output relay to permit voice dialog between an operator at the central station and a person at the premises.
- 21. Cross-Zoning Capability - Helps prevent false alarms by preventing a zone from going into alarm unless its cross-zone is also faulted within five (5) minutes.
- 22. Pager Interface – The Control Panel shall be capable of sending event information to an alphanumeric pager via a VA-8201 pager interface device.
- 23. 24-Volt Power Supply – The Control Panel shall be compatible with a 24-Volt power supply module. The module shall supply two (2) 24 vdc, 3.4 amps, rectified, unfiltered outputs, which power:
 - a. Alarm notification appliances, including but not limited to sirens horns, bells and strobes.
 - b. Auxiliary devices capable of operating using full-wave rectified unfiltered voltage.
- 24. Exit Error False Alarm Prevention Feature – The System shall be capable of differentiating between an actual alarm and an alarm caused by leaving an entry/exit door open. If not subsequently disarmed, the control panel shall:
 - a. Bypass the faulted E/E zone(s) and/or interior zones and arm the system.

- b. Generate an Exit Error report by user and by zone so the central station knows it was an exit alarm and who caused it.
25. Enhanced Fire Walk-Test Mode – The Control Panel shall provide the installer with the following features:
- a. Automatic test of all integrated remote point module (RPM) devices, equipped with an automatic test feature.
 - b. While automatic test is in progress all fire zones that remain untested shall be displayed.
 - c. An event log shall be capable of logging the results of tested and untested zones.
 - d. The ability to report the result of tested and untested zones to the central station.
26. Built-in User's Manual and Descriptor Review - For end-user convenience, the control panel shall contain a built-in User's Manual. It shall include the following capabilities:
- a. By depressing any of the function keys on the keypad for five (5) seconds, a brief explanation of that function shall scroll across the alphanumeric display.
 - b. By depressing the READY key for five (5) seconds, all programmed zone descriptors shall be displayed (one at a time). This feature shall provide a check for installers and ensure all descriptors have been entered properly.
27. Programming - The Control shall be capable of being programmed locally or remotely using the ADEMCO Compass Downloader and shall be capable of:
- a. Uploading and downloading all programming information at 300 baud.
 - b. Uploading and displaying firmware revision levels from the control.
28. Panel Linking - The Control shall be capable of being networked together with up to eight other controls and being operated by any keypad within the system. It shall provide the ability for users to:
- a. Control multiple zones, partitions, and/or buildings from a central location.
 - b. Check status, arm and disarm any partition from any keypad in the system.
 - c. Globally arm or disarm partitions based upon user authority.
29. Automation Software - The Control shall be capable of interfacing with automation software via an RS232 input on a single partition.

The control panel shall be the ADEMCO VISTA-128FBP Commercial Fire/Burglary Partitioned Security System or equivalent.

2.02 ENCLOSURE

- A. The Control Panel shall be enclosed in a metal cabinet, suitable for wall mounting. The dimensions shall not exceed 18 inches (45.7 cm) in height, 14.5 inches (36.8 cm) in width or 4.3 inches (10.9 cm) in depth.

2.03 ELECTRICAL POWER REQUIREMENTS

- A. System Power – The Fire and Burglary Alarm System shall operate using standard 120 volts AC, 50/60 Hz power.
 - 1. Control Primary Power – Transformer power shall be 18 VAC, 72 VA.
 - 2. Backup Battery – A rechargeable 12 VDC, gel type, lead acid backup battery shall be provided. The battery shall be rated between 12 and 34-ampere hours (AH).
 - 3. Alarm Power – Alarm power shall be 12 VDC, 1.7 amps for each bell output
 - 4. Auxiliary Standby Power – Standby power shall be 12 VDC, 1 amp maximum.
 - 5. Total Power - Combined auxiliary standby and alarm currents shall be 2.3 amps.
 - 6. Fusing – The battery input, auxiliary, and bell outputs shall be protected using PTC circuit breakers. All outputs shall be power limited.
 - 7. Power Supply - A 24-volt power supply shall provide 24 vdc, 3.4 amps full-wave rectified, unfiltered outputs.

2.04. ENVIRONMENTAL CONDITIONS

- A. Environmental Conditions – The Fire and Burglary Alarm System shall be designed to meet the following environmental conditions.
 - 1. Storage Temperature – The system shall be designed for a storage temperature of -10° C to 70°C.
 - 2. Operating Temperature - The system shall be designed for an operating temperature of 0° C to 50°C (32° F to 120°F).

3. Humidity - The system shall be designed for normal operation in an 85% relative humidity environment.
4. Electromagnetic Interference – The system shall meet or exceed the requirements of FCC Part 15, Class B devices, FCC Part 68, IEC EMC directive.

PART 3 EXECUTION

3.01 EXAMINATION

- A. Submission of a proposal confirms that the Contract Documents and site conditions are accepted without qualifications unless exceptions are specifically noted.
- B. The site shall be visited on a regular basis to appraise ongoing progress of other trades and contracts, make allowances for all ongoing work, and coordinate the requirements of this contract in a timely manner.

3.02 INSTALLATION

- A. The System shall be installed and tested in accordance with the Manufacturer's Installation instructions. The following conditions are applicable:
 1. In order to ensure a complete, functional System, for bidding purposes, where information is not available from the Owner upon request, the worst case condition shall be assumed.
 2. Interfaces shall be coordinated with the Owner's representative, where appropriate.
 3. All necessary backboxes, pullboxes, connectors, supports, conduit, cable, and wire shall be furnished and installed to provide a complete and reliable System installation. Exact location of all boxes, conduit, and wiring runs shall be presented to the Owner for approval in advance of any installation.
 4. All conduit, cable, and wire shall be installed parallel and square with building lines, including raised floor areas. Conduit fill shall not exceed forty percent (40%). All wires shall be gathered and tied up to create an orderly installation.

3.03 TESTING AND CERTIFICATION


- A. The Contractor shall demonstrate the functionality of the System upon completion of installation, documenting the result of all tests and providing these results to the Owner. The System shall be tested in accordance with the following:

1. The Contractor shall conduct a complete inspection and test of all installed equipment. This includes testing and verifying connection to equipment of other Divisions.
2. The Contractor shall provide staff to test all devices and all operational features of the System for witness by the Owner's representative and the Authority having jurisdiction. The Contractor shall provide two-way radio communications to assist in the testing. All testing must be witnessed by the owner's representative, prior to acceptance.
3. The testing and certification shall take place as follows:
 - a. System shall be tested in conjunction with the manufacturer's representative.
 - b. All deficiencies noted in the above test shall be corrected.
 - c. Test results shall be submitted to the consultant or owner's representative.
 - d. System test witnessed by owner's representative and correction of any deficiencies noted.
 - e. The owner's representative shall accept the System.
 - f. System test shall be witnessed by the Authority having Jurisdiction, and any deficiencies that are noted shall be corrected.
4. A letter of certification shall be provided to indicate that the tests have been performed and all devices are operational.

END OF SECTION

6160CR-2

COMMERCIAL FIRE ALPHA KEYPAD
UL864 REV 9 LISTED



The 6160CR-2 is an addressable remote keypad intended for use in commercial fire applications with Honeywell's commercial fire control panels. The keys are continuously backlit for convenience and easy visibility. The LCD display

is backlit only when a key is depressed*, or when the system is in alarm or trouble condition.

*Note: The LCD may be programmed to remain on at all times (see panel instructions for details).

FEATURES

- Four programmable function keys
- Built-in sounder
- Seven Status LEDs
 - Armed (Red)
 - Ready (Green)
 - Power (Green)
 - Fire Alarm (Red)
 - Silenced (Yellow)
 - Supervisory (Yellow)
 - Trouble (Yellow)
- Large easy-to-read display
- Red removable door
- Physical
5.250" W x 7.437" H x 1.312" D

SPECIFICATIONS

Sounder

- High-quality speaker

Electrical

- 45mA standby 160mA in alarm (sounder, back light and LED on)

Compatibility

- Supports Control Panels
 - VISTA-32FB Rev 5 and higher
 - VISTA-128FBP Rev 4 and higher
 - VISTA-250FBP Rev 4 and higher

UL/CUL and residential Listed for commercial fire and burglary installations. To be employed with manufacturer's listed control units as indicated in the installation instructions.

Product specifications subject to change.

ORDERING

6160CR-2 Commercial Fire Alpha Keypad

For more information: www.honeywell.com/security/hsc

Automation and Control Solutions
Honeywell Security & Communications
2 Corporate Center Dr. Suite 100
Melville, NY 11747
1.800.467.5875
www.honeywell.com

L/6160CR2D/D
September 2009
© 2009 Honeywell International Inc.

Honeywell

5809

WIRELESS HEAT DETECTOR

SPECIFICATIONS:

• **Power:**

- 3V lithium battery (Duracell DL123A, Panasonic CR123A, Sanyo CR123A, Varta CR123A)
- Operating temperature: 40° to 140°F (6° to 60°C)
- Rate-of-rise temperature: 15°F (8°C) increase per minute (NOTE: Rate-of-rise sensor does not operate above 38°C)

- Fixed temperature: 135°F (57°C)
- Maximum spacing: 50 ft x 50 ft UL, 30 ft x 30 ft FM (refer to National Fire Alarm Code Standard NFPA 72 for application requirements)
- Dimensions: 4.4" diameter/2/2" deep

• **Agency Listings:**

- UL 521 Listed for Commercial (when using 5881EH Receiver) or

Residential applications

• **Wireless Transmission Path Test:**

- A good RF transmission path must be established from the proposed mounting location before permanently installing the detector. To determine that there is a good signal reception from the proposed location, perform the test procedure described in the installation instructions procedure.

MOUNTING THE DETECTOR:

- You can mount the 5809 on a wall or ceiling within the protection area:
- Wall mounting: Mount the detector 4" 6" from the ceiling
- Ceiling mounting: Mount the detector at least 4" from any wall. Make sure the normal ceiling temperature will not exceed 100°F (37.8° C).

- Refer to NFPA Standard 72 for detector spacing and other requirements. Maximum spacing for UL installations is 50' x 50'
- Avoid mounting the detector near heat generating devices (e.g. ovens, heat vents, furnaces, boilers)
- IMPORTANT: Heat detectors should

be used for property protection. Reliance should not be placed solely on heat detectors for life safety. When life safety is involved, smoke detectors MUST also be used. Detectors must not be painted.

TESTING THE DETECTOR:

The test procedure should be performed to determine a good RF transmission path and again after installation is completed.

- CAUTION: The fixed temperature sensor is intended for one-time use. Prolonged heat during testing can damage the unit. If used carefully following the instructions described below, the heat from a portable hair dryer can be used to test the unit. If the round disk on top of the detector detaches, the detector must be replaced.
- Activate the control panel's test mode

- Use either method (a) or (b) or activate the detector

- (a) Press and release the activation button on the PC board assembly OR
- (b) Holding a portable hair dryer about 12 to 18 inches away from the detector, turn the dryer on and aim the warm air at the side of the detector.

CAUTION: Aiming the dryer directly at the round disk on the detector can damage the unit to be replaced.

- The system's keypad should beep and the detector's ID should be displayed

- Exit the control's test mode
- FCC ID: CFS 8DL 5809

This device complies with part 15 of FCC rules.

Operation is subject to the following conditions:

- (1) This device may not cause harmful interference, and (2) this device must accept any interference received, including interference that may cause undesired operation.

ORDERING

5809 Heat Detector

Honeywell Security & Custom Electronics

Honeywell
2 Corporate Center Drive Suite 100
P.O. 9040
Melville, NY 11747
www.honeywell.com

L/5809/D
October 2007
© 2007 Honeywell International Inc.

Honeywell

5881ENHC

COMMERCIAL WIRELESS RECEIVER



The new 5881ENHC RF Receiver is designed for use with control panels that are approved for use in commercial fire and/or burglary installations. The receiver recognizes alarm, status and keypad control messages from wireless

transmitters operating at 345 MHz. The receiver also features a Spatial Diversity System that virtually eliminates "nulls" and "dead spots" within the coverage area.

FEATURES

- Front and back tamper for commercial fire/burg installations
- One or two receivers can be used to provide redundant coverage or extend coverage in large areas
- Spatial Diversity System virtually eliminates "nulls" and "dead spots" within the coverage area
- Can be mounted remotely, anywhere on the keypad bus, for extended coverage
- Compatible with all 5800 series wireless devices
- Connects to control panel via the keypad bus
- UL listed for Commercial Fire/Burg applications

COMPATIBLE CONTROLS

- VISTA-32FB
- VISTA-128FBP
- VISTA-250FBP
- FA1700 series
- VISTA-128BP
- VISTA-250BP
- FA1600 series

SPECIFICATIONS

Dimensions

- 7-3/8" W x 4-3/8" (10-7/8" with antennas) H x 1-7/16" D
188mm W x 112mm H
(277mm with antennas) x 37mm D

Input Voltage

- 12VDC (from control's keypad terminals)

Current

- 60mA (typical)

Operating Temperature

- 32° F to 122° F
(0° C to 50° C)

Interface Wiring

- RED: 12VDC input (+) Aux. power
- GREEN: Data out to control
- YELLOW: Data in from control
- BLACK: Ground (-)

Range

- 200 ft (60m) nominal indoors from wireless transmitters (the actual range to be determined with the security system in the Test mode)

Installation

- See product installation instructions for details on programming and mounting

UL Listings

- Commercial Fire UL 864
- Household Fire UL 985
- Household Burg UL 1023
- Commercial Burg UL 365, UL 609, UL 1076, UL 1610
- FM
- MEA
- CSFM

ORDERING

5881ENHC

Commercial Wireless Receiver

Automation and Control Solutions
Honeywell Security & Communications
2 Corporate Center Dr. Suite 100
P.O. Box 9040
Melville, NY 11747
www.honeywell.com

L/5881ENHC/D
October 2008
© 2008 Honeywell International Inc.

Honeywell



PORTLAND MAINE

Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Receipts Details:

Tender Information: Check , BusinessName: visa, Check Number: 16651

Tender Amount: 90.00

Receipt Header:

Cashier Id: gguertin


Receipt Date: 8/7/2012

Receipt Number: 46790

Receipt Details:

Referance ID:	7530	Fee Type:	BP-Constr
Receipt Number:	0	Payment Date:	
Transaction Amount:	90.00	Charge Amount:	90.00
Job ID: Job ID: 2012-08-4634-FAFS -			
Additional Comments: 727 Congress St, Cunningham Security			


Thank You for your Payment!



APPROXIMATE
UNIT SQUARE FOOTAGES

UNIT #1	400 SF LOWER LEVEL
	474 SF FIRST FLOOR
	874 SF TOTAL
UNIT #2	689 SF LOWER LEVEL
	646 SF FIRST FLOOR
	1335 SF TOTAL
UNIT #3	873 SF
UNIT #4	819 SF
UNIT #5	990 SF
UNIT #6	847 SF
UNIT #7	744 SF
UNIT #8	598 SF THIRD FLOOR
	394 SF FOURTH FLOOR
	992 SF TOTAL

1 LOWER LEVEL FLOOR PLAN
SCALE: 1/8"=1'-0"



Prepared For Owner of Record:
Congress Place West, LLC
C/O 10 Dana Street, Suite 400
Portland, ME 04101
Attn: Thomas W. Moulton

Architect:
ARCHETYPE
a.r.c.h.i.t.e.c.t.s
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-4056


Project:
Condominium Plans
Longfellow Place
Condominium
77 CONGRESS STREET
PORTLAND, CUMBERLAND COUNTY, MAINE

Revisions:

Date: 21 June 2012
Scale: 1/8" = 1'-0"

LOWER LEVEL
FLOOR PLAN


Sheet
1
of Five



APPROXIMATE
UNIT SQUARE FOOTAGES

UNIT #1	400 SF LOWER LEVEL
	474 SF FIRST FLOOR
	874 SF TOTAL
UNIT #2	689 SF LOWER LEVEL
	646 SF FIRST FLOOR
	1335 SF TOTAL
UNIT #3	873 SF
UNIT #4	819 SF
UNIT #5	990 SF
UNIT #6	847 SF
UNIT #7	744 SF
UNIT #8	598 SF THIRD FLOOR
	394 SF FOURTH FLOOR
	992 SF TOTAL

2 | FIRST FLOOR PLAN
SCALE: 1/8"=1'-0"



Prepared For Owner of Record:
Congress Place West, LLC
C/O 10 Dana Street, Suite 400
Portland, ME 04101
Attn: Thomas W. Moulton

Architect:
ARCHETYPE
architects
48 Union Wharf Portland, Maine 04101
(207) 772-6022 Fax (207) 772-1056


Project:
Condominium Plans
Longfellow Place
Condominium
77 CONGRESS STREET
PORTLAND, COMBRIAND COUNTY, MAINE

Revisions:

Date: 21 June 2012
Scale: 1/8" = 1'-0"

FIRST
FLOOR PLAN


Sheet
2
of Five



APPROXIMATE
UNIT SQUARE FOOTAGES

UNIT #1	400 SF LOWER LEVEL
	474 SF FIRST FLOOR
	874 SF TOTAL
UNIT #2	689 SF LOWER LEVEL
	646 SF FIRST FLOOR
	1335 SF TOTAL
UNIT #3	873 SF
UNIT #4	819 SF
UNIT #5	990 SF
UNIT #6	847 SF
UNIT #7	744 SF
UNIT #8	598 SF THIRD FLOOR
	394 SF FOURTH FLOOR
	992 SF TOTAL

3 | SECOND FLOOR PLAN
SCALE: 1/8"=1'-0"



Prepared for Owner of Record:
Congress Place West, LLC
C/O 10 Dana Street, Suite 400
Portland, ME 04101
Attn: Thomas W. Moulton


Architect:
ARCHETYPE
a r c h i t e c t s
48 Union Wharf, Portland, Maine 04101
(207) 772-6022 Fax (207) 772-0156

Project:
Condominium Plans
Longfellow Place
Condominium
77 CONGRESS STREET
PORTLAND, CUMBERLAND COUNTY, MAINE


Revisions:

Date: 21 June 2012
Scale: 1/8" = 1'-0"

Sheet
3
of Five




4 | THIRD FLOOR PLAN
SCALE: 1/8"=1'-0"



5 | FOURTH FLOOR PLAN
SCALE: 1/8"=1'-0"

APPROXIMATE
UNIT SQUARE FOOTAGES

UNIT #1	400 SF LOWER LEVEL
	474 SF FIRST FLOOR
	874 SF TOTAL
UNIT #2	689 SF LOWER LEVEL
	646 SF FIRST FLOOR
	1335 SF TOTAL
UNIT #3	873 SF
UNIT #4	819 SF
UNIT #5	990 SF
UNIT #6	847 SF
UNIT #7	744 SF
UNIT #8	598 SF THIRD FLOOR
	394 SF FOURTH FLOOR
	992 SF TOTAL



Prepared For Owner of Record:
Congress Place West, LLC
C/O 10 Dana Street, Suite 400
Portland, ME 04101
Attn: Thomas W. Moulton

Architect:
ARCHETYPE
a.r.c.h.i.t.e.c.t.s
48 Union Wharf, Portland, Maine 04101
(207) 772-6022 Fax (207) 772-6056

Project:
Condominium Plans
Longfellow Place
Condominium
727 CONGRESS STREET
PORTLAND, CUMBERLAND COUNTY, MAINE

Revisions:

Date:
21 June 2012

Scale:
1/8" = 1'-0"

THIRD AND FOURTH
FLOOR PLAN

Sheet
4
of Five