CITY OF PORTLAND

FIRE PREVENTION BUREAU

380 Congress Street, Portland, Maine 04101 fireprevention@portlandmaine.gov (207) 874-8400

NOTICE OF VIOLATION AND ORDER TO CORRECT

July 6, 2017

Responsible Party 1:			
G B S REALTY LLC			
693 CONGRESS ST			
PORTLAND, ME 04102			
Location	CBL	Inspection Date	
691 CONGRESS ST	047 C033001	6/13/2017	
Inspector	Inspection Type	Status	

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 7/30/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
NFPA 10- 7.2.4.4 FIRE EXTINGUISHER INSPECTION TAG ; Where manual inspections are conducted, records for manual inspections shall be kept on a tag or label attached to the fire extinguisher, on an inspection checklist maintained on file, or by an electronic method. Extiguishers located on floor in the boiler room in the basement.	
1-14-3.2 EMERGENCY LIGHTING AND EXIT SIGNS SHALL BE TESTED ; EMERGENCY LIGHTING FACILITIES AND EXIT SIGNS SHALL BE TESTED MONTHLY FOR 30 SECONDS AND ANNUALLY FOR 90 MINUTES, AND WRITTEN RECORDS SHALL BE MAINTAINED.	
None of the emergency lights were working.	
NFPA 211- 9.5.1 CLEARANCE PROTECTION NOT PROVIDED; Clearances from connectors to combustible material shall be in accordance with the requirements of 9.5.1.1 through 9.5.5.3 for both unprotected and protected installations. Bikes are hanging in front of the boiler, blocking the sprinkler protection. Also hanging in front of the electical panel across from boiler	
FINAL DATE OF COMPLETED VIOLATION(S)	/ /
	//
FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)	/ /

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.

VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau <u>prior to the deadline</u> to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

Date	Responsible Party
Date	Responsible Party
SEEN AND AGREED	
Date	Fire Prevention Bureau