

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK

CITY OF PORTLAND

BUILDING INSPECTION

PERMIT

Please Read Application And Notes, If Any, Attached

Permit Number: 070191

PERMIT ISSUED
APR -- 9 2007
CITY OF PORTLAND

This is to certify that FACTORS FINANCIAL ER INC /Bourgoin & Sons

has permission to Install Type 1 hood System w fire Suppression

AT 685 CONGRESS ST

047 C084001

provided that the person or persons who accept this permit shall comply with all of the provisions of the Statutes of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of buildings and structures, and of the application on file in this department.

Apply to Public Works for street line and grade if nature of work requires such information.

Notification of inspection must be given and when permission is procured before this building or part thereof is used or service closed-in. 4 HOUR NOTICE REQUIRED.

A certificate of occupancy must be procured by owner before this building or part thereof is occupied.

OTHER REQUIRED APPROVALS

Fire Dept. _____

Health Dept. _____

Appeal Board _____

Other _____
Department Name

Jeanie Bonke 3/19/07
Director - Building & Inspection Services

PENALTY FOR REMOVING THIS CARD

City of Portland, Maine - Building or Use Permit

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716


Permit No: 07-0191	Date Applied For: 02/22/2007	CBL: 047 C034001
------------------------------	--	----------------------------

Location of Construction: 685 CONGRESS ST	Owner Name: FACTORS FINANCIAL FRC INC	Owner Address: PO BOX 7002	Phone:
Business Name:	Contractor Name: Bourgoin & Sons	Contractor Address: 123 Davis Road Durham	Phone: (207) 749-1878
Lessee/Buyer's Name	Phone:	Permit Type: Hood Systems, Commerical	

Proposed Use: Commercial Restaurant - Install Type 1 hood System w/ Fire Suppression	Proposed Project Description: Install Type 1 hood System w/ Fire Suppression
--	--

Dept: Zoning	Status: Approved	Reviewer: Marge Schmuckal	Approval Date: 02/27/2007	Note:	Ok to Issue: <input checked="" type="checkbox"/>
Dept: Building	Status: Approved with Conditions	Reviewer: Jeanine Bourke	Approval Date: 03/19/2007	Note: 1) The Hood shall be installed per IMC 2003 and NFPA 96 2) Application approval based upon information provided by applicant. Any deviation from approved plans requires separate review and approval prior to work.	Ok to Issue: <input checked="" type="checkbox"/>
Dept: Fire	Status: Approved with Conditions	Reviewer: Cptn Greg Cass	Approval Date: 03/06/2007	Note: 1) This hood is not compatible with solid fuel cooking. NFPA 96 compliance letter required	Ok to Issue: <input checked="" type="checkbox"/>

Comments:
3/16/2007-jmb: left vmail w/Dan B. For clearance to combustibile at top of hood
3/19/2007-jmb: Dan B. Called to confirm the distance from the top of the hood to the drop celing is 2-3 feet and from the hood to the steel I-beams is 6 feet. Ok to issue






General Building Permit Application

If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Address of Construction: <u>685 CONGRESS ST</u>		
Total Square Footage of Proposed Structure		Square Footage of Lot
Tax Assessor's Chart, Block & Lot Chart# <u>47</u> Block# <u>C</u> Lot# <u>34</u>		Owner: <u>William Black</u> Telephone:
Lessee/Buyer's Name (If Applicable) <u>Jay Ullani</u>	Applicant name, address & telephone: <u>Below -</u> <u>207-272-3004</u>	Cost Of Work: \$ <u>13900.00</u> Fee: \$ _____ C of O Fee: \$ _____
Current Specific use: <u>VACANT</u> If vacant, what was the previous use? <u>Commercial Building</u> Proposed Specific use: <u>RESTAURANT</u>		
Project description: <u>Install Type I Hood system with Fire Suppression</u>		
Contractor's name, address & telephone: <u>Dan Bourgain 749-1878</u>		
Who should we contact when the permit is ready: <u>Dan Bourgain Bourgain Sons LLC</u> Mailing address: _____ Phone: <u>749-1878</u>		



Please submit all of the information outlined in the Commercial Application Checklist. Failure to do so will result in the automatic denial of your permit.

In order to be sure the City fully understands the full scope of the project, the Planning and Development Department may request additional information prior to the issuance of a permit. For further information visit us online at www.portlandmaine.gov, stop by the Building Inspections office, room 315 City Hall or call 874-8703.

I hereby certify that I am the Owner of record of the named property, or that the owner of record authorizes the proposed work and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the City's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this project.

Signature of applicant: <u>Dan Bourgain</u>	Date: <u>2/22/07</u>
---	----------------------

This is not a permit; you may not commence ANY work until the permit is issued.



PORTLAND MAINE


Strengthening a Remarkable City, Building a Community for Life • www.portlandmaine.gov

Lee Urban- Director of Planning and Development
Michael J. Nugent- Inspections Division Director

Kitchen Exhaust System Checklist and Code Provisions

Dear Applicant,

The following is a checklist to assist you in filing for a permit for a Kitchen Exhaust system. The applicable Mechanical Code provisions have also been attached. Please complete this and submit job specific construction documents that demonstrate compliance with the attached information.



Type of System:

Type I Type II

(Type I systems are systems that vent fryers, grills, broilers, ovens or woks. Type II systems are systems that vent steamers and other non grease producing appliances)

Type of Materials:

Is the hood Stainless steel or other type of steel? Stainless Steel If Other, what Type? _____

Is the duct work Stainless steel or other type of steel? other If Other, what type? Crs Steel 16ga

Thickness of the steel for the hood 16ga

Thickness of the duct for the hood 16ga

Type of Hood and Duct supports

Canopy Hood thread to rod

Type of seams and Joints Solid welded

Grease Gutters provided? _____

Hood Clearance from Combustibles materials 18" or wrap

Duct Clearance from Combustibles materials 18" or wrap 3m grease duct wrap

Vibration Isolation System:

N/A

Air Velocity within the duct system .75 static pressure

Grease accumulation prevention system

grease

Cleanouts N/A 8' ft run no 90°

Grease Duct enclosure 3m grease duct fire barrier duct wrap

Exhaust Termination roof

Fire Suppression

system 6 Gallon wet chemical

Exhaust fan mounting and clearance from the roof or wall 18" off roof
40 to TCP

Exhaust fan distance from other vents or opening 10'

Exhaust fan height above adjoining grade 10'

Hood Specs

Style of hood 4' S/S wall mounted

Type of Filter: ALUMINUM BAFFLE

Height of filter above nearest cooking surface: 56"

Capacity of hood in CFM 5300

Makeup Air system description and capacity

roof mounted 10' from exhaust return 2310 cfm
10'

rubber roof

4" Concrete Slab

I-Beam are space 4' on ctr

12" I-Beam
3/8 web

Per Draw
3/16/07 - 6'

hanger 3/8 thread rod 6-piece. Hood w. 11 support from I-Beams.

3" air space behind hood


Back 24 ga galv metal sheet 1" min wool insulation face w. to 24 ga galv.


1" metal spacer for 1" air space

6'-6"

Wall 3/8 sheet rock on metal studs on other side 3/8 sheet rock


Floor





Duct 16ga solid welded
 Duct work to be wrap in 3m fire barrier
 grease duct wrap

3/9/07 per Dan Bougoin
 The whole length of stack
 is wrapped
 jmb



SECTION VIEW - MODEL 4812-SND-2 with PSP Accessory

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with NO Exception Taken


Revise and Resubmit

SIGNATURE *[Signature]*

Your Title _____ Date _____

CAPTIVE AIR

JOB	Local 188	
LOCATION		
DATE	2/2/2007	JOB # 548819
DWG #	Local188	DRAWN BY BFC
REV	2.00	SCALE 0.5" = 1'-0"



PLAN VIEW - 11' 0.00" LONG 4812SND-?-PSP-F


CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted
 Approved with Exception Taken
 Revise and Resubmit
 SIGNATURE *[Signature]*
 Your Title _____ Date _____

CAPTIVE AIR

JOE Local 138	
LOCATION	
DATE 2/2/2007	JOB # 548819
DWG # Local188	DRAWN BY BFC

NCAFA SERIES UPBLAST EXHAUST FANS (UL762)



FEATURES:

- ROOF MOUNTED FANS
- RESTAURANT MODEL
- UL762
- AMCA SOUND AND AIR CERTIFIED
- WIRING FROM MOTOR TO DISCONNECT SWITCH
- WEATHERPROOF DISCONNECT
- HIGH HEAT OPERATION 300°F (149°C)
- GREASE CLASSIFICATION TESTING

NORMAL TEMPERATURE TEST

EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING AIR AT 300°F (149°C) UNTIL ALL FAN PARTS HAVE REACHED THERMAL EQUILIBRIUM, AND WITHOUT ANY DETRIMENTAL EFFECTS TO THE FAN WHICH WOULD CAUSE UNSAFE OPERATION.


ABNORMAL FLARE-UP TEST

EXHAUST FAN MUST OPERATE CONTINUOUSLY WHILE EXHAUSTING BURNING GREASE VAPORS AT 600°F (316°C) FOR A PERIOD OF 15 MINUTES WITHOUT THE FAN BECOMING DAMAGED TO ANY EXTENT THAT COULD CAUSE AN UNSAFE CONDITION.


OPTIONS:

- GREASE BOX
- HINGED FAN
- PITCHED CURB
- INSULATED CURB

DUCTWORK BETWEEN EXHAUST RISER (ON HOOD) AND FAN (BY OTHERS)



PITCHED CURBS ARE AVAILABLE FOR PITCHED ROOFS.



SPECIFY PITCH:
EXAMP 7/12 PITCH = 30° SLOPE

NCAFA BELT DRIVE CENTRIFUGAL UP-BLAST EXHAUST FANS DIMENSIONAL DATA

FAN MODEL	HT	W	B	C	F	R	RD	WEIGHT LB
NCA16FA	33 3/4"	38"	2"	28"	23 1/2"	16 1/2"	24 1/2"	190

CURB DIMENSIONAL DATA

FAN MODEL	D	E
NCA16FA	26 1/2"	20"

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with NO Exception Taken

Revised and Resubmit

SIGNATURE *Paul Meyer*

Your Title _____ Date _____



JOB Local 188	
LOCATION	
DATE 2/2/2007	JOB # 548819
DWG # Local188	DRAWN BY BFC
REV. 2.00	SCALE 8.5" x 11"

FAN INFORMATION

FAN UNIT NO.	FAN UNIT MODEL #	EXHAUST FAN										SUPPLY FAN									
		MODEL	TAG	CFM	S.P.	RPM	H.P.	Ø	VOLT	FLA	BLOWER	HOUSING	TAG	CFM	S.P.	RPM	H.P.	Ø	VOLT	FLA	
1	NCA16FA	NCA16FA		3300	1.000"	1129	1500	1	115	20.4											
2	NSAU1-G10										G10	NSAU1		2310	0.250"	777	1000	1	115	14.0	

FAN OPTIONS

FAN NO.	OPTION (Qty. - Descr.)
1	1 - Grease Box
2	1 - Gravity Backdraft Damper for Size 1 Housing

CURB ASSEMBLIES

NO.	ON FAN	ITEM	SIZE
1	# 1	Curb	26.500"W x 26.500"L x 20.000"H Vented Hinged
2	# 2	Curb	23.000"W x 23.000"L x 14.000"H

CUSTOMER APPROVAL TO MANUFACTURE:

Approved Noted

Approved with NO Exception To an

Revise and Resubmit

SIGNATURE *[Signature]*

Your Title _____ Date _____




JOB	Loc	188
LOCATION		
DATE	2/2/2007	JOB # 548819
DWG #	Local188	DRAWN BY BFC
REV.	2.00	SCALE 8.5' x 11'

NSAU-1 AND NSAU-2 SERIES DOWN DISCHARGE SUPPLY FANS



SUPPLY AIR UNIT DIMENSIONAL DATA

MODEL	BLOWER	HP RANGE	A	B	C	D	E	F	FILTER QTY.	FILTER SIZE	WEIGHT
NSAU-1	G-10	.33 - 2	26	32	28	20	20	26	2	16" X 20"	175 LBS
NSAU-2	G-12	.33 - 3	36	40	35	28.5	25	29	2	20" X 25"	275 LBS
	G-15	.75 - 5						53.75	3	20" X 25"	315 LBS




CURB/ROOFTOP DIMENSIONAL DATA

MODEL	BLOWER	E	H	J	K
NSAU-1	G-10	23	14	11-3/4	13-1/2
NSAU-2	G-12	32.5	14	13-3/4	15-7/8
	G-15			16-1/8	18-7/8

PITCHED CURBS ARE AVAILABLE FOR PITCHED ROOFS.

SPECIFY PITCH:
EXAMPLE: 7/12 PITCH = 30° SLOPE



CAPTIVE-AIRE SYSTEMS, INC. RESERVES THE RIGHT TO MODIFY THE DESIGN, MATERIALS AND/OR SPECIFICATIONS AS A RESULT OF CODE REQUIREMENTS OR PRODUCT ENHANCEMENTS RESULTING FROM ONGOING RESEARCH AND DEVELOPMENT.

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted
 Approved with NO Exception Taken
 Revise and Resubmit
 SIGNATURE *[Signature]*
 Your Title _____ Date _____



JOB	Local 188
LOCATION	
DATE	2/2/2007
JOB #	548819
DWG #	Local188
DRAWN BY	BFC
REV.	2.00
SCALE	AS SHOWN

HOOD INFORMATION

HOOD NO.	MODEL	LENGTH	MAX. COOKING TEMP.	EXHAUST PLENUM					SUPPLY PLENUM					HOOD CONSTRUCTION	HOOD CONFIG.		
				TOTAL EXH. CFM	RISER(S)				TOTAL SUP. CFM	RISER(S)					END TO END	ROW	
					WIDTH	LENG.	DIA.	CFM		S.P.	WIDTH	LENG.	DIA.				CFM
1	4812 ND-2-PSP	11' 0.00"Nom. 11' 0.00"OD	600 Deg.	3300	12'	26'		3300	-0.673'	2310					430 SS 100%	ALONE	N/A

HOOD INFORMATION

HOOD NO.	FILTER(S)				LIGHT(S)			UTILITY CABINET(S)					FIRE SYSTEM PIPING	HOOD WEIGHT	
	TYPE	QTY	HEIGHT	LENGTH	QTY	TYPE	WIRE GUARD	LOCATION	FIRE SYSTEM		ELECTRICAL	SWITCHES			
									TYPE	SIZE	MODEL #	QUANTITY			LOCATION
1	Alum. Baffle w/ Handle	2 5	16" 16"	16" 20"	4	Incandescent Light	NO							NO	356 LBS.

PERFORATED SUPPLY PLENUM(S)

HOOD NO.	POS.	LENGTH	WIDTH	HEIGHT	RISER(S)				
					WIDTH	LENG.	DIA.	CFM	S.P.
1	Front	132'	16'	6'	10"	28"		1155	0.174'
					10"	28"		1155	0.174'

THE HOOD MAY BE INSTALLED WITH A 0 INCH CLEARANCE TO COMBUSTIBLE MATERIALS IF CONSTRUCTED IN ONE OF THE FOLLOWING METHODS:


- 3" UNINSULATED STANDOFF
- 1" INSULATED STANDOFF
- 1" INSULATED BACKSPASH
- BACK RETURN SUPPLY PLENUM

TABLE 1


1. ALL ELECTRICAL FIELD CONNECTIONS AND RELATED INTERCONNECTIONS BY ELECTRICAL CONTRACTORS.
2. ALL PLUMBING FIELD CONNECTIONS AND RELATED INTERCONNECTIONS BY PLUMBING CONTRACTORS.
3. ALL ASSOCIATED HANGING INTERIORS BY INSTALLING CONTRACTORS.
4. 8" LONG FACTORY SUPPLIED AND WELDED HANGER BRACKETS AS SHOWN ON PLANS.
5. ALL CONNECTIONS FROM CAPTIVE-AIRE DUCT PER THE PLANS BY MECHANICAL CONTRACTORS.
6. ALL LIGHTS SHOWN SHALL BE CAPTIVE-AIRE, ARE FACTORY PROVIDED PER THE PLANS, INTERCONNECTIONS BETWEEN HOODS AND TO SWITCHES BY ELECTRICAL CONTRACTOR.
7. LAMPS FOR LIGHT FIXTURES BY INSTALLING CONTRACTORS.
8. SEISMIC RESISTANTS ARE RESPONSIBILITY OF INSTALLING CONTRACTOR.
9. INSTALLING CONTRACTORS ASSUME ALL RELATED RESPONSIBILITY FOR VERIFICATION OF DIMENSIONAL DATA CONTAINED ON THESE DOCUMENTS FOR ACCURACY, INTEGRITY AND ADMINISTRATION OF CODE REQUIREMENTS IN EFFECT PRIOR TO ANY RELEASE FOR PRODUCTION OF EQUIPMENT SHOWN.
10. SIGNED AND "APPROVED" COPIES OF THIS DOCUMENT MUST BE RECEIVED BY THE FACTORY PRIOR TO COMMENCEMENT OF FABRICATION.
11. NOMINAL HOOD DIMENSIONS AS SHOWN ON DRAWINGS.

GENERAL NOTES

CAPTIVE-AIRE HOODS ARE BUILT IN COMPLIANCE WITH



NFPA #96
NSF
UL 710 & ULC710 STANDARDS
E.T.L. LISTED 3054804-001



EXHAUST CFM - LENGTH OF HOOD : CFM/INCH. (LOAD)

SUPPLY CFM = EXHAUST CFM X PERCENTAGE REQUIRED

$$\text{TOTAL DUCT AREA} = 144 \times \frac{\text{CFM}}{\text{FPM}(\%)}$$

$$\text{DUCT LENGTH} = \frac{\text{TOTAL DUCT AREA}}{\text{DUCT DEPTH}}$$

*CAPTIVE-AIRE VENTILATOR DUCT SIZES ARE CALCULATED USING AN EXHAUST VELOCITY OF 1600-1800 FPM AND A SUPPLY VELOCITY OF 1000 FPM. PLEASE CONSULT FACTORY FOR MAXIMUM ALLOWABLE DUCT SIZES

CALCULATIONS UTILIZED

CUSTOMER APPROVAL TO MANUFACTURE:

Approved as Noted

Approved with NO Exception Taken

Revise and Resubmit

SIGNATURE *Dave Brown*

Your Title _____ Date _____



JOB	Local 188
LOCATION	
DATE	2/2/2007
DWG #	Local188
REV	201
JOB #	548819
DRAWN BY	BFC
SCALE	AS SHOWN