Master Box Approval

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/19/13

Applicant: Ray Kenneally

App Phone #: 207-828-1274

Building Name: Longfellow Commons

Building Address: 206 State St

Occupancy: 44 unit apartment building
Assembly OL>300, 20 unit apartment building, etc.

Emergency Contact: On call

Emergency phone #: 207-828-

Date of Application: 4/18/13

Billing Address: 206 State Stre
Portland, ME 04101

Comments:

**Applicant completes red box and submits with Fire Alarm Permit**

1

FIRE PREVENTION: ☑ Approved ☐ Denied

6 / 19 / 13
Date

Fire Prevention Officer

Zone 1: Water flow

Zone 2: City disconnect – Water Flow

Zone 3: Pulls and detectors

Zone 4: City disconnect – Pulls and Detectors

Zone 5: Unassigned

Zone 6: Unassigned

Zone 7: Unassigned

Zone 8: AES Tamper switch

Modify City Box response to alarm sounding in CAD: ☐ YES ☑ NO

2

FIRE ALARM: Box #: _____

3

ELECTRICAL DIVISION: ☐ Approved ☐ Denied

Box Type: AES Radio Box / _____
New Other

Test Date: _____/_____/_____ In Service Date: _____/_____/_____ _____
Fire Alarm Technician

AES

Circuit if applicable:

4

FIRE ALARM: Same Running Assignment As Box: _____

Notifications: ☐ All Stations ☐ Run Books ☐ Digitizer ☐ Computer ☐ Cad Box Test

☐ South Portland ☐ _____ _____
Other Dispatcher

5

BILLING: ☐ Entered _____
Financial Officer