Fire Alarm Permit

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

If you or the property owner owes real estate or property taxes or user charges on any pr
within the city, payment arrangements must be made before permits of any kind are acc

Date: 06/19/13

Installation address: ~~206 State St~~ 681 Congress CBL: 047 C035

Exact location: (within structure)

Type of occupancy(s) (NFPA & ICC): Residential (Multi Unit Apartment Building)

Building owner: Weston Associates MGMT

System Designer (point of contact): Marc Tardif (Must be)

Designer phone: 207-784-1507 E-mail: tardifml@efp-efs.com

Installing contractor: Eastern Fire Services Certificate of Fitness No: M1024

Contractor phone: 207-784-1507 E-mail: malcolmcr@efp-efs.com

This is a new application: YES ◉ NO ○ New AES Master Box: YES ○ NO ○
(Include Master Box approval form)

Amendment to an existing permit: YES ○ NO ○ Permit no:

The following documents shall be provided with this application:

- ☑ Floor plans
- ☑ Wiring diagram
- ☑ Annunciator details
- ☑ Input/ Output Matrix
- ☑ Equipment data sheets
- ☑ Electrical Permit Pulled (check alarm/com)
- ☑ Scope of Work
- ☑ 11 ½ x 17s
- ☑ pdf copy (may be e-mailed)
- ☑ Designer qualifications
- ☑ Battery/ voltage drop calcs

COST OF WORK: $ 75,000

PERMIT FEE: $ 770.00
($10 PER $1,000 + $30 FOR THE FIRST $1,000)

RECEIVED
FEB 15 2013
Dept. of Building Inspections
City of Portland Maine

Master box approval only: YES ○ NO ○
(If yes check *New AES Master Box* above)

The designer shall be the responsible party for this application. Download a new copy of this application at www.portlandmaine.gov/fire for every submittal. Submit all plans in electronic PDF in addition to readable 11 ½ x 17s to the Building Inspections Department, 389 Congress Street, Room 315, Portland, Maine 04101.

Prior to acceptance of any fire alarm system, a complete commissioning and acceptance test must be coordinated with all fire system contractors and the Fire Department, and proper documentation of such test(s) provided.

All installation(s) must comply with the *City of Portland Technical Standard for Signaling Systems for the Protection of Life and Property*, available at www.portlandmaine.gov/fire .

Applicant signature: Date: