Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/19/13

FIRE ALARM SYSTEM LAYOUT – SECOND FLOOR

SCALE: 1/8"=1'

FIRE ALARM SYSTEM LAYOUT – THIRD FLOOR

SCALE: 1/8"=1'

0 1" 2" 3"
0 8' 16' 24'
1/8"=1'-0" GRAPHIC SCALE

GENERAL NOTES	DATE	REVISIONS	REQUIRED APPROVALS
- SCOPE OF WORK: INSTALL NEW ADDRESSABLE FIRE ALARM			OWNER
SYSTEM. ALL INSTALLATION PRACTICES SHALL COMPLY			
WITH NFPA 70, 72			PORTLAND FIRE DEPARTMENT
- PHASE 1: INSTALL NEW CONTROL PANEL			
- PHASE 2: INSTALL NEW DEVICES			DRAWN BY CRM
- PHASE 2 TO BEGIN IMMEDIATELY FOLLOWING PHASE 1			
- HORN LOCATIONS IN DWELLING UNITS ARE FOR REFERENCE			CHECKED BY MLT
ONLY. AUDIBILITY WILL BE FEILD TESTED AND LOCATIONS			
MAY CHANGE TO ACHEIVE 75 DB AT THE PILLOW AND			CONTRACTOR LICENSE #
15 DB ABOVE AMBIENT SOUND THROUGHOUT UNIT			

LONGFELLOW COMMONS
206 STATE ST.
PORTLAND, ME

CONTRACT WITH: WESTON ASSOCIATES MGMT

EASTERN FIRE SERVICES, INC.
AUBURN/LEWISTON INDUSTRIAL AIRPARK, AUBURN, MAINE 04210

FIRE ALARM SYSTI

PLANS & DETAIL

DWG. NO.
2 OF 4

JOB NUMBER

SCALE
AS SHOWN

DATE
1/25/13