

## SYSTEM OUTPUTS

SYSTEM INPUTS		CONTROL UNIT ACTIVATION								NOTIFICATION					
		ACTUATE COMMON ALARM SIGNAL INDICATOR	ACTUATE AUDIBLE ALARM SIGNAL	ACTUATE COMMON SUPERVISORY SIGNAL	ACTUATE AUDIBLE SUPERVISORY SIGNAL INDICATOR	ACTUATE COMMON TROUBLE SIGNAL	DISPLAY ALPHA-NUMERIC COMMON TROUBLE SIGNAL	RECORD EVENTS IN THE SYSTEM MEMORY	TRANSMIT FIRE ALARM SIGNAL	TRANSMIT SUPERVISORY SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT TROUBLE SIGNAL TO REMOTE ALARM RECEIVING STATION	TRANSMIT ALARM SIGNAL TO MASTERBOX	TRANSMIT TROUBLE SIGNAL TO MASTERBOX		
		A	B	C	D	E	F	G	H	I	J	K	L	M	
1	ALARM SIGNAL FROM EXISTING FACP	●	●					●	●	●			●		1
2	SPRINKLER TAMPER			●	●			●	●		●				2
3	SPRINKLER WATERFLOW	●	●					●	●	●			●		3
4	FCPS POWER FAIL			●	●			●	●		●				4
5	FCPS GROUND FAULT					●	●	●	●			●			5
6	FCPS NOTIFICATION APPLIANCE CIRCUIT SHORT					●	●	●	●			●			6
7	MASTERBOX DISCONNECT SWITCH ACTIVATED					●	●	●	●					●	7
		A	B	C	D	E	F	G	H	I	J	K	L	M	

SUBMITTAL	DATE: 05/07/2015
CAUSE AND EFFECT MATRIX	
PROJECT NAME	BY
PAYSON BUILDING 100 STATE STREET PORTLAND, MAINE 04101	JRS
	SCALE
	NONE
	SHEET
	<b>MX-1</b>

