

DOORS 130, 129.1, 126.1, 128 shall be changed from 60 minute rated doors w/ closers to 20 minute rated doors with closers. Partitions that these doors are located in remain 1 hour rated.

WINTON SCOTT ARCHITECTS, PA
5 Milk Street
Portland, Maine 04101
207 774 4811

Portland Community Health Clinic- Renovation Project

ASK 6

November 30, 2012