

LEGEND


FIRE ALARM SYSTEM HORN/STROBE - CD PER NFPA 72 OR AS NOTED - MOUNTED C/L UP 84" ON WALL


- FIRE ALARM SYSTEM STROBE UNIT CD PER NFPA 72 OR AS NOTED MOUNTED C/L UP 84" ON WALL

 FIRE ALARM SYSTEM HORN/STROBE CD PER NFPA 72 OR AS NOTED CEILING MOUNTED
- F FIRE ALARM SYSTEM MANUAL PULL STATION MOUNTED C/L UP 48" ON WALL
- FIRE ALARM SYSTEM MANUAL PULL STATION MOUNTED C/L UP 48" ON V
- FIRE ALARM SYSTEM SMOKE DETECTOR CEILING MOUNTED
- EXIT SIGN CEILING MOUNTED WITH FACES & DIRECTIONAL ARROWS AS INDICATED
- EXIT SIGN WALL MOUNTED C/L UP 96" WITH FACES & DIRECTIONAL ARROWS AS INDICATED

 *** EMERGENCY PATTERY UNIT. WALL MOUNTED C/L UP 7/16"
- EMERGENCY BATTERY UNIT WALL MOUNTED C/L UP 7'-6"
- EMERGENCY BATTERY UNIT CEILING MOUNTED

 EMERGENCY DUAL REMOTE HEAD WALL MOUNTED C/L UP 7'-6"





HARRIMAN

AUBURN PORTLAND MANCHESTER


COMMUNITY DENTAL PORTLAND

180 Park Avenue

Portland, ME		
Harriman Project No.	16336	
Key Plan	Proj North	



Issue	Issues and Revisions		
Mark	Date	Description	
	04-22-16	STATE FIRE MARSHAL REVIE	



Drawing Scales			
PA / PE: JWT Drawn By: JWT	© 2016 Harriman Associates		

ELECTRICAL LIFE-SAFETY PLAN

E-LS