DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK





This is to certify that

180 PARK AVENUE LLC

Located at

180 Park Ave

PERMIT ID: 2016-01397 **ISSUE DATE:** 07/14/2016 **CBL:** 048 A001002

has permission to Complete renovations to existing building; no change of use for Community Dental. Extend rear handicap access ramp.

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED. A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Michael White

/s/ Laurie Leader

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning Medical offices Building Inspections
Use Group: B Type:
Medical Offices
ENTIRE

MUBEC/IBC 2009

Fire Department Classification: Business ENTIRE NFPA 2009

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY) or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Close-in Plumbing/Framing w/Fire & Draft Stopping Above Ceiling Inspection Electrical Close-in w/Fire & Draftstopping Final - Electric Final - Fire Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

City of Portland, Maine - Building or Use Permit		Permit No:	Date Applied For:	CBL:
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 87	4-8716	2016-01397	05/27/2016	048 A001002
roposed Use: Proposed Project Description:				
Dental offices/ Health Clinic			existing building; no nd rear handicap acco	
Note: R-6 zone Small extension of rear handicap ramp - will be >5' from side Conditions:		Christina Stacey e and >10' from re		tte: 07/01/2016 Ok to Issue: ☑
1) Separate permits shall be required for any new signage.				
 This permit is being approved on the basis of plans submitted. Any deviations shall require a separate approval before starting that work. 				
Dept: Building Inspecti Status: Approved w/Conditions Re Note: Conditions:	eviewer:	Laurie Leader	Approval Da	te: 07/12/2016 Ok to Issue: ☑
 Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems, fire suppression and fuel tanks. Separate plans may need to be submitted for approval as a part of this process. 				
2) This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
Dept:Engineering DPS Status:Not ApplicableReNote:	eviewer:	Rachel Smith	Approval Da	te: 06/07/2016 Ok to Issue: ☑
Conditions:				
 This approval is non-applicable to Engineering DPS as it relates to approval for Grease Control Equipment for the Fats, Oil, and Grease Program. If approval is needed for this project by the Engineering Department of Public Services for any other reason than FOG, please contact David Margolis-Pineo at 207-874-8850 or dmp@portlandmaine.gov 				
Dept:FireStatus:Approved w/ConditionsReNote:	eviewer:	Michael White	Approval Da	te: 07/14/2016 Ok to Issue: ☑
Conditions:				
1) The fire alarm technician shall be present for the fire inspection. System acceptance and commissioning must be coordinated with alarm and suppression system contractors and the Fire Department. Call 874-8400 to schedule.				
 Portable fire extinguishers shall be installed, inspected and maintained in accordance with NFPA 10, Standard for Portable Fire Extinguishers. (2009 NFPA 101, Chapter 9.7.4.1). 				
3) A Knox Box is required.				
5) All construction shall comply with City Code, Chapter 10.				
6) All construction shall comply with 2009 NFPA 1, Fire Code. Review and approval by the AHJ shall not relieve the applicant of the responsibility of compliance with this Code (Chapter 1.14.4).				
7) All construction shall comply with 2009 NFPA 101, Chapter 43 Building Rehabilitation.				
8) All construction shall comply with 2009 NFPA 101, Chapter 39 Exisiting Business Occupancies.				
9) The fire alarm system shall have a new fire alarm inspection sticker.				
10 Application requires State Fire Marshal approval.				

- 11 The Fire Alarm installation shall comply with the following: City of Portland Chapter 10, Fire Prevention and Protection; NFPA 1, Fire Code (2009 edition), as amended by City Code; NFPA 101, Life Safety Code (2009 edition), as amended by City Code; City of Portland Fire Department Rules and Regulations; NFPA 72, National Fire Alarm and Signaling Code (2010 edition), as amended by Fire Department Rules and Regulations; and NFPA 70, National Electrical Code (2011 edition) as amended by the State of Maine.
- 12 All smoke alarms shall be photoelectric.
- 13 A separate Fire Alarm Permit is required for new systems; or for work effecting more than 5 fire alarm devices; or replacement of a fire alarm panel with a different model. This review does not include approval of fire alarm system design or installation.
- 14 All means of egress to remain accessible at all times.