

354 965

Portland, Maine



Yes. Life's good here.

September 14, 2015

DOYLE LINFORD F &

50 FAIRLAWN AVE

SOUTH PORTLAND, ME 04106

CBL: 048 A006001

Located at 130 PARK AVE

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

A handwritten signature in cursive script that reads "A/C Keith Santore".

Portland Fire Department

Fire Prevention Bureau

**CITY OF PORTLAND
PORTLAND FIRE DEPARTMENT**

380 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager DOYLE LINFORD F &		Inspector Michael Nixon	Inspection Date 9/13/2015
Location 130 PARK AVE	CBL 048 A006001	Status Unable to Gain Entry	Inspection Type Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 1.115 Exterior

Violation: 1-14.9.1 MINIMUM OF TWO MEANS OF EGRESS; THE NUMBER OF MEANS OF EGRESS FROM ANY BALCONY, MEZZANINE, STORY, OR PORTION THERE OF SHALL BE NOT LESS THAN TWO, EXCEPT UNDER ONE OF THE FOLLOWING CONDITIONS (1) A SINGLE MEANS OF EGRESS SHALL BE PERMITTED WHERE PERMITTED IN CHAPTERS 11 THROUGH 43 OF NPFA 101. (2) A SINGLE MEANS OF EGRESS SHALL BE PERMITTED FOR A MEZZANINE OR BALCONY AND THE COMMON PATH OF TRAVEL LIMITATIONS OF CHAPTERS 11 THROUGH 43 OF NPFA 101 ARE MET.

Notes: FIRE ESCAPE STILL IN DISREPAIR FROM THE 6/11/12 INSPECTION. DROP LADDER BENT AND UNABLE TO USE. CONNECTION TO THE BUILDING IS DOUBTFUL.

Comments: We were unable to gain entry to the rest of the building due to the tenant not letting us in. The violation from 6/11/12 is still open, the Fire Escape is in disrepair

STATE OF MAINE

DISTRICT COURT

Location: Portland

Docket No.

CITY OF PORTLAND and body politic and
Corporate, located in the County of
Cumberland and State of Maine,

Plaintiff,

v.

Linford Doyle & William C Bovill
Defendant

**FIRE PREVENTION AND PROTECTION
CODE VIOLATION**


(M.R. CIV. P. 80H AND 80k)

SUMMONS NUMBER: 354965

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 11/09/2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 11/09/2015.

Dated:

9/17/15



Adam R. Lee, Esq. Bar No. 4143
Associate Corporation Council
City of Portland
389 Congress St
Portland, ME 04101
207-874-8480