

City of Portland, Maine – Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 133 Grant St		Owner: Grant Management LLC	Phone:	Permit No: 980172
Owner Address:	Lessee/Buyer's Name:	Phone:	BusinessName:	<div style="border: 2px solid black; padding: 5px; text-align: center;"> PERMIT ISSUED Permit Issued: MAR - 4 1998 CITY OF PORTLAND </div>
Contractor Name: Sentry	Address: 336 Riverside St Pold, ME 04103	Phone: 797-7799		
Past Use: Multi Fam	Proposed Use: Same	COST OF WORK: \$ 5,035.00	PERMIT FEE: \$ 45.00	Zone: CBL: 048-A-016 Zoning Approval: Special Zone or Reviews: <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan maj <input type="checkbox"/> minor <input type="checkbox"/> mm <input type="checkbox"/>
Proposed Project Description: Install Fire Alarm System		FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied	INSPECTION: Use Group: Type:	
		Signature: <i>[Signature]</i>	Signature:	
Permit Taken By: Mary Gresik		Date Applied For: 23 February 1998		PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.) Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/> Signature: _____ Date: _____

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

23 February 1998

SIGNATURE OF APPLICANT Bill Lanson	ADDRESS:	DATE:	PHONE:
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE			PHONE:

White-Permit Desk Green-Assessor's Canary-D.P.W. Pink-Public File Ivory Card-Inspector

PERMIT ISSUED WITH REQUIREMENTS

CEO DISTRICT 5

PORTLAND FIRE DEPARTMENT

Review Date: 3/2/98 Contractor: Scoutry

Address: 133 Grant St CBL: _____

Please note marked Conditions of Approval

- * The boiler or furnace shall be protected by enclosing with one hour fire rated construction including fire doors and ceiling or by providing automatic extinguishment and smoke protected enclosure. Sprinkler piping serving not more than six sprinklers may be connected to a domestic water supply system having a capacity sufficient to provide a 0.15 gpm per sq ft of floor throughout the entire area. An indicating shut-off valve shall be installed in an accessible location between the sprinkler and the connection to the domestic water supply. Minimum pipe size shall be 3/4" copper or 1" steel. Maximum coverage area of a residential sprinkler in 144 sq ft per sprinkler.
- (*) All required fire alarm systems shall have the capacity of zone disconnect via switches or key pad program provided the method is approved by the Fire Prevention Bureau.
- * All remote annunciators shall have a visible trouble indicator along with the fire alarm zone indicators.
- * Any master box connected to the _____ system shall have a supervised municipal disconnect switch.
- * All master box locations shall be _____ communications.
- * A master box shall be located _____ finished floor
- * All master box locations are r _____
- (*) A fire alarm acceptance rep _____ rtment.
- * All underground tank removal _____ ordinance with the
- Department of Environmer _____
- * No cutting of tanks on site _____ disposal site.
- * The fire dispatcher must _____ l or transportation of
- tanks.
- * All above ground L/P t _____ 58 standards.
- * Any tank located near _____ d.
- * All piping shall be protected from _____ andalism.
- * A 4" storz fire department connection is req _____
- * Any renovation of sprinkler system over 20 heads must _____ Fire Marshall approval.
- * A sprinkler performance test shall be submitted to the P.F.D. after completion of work.
- * State Fire Marshall approval is required for this project.

Mac
Will you
check & let me
know status
of work
room

ok Mac

A Gaylen Mc
Lt. Gaylen Mc Dbugall
Portland Fire Prevention Bureau