



PO Box 2551
2257 West Broadway
South Portland, ME 04106

1.800.370.3473
fax 207.879.0540

www.norrisinc.com

2/17/14

Scope of Work: 129 Grant St.

Norris Inc. will be installing a new addressable fire alarm system for the apartment building located at 129 Grant St. in Portland. The building has a basement, and 3 floors with a total of 19 units. The building is not sprinkled and therefore system connected heat detectors will be installed within the units in all rooms larger than 55 square feet.

The fire alarm panel will have a built in digital communicator which will be monitored via a 24 hour central station of the owner's choice. The panel will be located in the basement and there will be a remote annunciator located at the main entrance on the first floor. A Knox box will be located outside the main entrance door.

The fire alarm panel will be monitored via a remote central station of the owner's choice. The final decision has not yet been made as to who will be doing the monitoring, but that information will be determined prior to final testing.

Norris Inc. will provide and install the fire alarm equipment, provide the required documentation for permits, final connections and testing according to City of Portland requirements.