
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager DENG DENG A		Inspector Jon Rioux	Inspection Date 6/6/2007
Location 105 GRANT ST	CBL 048 A025001	Status Re-Inspect 10 Days	Inspection Type Complaint-Social Services/Gener

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-116.5	Interior	2		Stairways	
Violation:	Fire Protection				
Notes:	Have a Master Electrician re-place the hardwire smoke detector on the 2nd floor rear hallway near apt. three (3). & properly mount/ attach all smoke detectors within the apartment.				
2) 6-116.3	Interior	2			
Violation:	Egress Obstructions				
Notes:	Remove the trash and other debris from the rear entryway near apt. two (2).				

Comments: