
97 Grant Completed Fire prevention work

Dan Blake <Blake@bellportmgt.com>

Tue, Feb 21, 2017 at 4:26 PM

To: "fireprevention@portlandmaine.gov" <fireprevention@portlandmaine.gov>

Cc: "petruccellid@portlandmaine.gov" <petruccellid@portlandmaine.gov>, "Katharine Cahoon (kcahoon@portlandmaine.gov)" <kcahoon@portlandmaine.gov>

Hi Guys,

Are you both on the fire prevention email?

Here are the pics of the work we completed at 97 Grant. All remaining violations are fixed. Don't judge me on the drywall with the fire caulk, lol. I already talked to the guys about it.

1. Installed missing cover on junction box above washer and dryer.
2. Terminated live wires inside a new junction box.
3. Removed rubber wire molding and replaced with new molding.
4. Replaced attic access with 5/8 drywall and fire caulk (not fire foam)
5. Capped wires and installed a blank plate over open box at top of rear stairs. The guys forgot to get a pic of this one but they did do it.

Please let me know if you need anything else and if I can tell the owner this one is closed out.

We've completed everything at 252 woodford too except for the sprinkler head. Doing that tomorrow. I will send you another email with pics for that once the sprinkler head is done.

Thanks,

Dan Blake

Daniel Blake

Vice President



Portland, ME 04103

Office: [207-774-1400](tel:207-774-1400)

Direct: [207-215-1107](tel:207-215-1107)

Fax: [207-358-7226](tel:207-358-7226)

www.bellportmgt.com

5 attachments



IMG_20170216_153820247.jpg
1317K



IMG_20170216_153828558.jpg
1018K



IMG_20170216_161551405.jpg
1432K

IMG_20170216_161604727.jpg
1399K



IMG_20170216_161713997.jpg
1131K