DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



This is to certify that

Located at

SCARECROW AND THE FATMAN LLC /Dave Johnson

94 MELLEN ST

Building Remodeling, Inc. **PERMIT ID:** 2013-02454

ISSUE DATE: 01/07/2014

CBL: 048 A028001

has permission to Remove 2nd & 3rd floor porches & replace porch doors with windows.

Replace/repair 1st floor covered porch

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

/s/ Craig Messinger

/s/ Jeanie Bourke

Fire Official

Building Official

THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY THERE IS A PENALTY FOR REMOVING THIS CARD

Approved Property Use - Zoning

Building Inspections

Fire Department

Three family

Use Group: R-2

Type: 5B

Residential Apartment House (3 Units)

ENTIRE

MUBEC/IBC 2009

PERMIT ID: 2013-02454 **Located at:** 94 MELLEN ST **CBL:** 048 A028001

BUILDING PERMIT INSPECTION PROCEDURES Please call 874-8703 (ONLY)

or email: buildinginspections@portlandmaine.gov

Check the Status or Schedule an Inspection On-Line at http://www.portlandmaine.gov/planning/permitstatus.asp

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.
- Permits expire in 6 months. If the project is not started or ceases for 6 months.
- If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.
- Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.

REQUIRED INSPECTIONS:

Framing Only
Final - Commercial

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

PERMIT ID: 2013-02454 **Located at:** 94 MELLEN ST **CBL:** 048 A028001

City of Portland, Maine - Building or Use Permit 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874- Proposed Use: 3 Family			Permit No:	Date Applied For:	CBL:
			2013-02454	11/01/2013	048 A028001
			Proposed Project Description: Remove 2nd & 3rd floor porches & replace porch doors with windows. Replace/repair 1st floor covered porch		
		Reviewer:	Ann Machado	Approval D	
	ote:				Ok to Issue:
	onditions: This permit is being issued with the condition that all the work is	e taking nl	ace within the evis	eting footprint	
2)	This property shall remain a three family dwelling. Any change approval. This permit is being approved on the basis of plans submitted.	of use shal	l require a separat	e permit application	
	work.	111) 00 110		a separate approvar	serore starting that
	ept: Building Status: Approved w/Conditions Rote:	Reviewer:	Jeanie Bourke	Approval D	ate: 01/07/2014 Ok to Issue: ✓
C	onditions:				
1)	Separate permits are required for any electrical, plumbing, sprint pellet/wood stoves, commercial hood exhaust systems and fuel to part of this process.				
2)	Connections and Fasteners to be installed per 2009 IBC Sec. 230	04.9 and/o	IRC Table R602.	3(1)	
3)	This permit is approved under IBC Sec. 3403.4, Existing Structures, which allows the alteration or replacement of existing stairs to not meet new construction dimensions when the space is restricted. Guardrails and handrails, stair rise/run profile and continuity shall comply with new codes to the fullest extent possible.				
4)	Where supported by attachment to an exterior wall, decks shall be positively anchored to the primary structure and designed for both vertical and lateral loads as applicable. Such attachment shall not be accomplished by the use of toenails or nails subject to withdrawal. See IRC 2009 Sec. 502.2.2 and IBC Sec. 1604.8.3 for details.				
	Deck lateral load connection shall be allowed with hold-down tension devices installed in not less than two locations per deck, with each device having an allowable stress design capacity of not less than 1500 pounds.				
	Where positive connection to the primary building structure cannot be verified during inspection, decks shall be self- supporting.				
5)	. This permit is approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
	ept: Fire Status: Approved Rote:	Reviewer:	Craig Messinger	Approval D	ate: 11/20/2013 Ok to Issue:

PERMIT ID: 2013-02454 **Located at:** 94 MELLEN ST **CBL:** 048 A028001

Conditions: