



1 THIRD FLOOR ELECTRICAL PLAN BUILDING B
1/4" = 1'-0"

- NOTES:**
1. INSTALL (4) TYPE "OC" FIXTURES IN ATTIC. INSTALL SWITCH W/ PILOT LIGHT AT ACCESS POINT.
 2. INSTALL (4) 200 DEG. FIXED TEMP. HEAT DETECTORS IN ATTIC.
 3. OUTLETS IN DEMISING WALLS OF UNITS SHALL BE FIRE STOPPED TO MEET RATING OF WALL.
 4. INSTALL (2) GROUND FAULT/WEATHERPROOF RECEPTACLES ON ROOFTOP. PROVIDE 1P, 20A BREAKER IN PANEL HP, CIRCUIT #21.

