



Planning & Urban Development Department

Director of Planning and Urban Development
Jeff LevineInspection Services, Director
Tammy M. Munson

August 4, 2015

ADVANCED ENERGY GROUP LTD
PO BOX 2048
FORT LEE, NJ 07024**CBL: 048 B016001**
Located at: 65 GRANT ST**Certified Mail 7010 1870 0002 8136 8879**

To whom it may concern:

An evaluation of the above-referenced property on **08/04/2015** shows that the structure fails to comply with Chapter 6.Article V. of the Code of Ordinances of the City of Portland, The Housing Code. Attached is a list of the violations.

This is a notice of violation pursuant to Section 6-118 of the Code. All referenced violations should have a plan of action within **30** days of the date of this notice. A re-inspection of the premises will occur on **09/07/2015** at which time compliance will be required. Failure to comply will result in this office referring the matter to the City of Portland Corporation Counsel for legal action and possible civil penalties, as provided for in Section 1-15 of the Code.

This constitutes an appealable decision pursuant to Section 6-127 of the Code.

Please feel free to contact me if you wish to discuss the matter or have any questions.

Please be advised that the Portland City Council has amended the Building regulations to include a \$150.00 re-inspection fee. This violation will automatically cause a re-inspection at no charge. If there are any subsequent inspections, however, the \$150.00 fee will be assessed for each inspection.

Sincerely,

A handwritten signature in black ink, appearing to read "Chuck Fagone".

Chuck Fagone
Code Enforcement Officer
(207) 874-8789

CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager ADVANCED ENERGY GROUP LTD		Inspector Chuck Fagone	Inspection Date 8/4/2015
Location 65 GRANT ST	CBL 048 B016001	Status Failed	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108. (d)	Exterior			Dining Room	
Violation:	STAIRWAYS, STAIRWELLS, STAIRS AND PORCHES				
	Every inside and outside stairway, stairwell, stairwell, stairs, and porch and any appurtenances thereto shall be structurally sound, in good repair, and safe to use.				
Notes:	<i>The fire escape is not structurally sound and appears to be at the end of its life span. A plan of action should be submitted to this office no later than 9/7/2015 to correct the situation.</i>				


Portland, Maine



Yes. Life's good here.

Planning & Urban Development
Inspection Division
389 Congress Street, Room 315
Portland, Maine 04101-3509

PRESORTED
FIRST CLASS



UNITED STATES POSTAGE




02 1M
0004288097

\$ 00.39¹
AUG 05 2015

MAILED FROM ZIP CODE 04105

X 015 NFE 130061410008/05/15
FORWARD TIME EXP RTN TO SEND
: ADVANCED ENERGY GROUP LTD
48 BI STATE PLZ # 363
OLD TAPPAN NJ 07675-7003

RETURN TO SENDER



0410103597
FRN558 07