



Laurie Leader &lt;lr@portlandmaine.gov&gt;

---

**RE: BP#2017-00268 105 Sherman Street - Plan review**

1 message

---

**Shereen AL Dhamen** <shereen@aquariuspm.com>

Mon, Mar 20, 2017 at 3:24 PM

To: Laurie Leader &lt;lr@portlandmaine.gov&gt;, iant.propainting@gmail.com

Cc: Jason Grant &lt;jgrant@portlandmaine.gov&gt;, Douglas Morin &lt;drm@portlandmaine.gov&gt;

Hi Laurie,

Attached are the revisions you discussed with Ian regarding the stairs at 105 Sherman St.

Please let me know if anything further is required!

Thank you for your help with this,

Shereen AL Dhamen  
Aquarius Residential Leasing  
780 Broadway  
South Portland, Maine  
04106  
[207-899-3845](tel:207-899-3845)

"Notice of Confidentiality" The information contained in this e-mail message and its attachments is intended for the use of the individual or entity named above. If the reader of this message is not the intended recipient, you are hereby notified that any dissemination, distribution, or copy of the communication is strictly prohibited."

---

----- Original Message -----

Subject: BP#2017-00268 105 Sherman Street - Plan review

From: Laurie Leader &lt;lr@portlandmaine.gov&gt;

Date: Thu, March 16, 2017 11:08 am

To: [iant.propainting@gmail.com](mailto:iant.propainting@gmail.com), [shereen@aquariuspm.com](mailto:shereen@aquariuspm.com)Cc: Jason Grant <[jgrant@portlandmaine.gov](mailto:jgrant@portlandmaine.gov)>, Douglas Morin <[drm@portlandmaine.gov](mailto:drm@portlandmaine.gov)>

Ian,

Per our conversation this morning, please provide the following information:

1. Provide layout of existing stairs and landing with dimensions. ( I understand that these have been removed but I will need approximate dimensions).
2. Provide layout of proposed stairs (on separate plans) with complete dimensions of both landings, width of stair, exact location and dimensions of bay window, and clarify the width of the stairs where the stairs meet the bay window.
3. Provide frost protection as required. The existing footprint is smaller than the proposed footprint. Clearly show frost protection as required.
4. Provide opening limitations of the guardrail.

5. Provide attachment detail of the proposed stairs and landings to the existing structure.

Thanks,

Laurie

--

Laurie Leader  
Plan Review/Code Enforcement  
City of Portland, Maine  
Inspections Division  
389 Congress Street  
Portland, ME 04101

P: [207-874-8714](tel:207-874-8714)

F: [207-874-8716](tel:207-874-8716)

E: [lrl@portlandmaine.gov](mailto:lrl@portlandmaine.gov)

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.



**105 Sherman St Exterior Stairs.pdf**

608K