HANDRAIL AND LEDGER BOARD DETAILS

CITY OF PORTLAND, MAINE
RESURGAM
Reviewed for Code Compliance
Inspections Division
Approved with Conditions
Date: 03/21/17

NOTE: THE LEDGER BOARDS USED ON THE TOP AND BOTTOM LANDING, HAVE THE SAME SYSTEM/ FASTENERS FOR SECURING THE NEW STAIRS TO THE EXISTING STRUCTURE

ALL MASONRY ANCHORS ARE TO BE ½" GALVANIZED WEDGE ANCHOR ATLEAST 6" LONG

Reference Figure 19: Ledger Board Fastener Spacing and Clearances