



Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 06/24/16

Fire Department Requirements

Scott and Perryn Ferris
101 Sherman Street
Portland, ME 04101
207-939-9366

Smoke detectors in bedrooms, smoke and gas detectors in living rooms and basement.