



# FLOOR PLANS

Location of proposed 2x4 wall 16" oc with 5/8 drywall on both sides and a 90 min fire rated door centered in new wall.



Portland, Maine  
Apt 13

80 Grant Street Portland, Maine

First Floor Plans



# Certificate of Occupancy

LOCATION 80 GRANT ST

CBL 048 D003001

Issued to BAYVIEW PROPERTIES LLC

Date of Issue 09/08/2005

**This is to certify** that the building, premises, or part thereof, at the above location, built — altered — changed as to use under Building Permit No. 05-0742, has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

Entire Structure

APPROVED OCCUPANCY

R-2 Use Group Type 5B  
13 unit multi family dwelling .

**Limiting Conditions:**

This permit does not certify building code compliance, it is a use permit authorizing a pre-existing condition. A complete Fire Supression system must be installed and functioning by 12/31/05.

This certificate supersedes certificate issued

Approved:

9/8/05 *[Signature]*  
Inspector

*[Signature]*  
Inspector of Buildings

9-9-05

Notice: This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

*Amend 050742 to include Fire Life Safety Plan*

# Port Property

M A N A G E M E N T

Fr: 80 Grant Street, LLC: Tom Watson, Its Manager  
To: Inspectional Services  
Re: Ammendment to Application #050742  
Da: December 10, 2009

## TABLE OF CONTENTS

1. Copy of Fire Alarm Permit
2. Copy of Electrical Permit (inc. Life Safety System Installation)
3. Copy of Building Permit for Hall Partitioning Fire Door System

Tom Watson  
252-0358

**RECEIVED**

DEC 10 2009

**Dept. of Building Inspections  
City of Portland Maine**