
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager RICE GEOFFREY I		Inspector Tom Markley	Inspection Date 9/11/2006
Locatation 60 GRANT ST	CBL 048 D009001	Status Re-Inspect 10 Days	Inspection Type Complaint-Inspection

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-113.1	Interior	1	1	Various locations	
Violation: Lighting standards/Habitable rooms					
Notes: No Electricity in unit or separate bathroom- no access to electric box in basement					
2) 6-108.2	Interior	1		Hallway	
Violation: Interior floors, walls, ceilings and doors					
Notes: Evidence of water damage on ceiling- plaster cracked/ chipped					
3) 6-108.2	Interior	4	2	Hallway	
Violation: Interior floors, walls, ceilings and doors					
Notes: Evidence of water damage on ceiling - plaster cracked / chipped					

Comments: