

353 816

Portland, Maine



Yes. Life's good here.

Jerome F. LaMoria
Fire Chief, Fire Department

Portland Fire Department
Fire Prevention Bureau
380 Congress St
Portland, ME 04101

July 7, 2015

S S & M LLC
PO Box 9715-747
Portland, ME 04104

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at 264 State St on 07/07/2015 revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department
Fire Prevention Bureau

**CITY OF PORTLAND
PORTLAND FIRE DEPARTMENT**

380 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager S S & M LLC		Inspector Daniel Dyer	Inspection Date 7/7/2015
Location 264 STATE ST	CBL 048 D023001	Status Failed	Inspection Type Fire Company-FP Routine Inspec

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
------	---------	-------	----------	------	-----------------

1) 80.16

Violation: NFPA 101-7.9.2.1 E-LIGHTS REQUIRE MAINTENANCE; Emergency illumination shall be provided for a minimum of 1.5 hours in the event of failure of normal lighting. Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 ft-candle and, at any point, not less than 0.1ft-candle, measured along the path of egress at floor level. Illumination levels shall be permitted to decline to not less than 0.006 ft-candle at the end of 1.5 hours. A maximum-to-minimum illumination uniformity ratio of 40 to 1 shall not be exceeded.

Notes: 3RD FLOOR HALLWAY

2) 81.10

Violation: PORTLAND FIRE DEPARTMENT CHAPTER 10 FIRE ALARM INSPECTION STICKER REQUIRED; Provide annual fire alarm inspection sticker at the annunciator. This sticker must be provided by a licensed master fire alarm company. A list of licensed master fire alarm companies can be found at: www.portlandmaine.gov/fireprevention.

Notes: STICKER EXPIRED FEB. 2013

3) 80.16

Violation: NFPA 101-7.9.2.1 E-LIGHTS REQUIRE MAINTENANCE; Emergency illumination shall be provided for a minimum of 1.5 hours in the event of failure of normal lighting. Emergency lighting facilities shall be arranged to provide initial illumination that is not less than an average of 1 ft-candle and, at any point, not less than 0.1ft-candle, measured along the path of egress at floor level. Illumination levels shall be permitted to decline to not less than 0.006 ft-candle at the end of 1.5 hours. A maximum-to-minimum illumination uniformity ratio of 40 to 1 shall not be exceeded.

Notes: 3RD FLOOR HALLWAY

4) 81.10

Violation: PORTLAND FIRE DEPARTMENT CHAPTER 10 FIRE ALARM INSPECTION STICKER REQUIRED; Provide annual fire alarm inspection sticker at the annunciator. This sticker must be provided by a licensed master fire alarm company. A list of licensed master fire alarm companies can be found at: www.portlandmaine.gov/fireprevention.

Notes: STICKER EXPIRED FEB. 2013

Comments:

STATE OF MAINE

DISTRICT COURT
Location: Portland
Docket No.

CITY OF PORTLAND and body politic and
Corporate, located in the County of
Cumberland and State of Maine,

Plaintiff,

v.

S S & M, LLC.
Defendant

**FIRE PREVENTION AND PROTECTION
CODE VIOLATION**

(M.R. CIV. P. 80H AND 80k)

SUMMONS NUMBER: 353816

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on August 10, 2015. I strongly urge you to contact Victoria Meserve at Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on August 10, 2015.

Dated: 7/9/15

Adam R. Lee, Esq. Bar No. 4143
Associate Corporation Council
City of Portland
389 Congress St
Portland, ME 04101
207-874-8480