ONLINE CERTIFICATIONS DIRECTORY

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/28/13

UOXX.S789
Control Unit Accessories, System

Page Bottom

Control Unit Accessories, System

See General Information for Control Unit Accessories, System

HONEYWELL SECURITY S789
SUITE 100
2 CORPORATE CENTER DR
PO BOX 9040
MELVILLE, NY 11747 USA

Backup dialer modules, Model(s) 5140DLM

Eight-zone remote point Class A interface modules, Model(s) 4208SNF

Eight-zone remote point modules, Model(s) 4208SN, 4208U

Enclosures, Model(s) 5800BOX

End-of-line resistors, Model(s) 4100EOLR, EOL100, EOL20, EOL22, EOL82, EOLR470K

Fire system annunciator keyswitch modules, Model(s) FSAKSM (d)

Fire system annunciator modules, Model(s) FSA-24F, FSA-8F

Internet and Digital Cellular Fire Communicator, Model(s) iPGSM-COM, IPGSM-DP

Internet communicators, Model(s) 7845i-ent, 7845i-entF (c)

Isolation modules, Model(s) ECP-Isolator, VPLEX-VSI

Keyswitches, Model(s) 4146 (a)

LCD keypads, Model(s) 6160CR-2, FA570CR

Polling loop extender modules, Model(s) 4297

RF receivers, Model(s) 5881ENHC

RF transceiver subassemblies, Model(s) 5883H

Sensor Interface Module Gateway, Model(s) 472368

Supervised notification appliance modules, Model(s) 4204CF

Transformers, Model(s) 1451

Universal group zoning multiplex modules, Model(s) 4209U

Wireless transmitters, Model(s) 5817CB

Zone expander modules, Model(s) 4190SN, 4193SN (b), 4193SNP (b)

(a) - Must be installed adjacent to an alphanumeric (English language) keypad, Model 6160CR-2 when used as a fire alarm silencing switch.

(b) - Must be mounted inside control panel cabinet or within a Listed junction box. Supervised Zone is required for Fire. Unsupervised Zone may be

used for Burglary.

(c) - For use with Model FOCUS 200 PLUS control unit.

(d) - Keyswitch module must be installed adjacent to FSA unit if remote silence/reset desired.

NOTE - Model numbers may include a prefix or suffix consisting of numbers and/or letters. For use with compatible Liste
indicated in the installation instructions.

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 10/28/13

Last Updated on 2011-07-18

Copyright © 2011 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2011 Underwriters Laboratories Inc.®"

An independent organization working for a safer world with integrity, precision and knowledge.