



- GENERAL NOTES**
- A.) FIRE ALARM SYSTEM WIRING SHALL COMPLY WITH THE NATIONAL ELECTRIC CODE, APPLICABLE STATE AND LOCAL CODES AND SHAL BE COORDINATED WITH THE LOCAL AUTHORITY HAVING JURISDICTION.
 - B.) CAUTION; DO NOT CONNECT ANY POWER TO THE CONTROL PANEL (BATTERIES OR 120VAC) UNTIL ALL FIELD WIRING HAS BEEN TESTED.
 - C.) DO NOT INSTALL FIRE ALARM CONTROL PANEL OR ANY ADDRESSABLE DEVICES IN UNHEATED SPACE.
 - D.) DO NOT INSTALL ANY AC CURRENT CARRYING CONDUCTORS CLOSE TO OR IN THE SAME RACEWAY WITH FIRE ALARM SYSTEM CONDUCTORS.
 - E.) SOLID LINES REPRESENT CONNECTIONS MADE BY THE SYSTEM INSTALLER.
 - F.) ALL RELAYS ARE SHOWN IN NORMAL SUPERVISORY CONDITION. ALL RELAYS ARE FORM "C" TYPE.

- INSTALLATION NOTES**
- A.) SMOKE DETECTORS SHALL NOT BE MOUNTED ANY CLOSER THAN 3' FROM ANY AIR DUCT OPENINGS.
 - B.) ELEVATOR LOBBY SMOKE SHALL BE MOUNTED WITHIN 10' OF THE ELEVATOR DOOR.
 - C.) MANUAL PULL STATIONS SHALL BE MOUNTED PE ADA REQUIREMENTS: 48" AFF OR 42" AFF TO COMPLY WITH SIDE/FRONT REACH REQUIREMENTS.
 - D.) WALL MOUNTED HORN STROBES AND STROBES SHALL BE MOUNTED 6" FROM CEILING, OR 96" TO 80" AFF TO THE CENTER OF THE STROBE.
 - E.) HORN STROBES AND STROBES SHALL BE MOUNTED 15" FROM THE CORNER OF THE WALL. IF THIS IS NOT POSSIBLE, DEVICE SHALL BE CENTERED ON THAT WALL.
 - F.) CEILING MOUNTED HALLWAY DEVICES SHALL BE LOCATED IN A SYMMETRICAL MANNER DOWN THE CENTER OF THE HALLWAY WHEN POSSIBLE.

CO RF WIRELESS	HEAT RF WIRELESS
SMOKE RF WIRELESS	STROBE
SINGLE INPUT MODULE	15cd
SOUNDER BASE	HORN STROBE
HEAT DETECTOR	15cd
DUAL MODULE	WEATHER PROOF HORN STROBE
MANUAL PULL STATION	WP 75cd
CO DETECTOR	MINI HORN
MICRO MODULE	CEILING MOUNT HORN STROBE
SMOKE DETECTOR	CL 15cd
RELAY MODULE	SPEAKER STROBE
ISOLATOR MODULE	SPRINKLER TAMPER SWITCH
	SPRINKLER WATERFLOW SWITCH

PROTECTION PROFESSIONALS

DATE 11/30/17

REVISION: 1.0

62 MELLEEN STREET

SCALE: NS

1ST FLOOR

SHEET: 2 OF 5

DESIGNER: JEREMY LAMBERT