

Ann Machado - Re: Permit #2014-00180 - solar electric panels for King Middle School

From: Christine Puopolo <christine@revisionenergy.com>
To: Ann Machado <AMACHADO@portlandmaine.gov>
Date: 2/3/2014 4:25 PM
Subject: Re: Permit #2014-00180 - solar electric panels for King Middle School
CC: Jen Hatch <jen@revisionenergy.com>
Attachments: King Middle School Plot Plan.JPG

Hi Ann,

I have attached a plan showing where the panels will be from an aerial view. Let me know if this works for you.

Also, the panels will be mounted on the side of the building with custom brackets. Sorry for any confusion in the wording and documents!

Thanks,

On Mon, Feb 3, 2014 at 3:01 PM, Ann Machado <AMACHADO@portlandmaine.gov> wrote:

Christine -

I have finished my zoning review. I need some more information before I can sign off.

First, you give a rendition of the panels on the wall but we need a key plan of the whole building indicating the location of the wall where the panels are going.

Second, I'm a little confused. The application talks about installing the panels on the side of the building and that is what the picture shows but the permit letter states that the roof structure can handle the weight of the panel load. Also the mounting specs sheet shows a roof mount Platform. Are the panels on the side or the roof?

Thanks.

Ann

Ann Machado

Zoning Specialist

Planning & Urban Development

Portland City Hall

[\(207\) 874-8709](tel:2078748709)

Notice: Under Maine law, documents - including e-mails - in the possession of public officials or city employees about government business may be classified as public records. There are very few exceptions. As a result, please be advised that what is written in an e-mail could be released to the public and/or the media if requested.

--

Christine Puopolo,
Office and Digital Marketing Assistant
ReVision Energy
207.221.6342