

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



This is to certify that  
CITY OF PORTLAND

Located at  
165 PARK AVE

PERMIT ID: 2014-00959      ISSUE DATE: 05/14/2014      CBL: 049 A001001

has permission to **Mother's Day Tent event at Hadlock Field**  
**Set up: 5/9/14; break down: 5/19/14 - 40'x60' tent in lower parking lot**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise cloed-in. 48 HOUR NOTICE IS REQUIRED.

A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.

*/s/ Chris Pirone*

*/s/ Tammy Munson*

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

*Approved Property Use - Zoning*

*Building Inspections*

*Fire Department*

Foundation next to old horse barn.  
Hadlock Field Ball Park  
Portland Expo Building

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

|  |                                      |   |  |   |
|--|--------------------------------------|---|--|---|
| <b>City of Portland, Maine - Building or Use Permit</b>  |                                      | <b>Permit No:</b><br>2014-00959   | <b>Date Applied For:</b><br>05/07/2014 | <b>CBL:</b><br>049 A001001                              |
| 389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716  |                                      |   |  |   |
| <b>Proposed Use:</b><br>Same: Hadlock Field Baseball Park  |                                      | <b>Proposed Project Description:</b><br>Mother's Day Tent event at Hadlock Field<br>Set up: 5/9/14; break down: 5/19/14 - 40'x60' tent in lower parking lot |  |   |
| <b>Dept:</b> Zoning  | <b>Status:</b> Approved              | <b>Reviewer:</b> Marge Schmuckal  | <b>Approval Date:</b> 05/07/2014       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| <b>Dept:</b> Building  | <b>Status:</b> Approved              | <b>Reviewer:</b> Tammy Munson   | <b>Approval Date:</b> 05/12/2014       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| <b>Dept:</b> Fire  | <b>Status:</b> Approved w/Conditions | <b>Reviewer:</b> Chris Pirone   | <b>Approval Date:</b> 05/08/2014       | <b>Ok to Issue:</b> <input checked="" type="checkbox"/> |
| <b>Note:</b>   |                                      |   |  |   |
| <b>Conditions:</b>   |                                      |   |  |   |
| <ol style="list-style-type: none"> <li>1) A main corridor for the main tent shall be maintained a minimum of 36 inches. Where a chair is placed between a table and the corridor the measurement shall be made from the table and add 19 inches for each chair.</li> <li>2) The tent shall have a minimum of 2 exits. Minimum clear width shall be 36".</li> <li>3) Emergency lighting shall be provided if the event takes place after sunset.</li> <li>4) Exits need to be clearly marked with Exit signs.</li> <li>5) No more than 160 occupants are permitted based on the dimensions with tables and chairs.</li> <li>6) All tents shall meet the flame propagation performance criteria contained in NFPA 701. A certificate or other evidence of acceptance by an organization acceptable to the AHJ shall serve as evidence that the tent fabric materials have the required flame propagation performance.</li> <li>7) Cooking within the tents has not been reviewed and approved.</li> <li>8) Fuel-fired heating equipment and propane tanks shall be installed outside of the tents and not within 5 feet of the tents or an exit discharge.</li> <li>9) If the sides of the tents are to be enclosed at least two remotely located and marked exits shall be provided.</li> <li>10) Tents shall have an approved fire resistant rating and maintain 10' between stake lines. No smoking or open flame allowed within 10'. Provide at least one 2A:10 BC fire extinguisher.</li> </ol> |                                      |   |  |   |