

**PERMIT ISSUED**

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0156	Issue Date: MAR 7 2006	CBL: 05	A006001
-----------------------	---------------------------	------------	---------

<b>Location of Construction:</b> 50 EXETER ST	<b>Owner Name:</b> WUESTHOFF RAPHAEL J & BET	<b>Owner Address:</b> 13 MORNING ST	<b>Phone:</b>
<b>Business Name:</b>	<b>Contractor Name:</b> Dead River Company	<b>Contractor Address:</b> CITY OF PORTLAND PO Box 467 Scarborough	<b>Phone:</b> 2078839515
<b>Lessee/Buyer's Name</b>	<b>Phone:</b>	<b>Permit Type:</b> Tanks - Dwellings	<b>Zone:</b> R5

<b>Past Use:</b> Residential 2 unit	<b>Proposed Use:</b> Residential 2 unit place tank 275 gal in basement	<b>Permit Fee:</b> \$30.00	<b>Cost of Work:</b> \$30.00	<b>CEO District:</b> 3
		<b>FIRE DEPT:</b> <input type="checkbox"/> Approved <input type="checkbox"/> Denied	<b>INSPECTION:</b> Use Group R3 Type: TANK	

<b>Proposed Project Description:</b> place tank 275 gal in basement	Signature: <i>AMB 3/1/06</i>
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied	
Signature:	Date:

<b>Permit Taken By:</b> dmartin	<b>Date Applied For:</b> 02/01/2006	<b>Zoning Approval</b>	
------------------------------------	--	------------------------	--

<p>1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.</p> <p>2. Building permits do not include plumbing, septic or electrical work.</p> <p>3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..</p>	<p><b>Special Zone or Reviews</b></p> <input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <i>ok</i> <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: <i>AMB 3/1/06</i>	<p><b>Zoning Appeal</b></p> <input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<p><b>Historic Preservation</b></p> <input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: <i>JMB</i>
---	---	---	---

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit.

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK. TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

# APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

51 A 006

To the INSPECTOR OF BUILDINGS, PORTLAND, ME.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 50 Exeter St. Use of Building residential Date 1-31-06

Name and address of owner of appliance John Wuesthoff

Installer's name and address Dead River Co. 73 Pleasant Hill Rd Scarborough ME 04074

Telephone 207-883-9515

### Location of appliance:

- Basement
- Floor
- Attic
- Roof

### Type of Fuel:


- Gas
- Oil
- Solid

Appliance Name: N/A

U.L. Approved  Yes  No


Will appliance be installed in accordance with the manufacturer's installation instructions?  Yes  No

IF NO Explain: \_\_\_\_\_



### Type of Chimney:

- Masonry Lined  
Factory built \_\_\_\_\_
- Metal  
Factory Built U.L. Listing # \_\_\_\_\_
- Direct Vent  
Type \_\_\_\_\_ uL# \_\_\_\_\_



Number of Tanks 1

Distance from Tank to Center of Flame 5' min feet.

Cost of Work: \$ 1650.00

Permit Fee: \$ 39.00

### The Type of License of Installer:

- Master Plumber # \_\_\_\_\_
- Solid Fuel # \_\_\_\_\_
- Oil # MS30008108
- Gas # \_\_\_\_\_
- Other \_\_\_\_\_

### Approved

Fire: \_\_\_\_\_  
Ele.: \_\_\_\_\_  
Bldg.: \_\_\_\_\_

### Approved with Conditions

- See attached letter or requirement

Inspector's Signature \_\_\_\_\_

Date Approved \_\_\_\_\_


Signature of Installer Dead River Company by Jaime Lavigne

White - Inspection    Yellow - File    Pink - Applicant's    Gold - Assessor's Copy

*Cash*



Limited Partnership



*Always  
a Tough To  
Warranty 3*

# UL 80

## Domestic Oil Tanks


#PRODUIT	MODELS	DIMENSIONS			GAUGE	WEIGHT
		H	W	L		
2090	120 us gals vertical	47"	23"	30"	12 ga	165 lb
2095	120 us gals horizontal	23"	47"	30"	12 ga	165 lb
2080	138 us gals vertical	44"	27"	30"	12 ga	175 lb
2085	138 us gals horizontal	27"	44"	30"	12 ga	175 lb
2070	220 us gals vert./stubbies	44"	27"	48"	12 ga	240 lb
2075	220 us gals horizontal	27"	44"	48"	12 ga	240 lb
2020	240 us gals narrow/vert.	47"	23"	60"	12 ga	260 lb
2025	240 us gals narrow/horiz.	23"	47"	60"	12 ga	260 lb
2040	275 us gals vertical	44"	27"	60"	12 ga	280 lb
2045	275 us gals horizontal	27"	44"	60"	12 ga	280 lb
2050	330 us gals vertical	44"	27"	72"	12 ga	320 lb
2055	330 us gals horizontal	27"	44"	72"	12 ga	320 lb

20 20 20 20  
12" 12" 12" 12"



### TECHNICAL SPECIFICATIONS

- Steel ASTM A-569
- Female openings NPT
- Tested at pressure 5 to 7 PSIG
- UI 80 label
- Operation at atmospheric pressure only
- Also available UL 142 labeled on 275 & 330 gals (including a 3" diameter emergency vent opening). Other models on request only.



Installation and maintenance **guidelines** for aboveground domestic fuel *oil* tanks (PDF).

## OUTSIDE FINISH

- Preparation: **Washed** and **phosphated**
- Electrostatic powder paint "black or gray".

## GENERAL CHARACTERISTICS

- Always a tough tank
- Welded lap joint: the strongest one
- Ergonomic handle on each head for easy handling

## NEW PRODUCTS:

- 275 gals. UL 80 labelled **10 gauge shell &**

## IN REFERENCE TO: UL LISTING

UL Listing: Requires outlet opening of 1/2" minir to be located underneath the tank only. Requires openings to be 2" minimum diameter. Tanks **whic** not meet above requirements cannot be UL 80 la

**NOTICE: N.F.P.A. Codes. UL and Granby Steel Tanks require t**  
these tanks be tested at job site before being put in *service*. To te  
tank, apply internal air pressure of not less than 3 PSIG or more t  
PSIG and soap all seams and welded areas. Warning: Over  
pressurization may cause tank *to fail*.

