Form # P 01

ELECTRICAL PERMIT
City of Portland, Me.

To the Chief Electrical Inspector, Portland Maine:
The undersigned hereby applies for a permit to make electrical installations in accordance with the laws of Maine, the City of Portland Electrical Ordinance, National Electrical code and the following specification:

Date 30 April 1996

Permit # 2999

051 - B - 013

LOCATION: 89 Washburn Ave

OWNER Sandis Wright **ADDRESS**

							TOTAL	EACH FEE
OUTLETS								
	Receptacles		Switches		Smoke Detector		.20	
FIXTURES	(number of)							
	incandescent		fluorescent				.20	
	fluorescent strip						.20	
SERVICES								
	Overhead				TTL AMPS TO	800 100	15.00	15.00
	Underground					800	15.00	
TEMPORARY SERV.								
	Overhead				AMPS OVER	800	25.00	
	Underground					800	25.00	
METERS	(number of)					1	1.00	1.00
MOTORS	(number of)						2.00	
RESID/COM	Electric units						1.00	
HEATING	oil/gas units						5.00	
APPLIANCES	Ranges		Cook Tops		Wall Ovens		2.00	
	Water heaters		Fans		Dryers		2.00	
Disposals	Dishwasher		Compactors		Others (denote)		2.00	
MISC. (number of)	Air Cond/win						3.00	
	Air Cond/cent						10.00	
	Signs						5.00	
	Pools						10.00	
	Alarms/res						5.00	
	Alarms/com						15.00	
	Heavy Duty						2.00	
	Outlets							
	Circus/Carnv						25.00	
	Alterations						5.00	
	Fire Repairs						15.00	
	E Lights						1.00	
	E Generators						20.00	
	Panels						4.00	
TRANSFORMER	0-25 Kva						5.00	
	25-200 Kva						8.00	
	Over 200 Kva						10.00	
					TOTAL AMOUNT DUE			
	MINIMUM FEE/COMMERCIAL 35.00				**MINIMUM FEE**	**25.00**		25.00

INSPECTION: Will be ready _____ or will call xxx

CONTRACTORS NAME C.A. DeSimone, Jr.
ADDRESS P.O. Box 14A Cumberland
TELEPHONE 829-3123
MASTER LICENSE No. 2999
LIMITED LICENSE No. _____

SIGNATURE OF CONTRACTOR C.A. DeSimone Jr.

ELECTRICAL INSTALLATIONS—

Permit Number # 2559

Location 89 [illegible] Rd

Owner Sam's [illegible]

Date of Permit 4/30/96

Final Inspection 5/22/96

By Inspector [illegible]

INSPECTION: Service 5/20/96 by [illegible]

Service called in 5/22/96

Closing-in _____ by _____

PROGRESS INSPECTIONS: 5/20/96 (SERVICE)

RE-INSPECT 5/22/96 (SERVICE)

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

_____ / _____ / _____

DATE:	REMARKS:
5/20/96	6 awg red wire not in PVC on building (service did not pass) must be installed in PVC & clipped to building.
5/22/96	All OK (will call Chief)