

STRUCTURAL ANALYSIS REPORT

For

ME 5045 (LTE)
PORTLAND USM
246 Deering Avenue
Portland, ME 03082

**Equipment Curb on the Roof; Antennas Mounted on the Building
Façade**



Prepared for:



at&t


500 Enterprise Drive, Suite 3A
Rock Hill, CT 06067

Dated:

March 8, 2012

Prepared by:

HUDSON DESIGN GROUP, LLC.
1600 Osgood Street Building 20 North, Suite 2-101
North Andover, MA 01845
Phone: (978) 557-5553
www.hudsondesigngroupllc.com





SCOPE OF WORK:

Hudson Design Group LLC (HDG) has been authorized by AT&T to conduct a structural evaluation of the structure supporting the proposed AT&T equipment located in the areas depicted in the latest HDG's construction drawings.

This report represents this office's findings, conclusions and recommendations' pertaining to the support of AT&T's proposed LTE Equipment.

This office conducted an on-site visual survey of the above areas on March 6, 2012. Attendees included Sergio Anastacio (HDG-Assistant Project Manager).

CONCLUSION SUMMARY:

As-built plans prepared by Donald L. Dimick were available for our use. The previous stamped drawings and design calculations prepared by Areal Spectrum, were available for our reference.

A limited visual survey of the structure was completed in or near the areas of the Proposed Work. Based on our evaluation, we have determined that, in general, structural designs to support the proposed AT&T Equipment within or near the Proposed Location can be completed and components installed with **NO STRUCTURAL UPGRADES REQUIRED** to the existing structure.

HDG recommends supporting the new LTE Equipment on a curb platform extension. The new extension is recommended to be installed directly over the building columns to adequately support the new loading. Reference the latest HDG's construction drawings for details.

A summary of the proposed support types and attachment locations are as follows:

(1) LTE Antenna (SBNH-1D6565C) (96.4"x11.9"x7.1" – Wt. 61lbs.) (Alpha Sector)...Mounted on a new steel pipe and mounting brackets, secured by the building facade.

(2) LTE Antennas (KMW AM-X-CD-16-65-00T) (72"x11.8"x5.9" - Wt. 48.5lbs.) (Beta and Gamma Sectors)....Mounted on new steel pipes supported by the existing antenna mounts.

(1) Emerson Outdoor Power Cabinet (Wt.=2150 lbs)...Supported by the new equipment curb extension.

(2) Purcell Cabinets (Wt. = 250 lbs/each).....Supported by the new equipment curb extension.

(3) Surge Arrestor DC2-48-60-0-9E (1 per sector)...Mounted on new unistrut components.

(6) RRH (2 per sector) (Wt. = 50 lbs/each).....Mounted on new unistrut components. Referenced documents are attached.



Referenced documents are attached.

DESIGN CRITERIA:

1. International Building Code 2009, ASCE 7-10 Minimum Design Loads for Buildings and Other Structures.

Wind Analysis:

Reference Wind Speed:	110 MPH	(FIG 26.5-1C; ASCE 7-10)
Category:	C	(26.7.3; ASCE 7 -10)
Gust Effect Factor (G):	0.85	(26.9.1; ASCE 7-10)
Force Coefficient (Cf):	Varies	(FIG 29.5-1 thru 29.5-3; ASCE 7-10)
$F = qz * G * Cf * Af:$		(Equation 29.5-1; ASCE 7-10)

Snow Loading:

Ground Snow Load (Pg):	60 psf	(FIG 7-1; ASCE 7-10)
Flat Roof Snow Load (Pf):	37.8 psf	

$$Pf = 0.7 * Ce * Ct * I * Pg \quad \text{(Equation 7.3-1; ASCE 7-10)}$$

$$Ce=0.9; Ct=1.0; I=1.0$$

2. EIA/TIA -222- G Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

County:	Cumberland
Wind Load:	100 mph

3. Approximate height above grade to antennas:

85'-2" +/- (Beta and Gamma sectors)
88'-8" +/- (Alpha sector)



EXISTING ROOF CONSTRUCTION:

The roof construction appears to consist of an adhered roofing membrane on top of a reinforced concrete slab supported by reinforced concrete columns and bearing walls.

Antenna SUPPORT RECOMMENDATIONS:

- The new LTE Alpha sector antenna is proposed to be supported by a new steel pipe and mounting brackets, secured to the building facade.
- The new LTE Beta and Gamma sector antennas are proposed to be supported by new steel pipes, secured to the existing antenna support angles.

RRH's / Surge Arrestor SUPPORT RECOMMENDATIONS:

- The new Alpha sector Surge Arrestor and RRH's are proposed to be mounted on new unistrut components, secured to the building using epoxy anchors.
- The new Beta and Gamma sector Surge Arrestors and RRH's proposed to be mounted on new unistrut components, secured to the existing antenna support angles.

EQUIPMENT SUPPORT RECOMMENDATIONS:

HDG recommends that the proposed equipment be supported by the new equipment rooftop curb extension as shown in the latest HDG construction drawings.

OTHER RECOMMENDATIONS:

HDG recommends that the new curb extension be installed directly over the building columns to adequately support the new equipment load. (Contractor to verify the column locations).



Notes:

1. Reference the latest HDG construction drawings for all the equipment locations.
2. All detail requirements will be designed and furnished in the construction drawings.
3. Mount all equipment per manufacturer's specifications.
4. HDG is under the assumption that the equipment curb was located over building columns.
5. All structural members and their connections are assumed to be in good condition and are free from defects with no deterioration to its member capacities.

EXISTING ANTENNAS:



Photo 1: Sample photo illustrating the existing Alpha sector antennas.



Photo 2: Sample photo illustrating the existing Beta sector antennas.




Photo 3: Sample photo illustrating the existing Gamma sector antennas.

EXISTING EQUIPMENT:



Photo 4: Sample photo illustrating the existing equipment.



Photo 5: Sample photo illustrating the existing equipment.



Calculations

Date: 03-20-12

Project Name: Portland USM

Project Number: ME5045

Designed By: AA Checked By: MSC



2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

z= 88.67 (ft)

z_g= 900 (ft)

α= 9.5

K_z= 1.234

$$K_{zmin} \leq K_z \leq 2.01$$

Table 2-4

Exposure	Z _g	α	K _{zmin}	K _e
B	1200 ft	7	0.70	0.90
C	900 ft	9.5	0.85	1
D	700 ft	11.5	1.03	1.10

2.6.6.4 Topographic Factor:

Table 2-5

Topo. Category	K _t	f
2	0.43	1.25
3	0.53	2
4	0.72	1.5

$$K_{zt} = [1 + (K_e K_t / K_h)]^2$$

$$K_h = e^{-(z/H)}$$

K_{zt}= #DIV/0!

K_h= #DIV/0!

K_e= 0 (from Table 2-4)

K_t= 0 (from Table 2-5)

f= 0 (from Table 2-5)

z= 88.67

H= 0 (Ht. of the crest above surrounding terrain)

K_{zt}= 1.00

(If Category 1 then K_{zt}=1.0)

Category= 1

Date: 03-20-12
Project Name: Portland USM
Project Number: ME5045
Designed By: AA Checked By: MSC



2.6.7 Gust Effect Factors

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 88.67

Gh= 0.48867

2.6.7.2 Guyed Masts

Gh= 0.85

2.6.7.3 Pole Structures

Gh= 1.1

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35

Gh= 1.35

Date: 03-20-12
 Project Name: Portland USM
 Project Number: ME5045
 Designed By: AA Checked By: MSC



2.6.8 Design Ice Thickness:

$$t_{iz} = 2.0 * t_i * I * K_{iz} * (K_{zt})^{0.35}$$

$t_{iz} = 2.21$

$t_i = 1$
 $I = 1$
 $K_{iz} = 1.10$
 $K_{zt} = 1$

$$K_{iz} = [z/33]^{0.10} \leq 1.4$$

$K_{iz} = 1.10$

Calculating the weight of ice, the cross-sectional area of ice shall be determined by:

$$A_{iz} = \pi * t_{iz} * (D_c + t_{iz})$$

$D_c = 96.4$ (in) Largest Dim of Member

$A_{iz} = 683.94$

2.6.9 Design Wind Load:

$$F = q_z * G * h * (EPA's)$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2$$

$q_z = 30.01$

$K_z = 1.234$
 $K_{zt} = 1$
 $K_d = 0.95$
 $V_{max} = 100$

Table 2-2

Structure Type	Wind Direction Probability Factor, Kd
Latticed structures with triangular, square or rectangular cross sections	0.85
Tubular pole structures, latticed structures with other cross sections, appurtenances.	0.95

Date: 03-20-12
Project Name: Portland USM
Project Number: ME5045
Designed By: AA **Checked By:** MSC



Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

C mph.ft	Round	18 Sided	16 Sided	12 Sided	8 Sided
< 32 (Subcritical)	1.2	1.2	1.2	1.2	1.2
32 to 64 (Transitional)	$38.4/C^{1.0}$	$25.8/C^{0.885}$	$12.6/C^{0.678}$	$2.99/C^{0.263}$	1.2
> 64 (Supercritical)	0.6	0.65	0.75	1	1.2

$$C = (I * K_{zt} * K_z)^{0.9} * V * D$$

Dp = Outside Diameter or Out to Out: 0.2 feet

C= 22.22 Cf= 1.2

<u>Appurtenances</u>	<u>Height</u>	<u>Width</u>	<u>Depth</u>	<u>Flat Area</u>	<u>Force Per Appurtenance</u>
Item No.1	96.4	11.9	7.1	7.97	387.30 (lbs)
Item No.2	72	11.8	5.9	5.90	286.84 (lbs)
Item No.3	55	11	5	4.20	204.26 (lbs)
Item No.4	0	0	0	0.00	0.00 (lbs)
Item No.5	0	0	0	0.00	0.00 (lbs)

TOTAL FORCE ($\sum F_A$) =	878.40 (lbs)
--	---------------------

ICE WEIGHT CALCULATIONS

Project: ME5045

Thickness of ice: 0.75

PROPOSED
Antenna

Weight of ice based on total radial SF area:

Depth (in): 7.1

height (in): 96.4

Width (in): 11.8

Total weight of ice on object: 89 pounds ice

Weight of object: 61 pounds

Combined weight of ice and object: 150 pounds

Per foot weight of ice:

Pipe

pipe weight per foot: 3.65

pipe length (ft): 8.5

diameter (in): 2.375

Per foot weight of ice on object: 2 pounds ice /ft

Total weight of ice on object: 19 pounds

Total weight of pipe: 31.025 pounds

Combined weight of pipe and ice: 50 pounds

* Density of ice used = 56 PCF

Total Weight: 199 pounds

ICE WEIGHT CALCULATIONS

Project: ME5045

Thickness of ice: 0.75

Weight of ice based on total radial SF area:

EXISTING
Antenna

Depth (in): 5

height (in): 55

Width (in): 11

Total weight of ice on object: 43 pounds ice

Weight of object: 30 pounds

Combined weight of ice and object: 73 pounds

Per foot weight of ice:

Pipe

pipe weight per foot: 3.65

pipe length (ft): 6

diameter (in): 2.375

Per foot weight of ice on object: 2 pounds ice /ft

Total weight of ice on object: 13 pounds

Total weight of pipe: 21.9 pounds

Combined weight of pipe and ice: 35 pounds

* Density of ice used = 56 PCF

Total Weight: 108 pounds

Project: ME5045 (LTE)

Location: ANTENNA SUPPORT ANGLE (WORSE CASE)

Multi-Loaded Multi-Span Beam

[2009 International Building Code(AISC 13th Ed ASD)]

A36 L4x4x1/4 x 5.0 FT Leg Up

Section Adequate By: 410.4%

Controlling Factor: Shear

Andres Agudelo

Hudson Design Group LLC

1600 Osgood Steet, Suite 2-101, Bldg. 20N

North Andover, MA 01845


page

of

StruCalc Version 8.0.111.0

3/20/2012 2:23:54 PM

LOADING DIAGRAM



DEFLECTIONS

Center

Live Load	0.02	IN L/3163
Horizontal Component	0.01	
Dead Load	0.00	in
Horizontal Component	0.00	in
Total Load	0.02	IN L/2908
Horizontal Component	0.01	

Live Load Deflection Criteria: L/360 Total Load Deflection Criteria: L/240

REACTIONS

A B

Live Load	167 lb	130 lb
Dead Load	17 lb	17 lb
Total Load	183 lb	146 lb
Bearing Length	0.63 in	0.63 in

BEAM DATA

Center

Span Length	5 ft
Unbraced Length-Top	1.5 ft
Unbraced Length-Bottom	5 ft

STEEL ANGLE PROPERTIES

L4x4x1/4 - A36

Properties:

Yield Stress:	Fy =	36 ksi
Modulus of Elasticity:	E =	29000 ksi
Depth (Leg Length):	d =	4 in
Leg Thickness:	tw =	0.25 in
Distance to Angle Toe of Fillet:	k =	0.63 in
Moment of Inertia About X-X Axis:	Ix =	3 in4
Section Modulus About X-X Axis:	Sx =	1.03 in3

Design Properties per 13th Edition AISC Steel Manual:

Angle Tip is in Compression	
Flange Buckling Ratio:	FBR = 16
Allowable Flange Buckling Ratio for Compact:	AFBR = 15.33
Allowable Flange Buckling Ratio for Non-Compact:	AFBR_NC = 25.83
Elastic Lateral-Torsional Buckling Moment:	Me = 114.89 ft-lb
Nominal Flexural Strength w/ Safety Factor:	Mn = 1962.04 ft-lb
Controlling Equation:	F10-3
Controlling Cv Factor:	Cv = 1
Nominal Shear Strength w/ Safety Factor:	Vn = 12934 lb

Controlling Moment:

267 ft-lb

1.5 Ft from left support of span 2 (Center Span)

Created by combining all dead loads and live loads on span(s) 2

Controlling Flexural Shear: 183 lb

Controlling Torsional Shear (C-G4-2): 2351 lb

Controlling Shear: 2534 lb

At left support of span 2 (Center Span)

Created by combining all dead loads and live loads on span(s)

Comparisons with required sections:

	Req'd	Provided
Moment of Inertia (deflection):	0.34 in4	3 in4
Moment:	267 ft-lb	1962 ft-lb
Shear:	2534 lb	12934 lb

UNIFORM LOADS

Center

Uniform Live Load	0 plf
Uniform Dead Load	0 plf
Beam Self Weight	7 plf
Total Uniform Load	7 plf

POINT LOADS - CENTER SPAN

Load Number	One	Two
Live Load	194 lb	102.5 lb
Dead Load	0 lb	0 lb
Location	1.5 ft	3.5 ft

$$F_{wind} = \frac{388\#}{2} = 194\#$$

$$F_{wind} = \frac{205\#}{2} = 102.5\#$$

* CHECK ANTENNA SUPPORT ANCHORING SYSTEM: (WORSE CASE)

OVERVIEW: THE ANTENNA SUPPORT ANCHORS ARE ATTACHED TO THE PARAPET AT EACH END WITH (2) 1/2 HILTI HY 20 (REFERENCE: ORIGINAL DESIGN DRAWING PREPARED BY AERIAL SPECTRUM)

$$\begin{array}{l} F_T = 525\# \\ F_V = 1230\# \end{array} \left. \begin{array}{l} \text{HIT-HY20} \\ (2" \text{ EMBEDMENT}) \\ (\text{ASSUMED}) \end{array} \right\}$$

- TENSION

$$f_T = \frac{183\#}{2 \text{ ANCHORS}} = \underline{\underline{91.5\#/\text{ANCHOR}}} < 525\#/\text{ANCHOR} \therefore \text{O.K.}$$

- SHEAR:

$$f = \frac{199\# + 108\# + 40\#}{2} = 173.5\#$$

$$f_V = \frac{173.5\#}{2 \text{ ANCHORS}} = \underline{\underline{86.75\#/\text{ANCHOR}}} < 1230\#/\text{ANCHOR} \therefore \text{O.K.}$$

- CHECK COMBINED TENSION/SHEAR:





$$\frac{f_T}{F_T} + \frac{f_V}{F_V} \leq 1.0$$

$$\frac{91.5}{525} + \frac{86.75}{1230} = \underline{\underline{0.24}} < 1.0 \therefore \text{O.K.}$$



Referenced Drawings



SECTION
SCALE 1/4" = 1'-0"



ROOF CURB EXTENSION

ALL THE REINFORCING IN SLABS WILL BE SET IN PLACE AND LOCATIONS TO BE NUMBERED BY POST-TENSIONING CONTRACTOR.




CURB LOCATED OVER THE (67) RAMPED CONCRETE COLUMNS.




NOTE: ALL ROOF REINFORCING PLAN FOR WILD REINFORCING PLAN DWG. 103 FOR CONCRETE.

FIN. 5TH FLOOR ELEV. 106.00'
FIN. 6TH FLOOR ELEV. 110.00'
FIN. 7TH FLOOR ELEV. 114.00'
FIN. 8TH FLOOR ELEV. 118.00'
FIN. 9TH FLOOR ELEV. 122.00'

DESIGN A. SEE PLAN, 7th FLOOR.




SECTION
NO SCALE



SECTION
NO SCALE



NOTES:
1. ALL REINFORCING SHALL BE SET IN PLACE AND LOCATIONS TO BE NUMBERED BY POST-TENSIONING CONTRACTOR.
2. ALL REINFORCING SHALL BE SET IN PLACE AND LOCATIONS TO BE NUMBERED BY POST-TENSIONING CONTRACTOR.
3. ALL REINFORCING SHALL BE SET IN PLACE AND LOCATIONS TO BE NUMBERED BY POST-TENSIONING CONTRACTOR.



ROOF PLAN
SCALE: 1/4"=1'-0"

NOTES:
-PLOT PLAN IS NOT THE RESULT OF A SURVEY. IT IS BASED ON FIELD MEASUREMENTS AND SCALED ASSESSMENTS. MAPS ARE AVAILABLE. ALL INFORMATION SHOWN IS APPROXIMATE ONLY AND SUBJECT TO ANY CONDITIONS THAT A SURVEY MAY REVEAL.

PLOT PLAN
APPL. SCALE: 1"=100'-0"

CINGULAR WIRELESS
SITE PLAN & ROOF PLAN
DERRICK TUBERT




NO.	DATE	REVISIONS	BY	CHK	APP'D

SCALE: AS SHOWN | DESIGNED: PRC ETJ | DRAWN: PRC BP

xcingular WIRELESS
CONSTRUCTION AUTHORITY
300 MAIN STREET
BOXTON, MA 01740
PHONE: (781) 960-1474
FAX: (781) 960-1474

ME5045
USM PORTLAND
DEERING AVENUE
PORTLAND, ME 03082

One General Way
PO Box 373 890
Bangor, ME 04401
tel: (781) 842 0020
fax: (781) 842 0554
e-mail: samon@cingularspectrum.com





GPS SUPPORT
SCALE: N.T.S.



EXTERIOR CONDUIT RUN
SCALE: N.T.S.



CONDUIT RUN ON ROOF
SCALE: N.T.S.



TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.



VERTICAL COAX CABLE TRAY
SCALE: N.T.S.



CONDUIT RUN ON ROOF
SCALE: N.T.S.




TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.



VERTICAL COAX CABLE TRAY
SCALE: N.T.S.



CONDUIT RUN ON ROOF
SCALE: N.T.S.



TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.



VERTICAL COAX CABLE TRAY
SCALE: N.T.S.



CONDUIT RUN ON ROOF
SCALE: N.T.S.



TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.



VERTICAL COAX CABLE TRAY
SCALE: N.T.S.



CONDUIT RUN ON ROOF
SCALE: N.T.S.

GPS SUPPORT
SCALE: N.T.S.

EXTERIOR CONDUIT RUN
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

GPS SUPPORT
SCALE: N.T.S.

EXTERIOR CONDUIT RUN
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.

CONDUIT RUN ON ROOF
SCALE: N.T.S.

TRENCH DETAIL-ELEC/TELCO
SCALE: N.T.S.

VERTICAL COAX CABLE TRAY
SCALE: N.T.S.

ROOF MOUNTED COAX TRAY
SCALE: N.T.S.




One General Way
PO Box 373 880
Rye Beach, WI 53081
Tel: (715) 842-0920
Fax: (715) 842-0551
E-mail: eason@earthlink.net

ME5045
USM PORTLAND
DEERING AVENUE
PORTLAND, ME 04102


cingular™ WIRELESS
CONSTRUCTION INFORMATION
340 MAIN STREET
BOSTON, MA 02140
PHONE: (781) 860-7474

C-2




PLAN

NOTE: LOCATION OF PROPOSED CURB PLATFORM DERIVED FROM EXISTING BUILDING PLANS OBTAINED FROM USM PORTLAND MAINTENANCE DEPARTMENT. EXISTING PLATFORMS TO BE REMOVED AND RELOCATED TO EXISTING SUPPORT COLUMNS PRIOR TO CONSTRUCTION.



ELEVATION A-A

SCALE: 1/2" = 1'-0"




SECTION AT RBS UNIT

SCALE: N.T.S.

DETAIL AT PLATFORM CURB

SCALE: N.T.S.

NOTE: THE CONTRACTOR SHALL COORDINATE ALL WORK WITH BUILDING OWNER'S PROJECT MANAGER AND COMPLETE ALL WORK ASSOCIATED WITH THE PROJECT PRIOR TO THE START OF CONSTRUCTION. THE BUILDING OWNER'S PROJECT MANAGER SHALL BE RESPONSIBLE FOR THE INSTALLATION OF THE EQUIPMENT CURB PLATFORM.



EQUIPMENT PLATFORM PLAN


SCALE: 1/2" = 1'-0"

One General Way
PO Box 373
Reading, MA 01860
Tel: (781) 942 0024
Fax: (781) 942 0551
e-mail: esmon@earthlink.net.com

ME5045
USM PORTLAND
DEERING AVENUE
PORTLAND, ME 03082

cingular
WIRELESS
CONSTRUCTION DEPARTMENT
BOSTON, MA 01740
PHONE: (781) 880-7422
FAX: (881) 880-2474


PROFESSIONAL STAMP		CINGULAR WIRELESS	
		CONSTRUCTION DETAILS	
NO. DATE	AS SHOWN	ISSUED:	DRAWN:
D 01-29-06	AS B.L.S.	INC. PAUL ETK	INC. CMC (APP)
REV. DATE	BY	CHK (APP)	REV.
			0
			0



TMA NOTE:
REQUIRED NUMBER OF TMAS PER ANTENNA BASED ON RF
REQUIREMENT. CONTACT CONTRIBUTOR TO VERIFY PRIOR TO CONSTRUCTION

ANTENNA DETAIL

SCALE: N.T.S.




NOTES:

1. PRIME AND PAINT ALL MOUNTING BRACKETS AND ANTENNAS TO MATCH (E) BUILDING FACADE W/GROUT LINES.

FACADE ANTENNA MOUNTING DETAIL

SCALE: N.T.S.



NOTES:

1. PRIME AND PAINT ALL MOUNTING BRACKETS AND ANTENNAS TO MATCH (E) BUILDING FACADE W/GROUT LINES.


ANTENNA MOUNTING DETAILS

SCALE: N.T.S.



ANGLE MOUNTING DETAIL

SCALE: N.T.S.



One General Way
PO Box 373
Reading, MA 01880
tel. (781) 942.0024
fax (781) 942.0551
e-mail eastmon@bairnadspectrum.com



ME5045
USM PORTLAND
DEERING AVENUE
PORTLAND, ME 03082


cingular
WIRELESS
CONSTRUCTION DEPARTMENT
BOSTON, MA 01740
PHONE: (781) 890-7422
FAX: (781) 890-7474



NO. DATE	AS SHOWN	DESIGNED	PRC. CH. DRAWN	PRC. IN
D 11-29-06	AS BUILTS		BY	CHK/PTD
			PRC. PAUL ETX	

CONSTRUCTION DETAILS	
DRAWING NUMBER	C-4
REV	0

CINGULAR WIRELESS



CLIENT NAME:
STATE OF MAINE
LAW SCHOOL

DATE: 4/12/06 PAGE: 1/7
BY: M. MARTEL
SITE NAME: USM PORTLAND

NEW LOCATION FOR CABINETS


CHECK COLUMNS 76 & 75

LOADS:


FROM DESIGN DRAWINGS

- ROOF 60 #/ft²
- 7th FLOOR 100 #/ft²
- 6th FLOOR 100 #/ft²
- 5th FLOOR 100 #/ft²
- 4th FLOOR 100 #/ft² (BEAM LOAD ONLY)

LIGHT WT CONCRETE ON ALL FLOORS
115 #/ft³



CALCULATE TRIBUTARY AREA FOR COLUMN



$$C = 2(\tan 10(41)) = 14.4$$

$$b = 2(\tan 10(8)) = 2.8$$

$$a = 20'$$


$$AREA = (C+b)/2 (a) = 172$$

SLAB THICKNESS = 8" $\Rightarrow 8/12(172) = 114.9 \text{ ft}^3$

COLUMN WT = $(18" \times 18") / 144 (10') = 22.5 \text{ ft}^3$

LOAD TOTALS:

	DL	DL SLAB	COLUMN
ROOF	10.5 ^k	13.2 ^k	2.6 ^k
7 th	17.2 ^k	13.2 ^k	2.6 ^k
6 th	17.2 ^k	13.2 ^k	2.6 ^k
5 th	17.2 ^k	13.2 ^k	2.6 ^k



AE DESIGN PACKAGE REVIEW STATUS			
<input checked="" type="checkbox"/>	ACCEPTED—NO COMMENTS, PROCEED		
<input type="checkbox"/>	COMMENTS		
A	<input type="checkbox"/> BAC into drawings/contracts	F	<input type="checkbox"/> Design deviation from standard
B	<input type="checkbox"/> AE did not follow directions provided	G	<input type="checkbox"/> Omissions
C	<input type="checkbox"/> Site owner requested changes	H	<input type="checkbox"/> AE generated change to design
D	<input type="checkbox"/> Design input changes, i.e., RF, zoning required	I	<input type="checkbox"/> AEB changed site design
E	<input type="checkbox"/> Revised site design	J	<input type="checkbox"/> OTHER
<small>Provisional to proceed does not constitute acceptance or approval of design details, calculations, analysis, test methods, or materials developed or selected by the supplier and does not relieve the supplier from full compliance with contractual obligations.</small>			
Reviewed by: (PE/SE) <i>Stam Rly</i>		Date: 2-12-07	
RF ENGINEER	SA	MANAGER LEAD	CONSTRUCTION
<i>172</i>			



ONE GENERAL WAY
PO BOX 373
READING, MA 01867
P: (781) 942-0024
F: (781) 942-0551

CLIENT NAME:

STATE OF MAINE
LAW SCHOOL

DATE: 4/12/06

PAGE: 2/7

BY: H. MARTIN


SITE NAME: USM PORTLAND

COLUMN LOAD

MAX COLUMN LOAD ON TOP OF 4TH FLOOR

$$P = 10.3 + (19.2)(3) + (13.2)(4) + (2.6)(4) = 125^k$$

CHECK COLUMN



$$K = 0.5$$

$$L = 10'$$

TOTAL LOAD 4/ CABINETS $10/2 = 5$

$$125^k + 5^k = 130^k$$

SEE ATTACHED SPREADSHEET
(MATH CADD)

Input Column Properties

$$f_c := 3000 \text{ psi} \quad A_s := 2 \text{ in}^2 \quad d' := 2.564 \text{ in} \quad b := 18 \text{ in}$$

$$f_y := 60000 \text{ psi} \quad A's := 2 \text{ in}^2 \quad h := 18 \text{ in}$$

$$A_g := b \cdot h \quad A_g = 324 \text{ in}^2 \quad y_{\text{bar}} := \frac{h}{2} \quad y_{\text{bar}} = 9 \text{ in}$$

Maximum Vertical Loading

$$P_o := [0.85 f_c (A_g - A_s - A's) + (A_s + A's) \cdot f_y]$$

$$P_o = 1056 \text{ kip}$$

$$\phi P_o := 0.7 \cdot P_o$$

$$\phi P_o = 739.2 \text{ kip}$$

$$P_{n\text{max}} := 0.8 [0.85 f_c (A_g - A_s - A's) + (A_s + A's) \cdot f_y]$$

$$\phi P_{n\text{max}} := 0.7 \cdot P_{n\text{max}}$$

$$P_{n\text{max}} = 844.8 \text{ kip}$$

$$\phi P_{n\text{max}} = 591.36 \text{ kip}$$

$$\phi M_o := 0$$

Balance Condition

$$d := h - d'$$

$$d = 15.44 \text{ in}$$

$$c_b := \frac{87000}{87000 + \frac{f_y}{\text{psi}}} \cdot d$$

$$c_b = 9.14 \text{ in}$$

$$e's := 0.003 \left(\frac{c_b - d'}{c_b} \right)$$

$$e's = 0.00216 \frac{\text{in}}{\text{in}}$$

$$f_s := 29000000 \text{ psi} \cdot e's$$

$$f_s = 62582.534 \text{ psi}$$

$$\beta_1 := 0.85 - \frac{0.05 \left(\frac{f_c}{\text{psi}} - 4000 \right)}{1000}$$

$$\beta_1 = 0.9$$

$$a_b := \beta_1 \cdot c_b$$

$$a_b = 8.22 \text{ in}$$

$$P_{nb} := 0.85 \cdot f_c \cdot b \cdot a_b + A's \cdot f_s - A_s \cdot f_y$$

$$\phi P_{nb} := 0.7 \cdot P_{nb}$$

$$P_{nb} = 382.556 \text{ kip}$$

$$\phi P_{nb} = 267.789 \text{ kip}$$

$$M_{nb} := 0.85 \cdot f_c \cdot b \cdot a_b \cdot \left(y_{\text{bar}} - \frac{a_b}{2} \right) + A's \cdot f_s \cdot (y_{\text{bar}} - d') + A_s \cdot f_y \cdot (d - y_{\text{bar}})$$

$$\phi M_{nb} := 0.7 \cdot M_{nb}$$

$$M_{nb} = 3422.942 \text{ in} \cdot \text{kip}$$

$$\phi M_{nb} = 199.7 \text{ ft} \cdot \text{kip}$$

$$e_b := \frac{M_{nb}}{P_{nb}} \quad e_b = 8.95 \text{ in}$$

Pure Bending Mo

$$a := \frac{A_s \cdot f_y}{0.85 \cdot f_c \cdot b}$$

$$a = 2.61 \text{ in}$$

$$\beta_1 := \frac{a}{c}$$

$$c = 2.9 \text{ in}$$

$$\epsilon'_{s_m} := 0.003 \cdot \left(\frac{c - d'}{c} \right)$$

$$\epsilon'_{s_m} = 0.00035 \frac{\text{in}}{\text{in}}$$

$$f'_{s_m} := 29000000 \text{ psi} \cdot \epsilon'_{s_m}$$

$$f'_{s_m} = 10208.841 \text{ psi}$$

$$M_{no} := A_s \cdot f_y \cdot \left(d - \frac{a}{2} \right)$$

$$\phi M_{no} := 0.9 \cdot M_{no}$$

$$M_{no} = 1695.5 \text{ in}\cdot\text{kip}$$

$$\phi M_{no} = 127.2 \text{ ft}\cdot\text{kip}$$

$$\phi P_0 := 0 \text{ kip}$$

Compression Controls

$$c_1 := \frac{c_b + h}{2} \quad c_1 = 13.57 \text{ in}$$

$$\epsilon'_{s_1} := 0.003 \cdot \left(\frac{c_1 - d'}{c_1} \right)$$

$$\epsilon_{y_1} := \frac{f_y}{29000000}$$

$$\epsilon_{s_1} := 0.003 \cdot \frac{d - c_1}{c_1}$$

$$\epsilon'_{s_1} = 0.00243 \frac{\text{in}}{\text{in}}$$

$$\epsilon_{y_1} = 0.00207 \frac{\text{in}}{\text{in}}$$

$$\epsilon_{s_1} = 0.00041 \frac{\text{in}}{\text{in}}$$

$$\epsilon'_{s_{a1}} := \min(\epsilon'_{s_1}, \epsilon_{y_1})$$

$$f_{s_1} := \epsilon'_{s_1} \cdot 29000000 \text{ psi}$$

$$f_{s_{a1}} := \epsilon'_{s_{a1}} \cdot 29000000 \text{ psi}$$

$$f_{s_1} = 11979.378 \text{ psi}$$

$$f_{s_{a1}} = 60000 \text{ psi}$$

$$a_1 := \beta_1 \cdot c_1$$

$$a_1 = 12.21 \text{ in}$$

$$C_{c1} := 0.85 \cdot f_c \cdot b \cdot a_1$$

$$C_{s1} := A_s \cdot f_y$$

$$T_{s1} := A_s \cdot f_{s_1}$$

$$C_{c1} = 560.49 \text{ kip}$$

$$C_{s1} = 120 \text{ kip}$$

$$T_{s1} = 23.96 \text{ kip}$$

$$P_{n1} := C_{c1} + C_{s1} - T_{s1}$$

$$\phi P_{n1} := 0.7 \cdot P_{n1}$$

$$P_{n1} = 656.53 \text{ kip}$$

$$\phi P_{n1} = 459.57 \text{ kip}$$

$$M_{n1} := C_{c1} \cdot \left(y_{\text{bar}} - \frac{a_1}{2} \right) + C_{s1} \cdot (y_{\text{bar}} - d') + T_{s1} \cdot (d - y_{\text{bar}})$$

$$\phi M_{n1} := 0.7 \cdot M_{n1}$$

$$M_{n1} = 2548.84 \text{ in}\cdot\text{kip}$$

$$\phi M_{n1} = 148.682 \text{ ft}\cdot\text{kip}$$

$$e_1 := \frac{M_{n1}}{P_{n1}}$$

$$e_1 = 3.88 \text{ in}$$

Tension Controls

$$c_2 := \frac{c_b}{2} \quad c_2 = 4.57 \text{ in}$$

$$a_2 := \beta_1 \cdot c_2$$

$$\epsilon's_2 := 0.003 \left(\frac{c_2 - d'}{c_2} \right)$$

$$a_2 = 4.11 \text{ in}$$

$$\epsilon's_2 = 0.00132$$

$$f_{s2} := \min(\epsilon's_2 \cdot 29000000 \text{ psi}, 60000 \text{ psi})$$

$$f_{s2} = 38165.069 \text{ psi}$$

$$f_{s2} := f_y$$

$$f_{s2} = 60000 \text{ psi}$$

$$C_{c2} := 0.85 \cdot f_c \cdot b \cdot a_2$$

$$C_{c2} = 188.7 \text{ kip}$$

$$C_{s2} := A's \cdot f_{s2}$$

$$C_{s2} = 76.33 \text{ kip}$$

$$T_{s2} := A_s \cdot f_{s2}$$

$$T_{s2} = 120 \text{ kip}$$

$$P_{n2} := C_{c2} + C_{s2} - T_{s2}$$

$$\phi P_{n2} := 0.7 \cdot P_{n2}$$

$$P_{n2} = 145.03 \text{ kip}$$

$$\phi P_{n2} = 101.52 \text{ kip}$$

$$M_{n2} := C_{c2} \left(y_{\text{bar}} - \frac{a_2}{2} \right) + C_{s2} \cdot (y_{\text{bar}} - d') + T_{s2} \cdot (d - y_{\text{bar}})$$

$$\phi M_{n2} := 0.7 \cdot M_{n2}$$

$$M_{n2} = 2573.976 \text{ in-kip}$$

$$\phi M_{n2} = 150.15 \text{ ft-kip}$$

$$e_2 := \frac{M_{n2}}{P_{n2}}$$

$$e_2 = 17.75 \text{ in}$$

Interaction Diagram Loads and Moments

$$\phi M := \begin{pmatrix} \frac{\phi M_0}{\text{ft}\cdot\text{kip}} \\ \frac{\phi M_{n1}}{\text{ft}\cdot\text{kip}} \\ \frac{\phi M_{nb}}{\text{ft}\cdot\text{kip}} \\ \frac{\phi M_{n2}}{\text{ft}\cdot\text{kip}} \\ \frac{\phi M_{no}}{\text{ft}\cdot\text{kip}} \end{pmatrix} \quad \phi P := \begin{pmatrix} \frac{\phi P_0}{\text{kip}} \\ \frac{\phi P_{n1}}{\text{kip}} \\ \frac{\phi P_{nb}}{\text{kip}} \\ \frac{\phi P_{n2}}{\text{kip}} \\ \frac{\phi P_0}{\text{kip}} \end{pmatrix} \quad \phi MI := \begin{pmatrix} 0 \\ \frac{\text{ft}\cdot\text{kip}}{\text{ft}\cdot\text{kip}} \\ \frac{\phi M_{nb}}{\text{ft}\cdot\text{kip}} \end{pmatrix}$$


$$\phi PO := \begin{pmatrix} \frac{\phi P_{nmax}}{\text{kip}} \\ \frac{\phi P_{nmax}}{\text{kip}} \end{pmatrix}$$


Loads and Moments from Structure

(kip and ft-kip)

$$P_n := \begin{pmatrix} 130 \\ 130 \\ 130 \\ 0 \end{pmatrix} \quad M_n := \begin{pmatrix} 0 \\ 60 \\ 130 \\ 0 \end{pmatrix}$$


Interaction Diagram




 ONE GENERAL WAY PO BOX 373 READING, MA 01867 P: (781) 942-0024 F: (781) 942-0551	CLIENT NAME:	DATE: 4/12/06	PAGE: 7/7
	STATE OF MAINE LAW SCHOOL	BY: M. MARTEL	
		SITE NAME: USM PORTLAND	

CHECK BEAM ON 4th FLOOR

BEAM B-2 & B-2A



SPAN 40'



$$M = 1831 \text{ ft KIPS} = 21972 \text{ in KIPS}$$

$$\begin{aligned}
 f^t &= -\frac{P_c}{AC} \left(1 + \frac{eG}{r^2}\right) + \frac{21972}{S_x} \\
 &= -\frac{793.6}{1200} \left(1 + \frac{17(21)}{12.12^2}\right) + \frac{21972}{8520} = \\
 &= -0.63 \text{ ksi} (1 + 2.43) + 2.49 = 0.329 \text{ ksi } \underline{OK}
 \end{aligned}$$

$$f^b = -0.63 (1 - 2.43) - 2.49 = 7.59 \text{ ksi } \underline{OK}$$