

STRUCTURAL ANALYSIS REPORT

For

ME 5045 (LTE 3C)

PORTLAND USM

246 Deering Avenue
Portland, ME 03082

**Antennas Mounted on Pipe Masts Secured to Parapet walls and
Penthouse Façade; Equipment Platform on the Roof**



Prepared for:



Dated: March 2, 2016

Prepared by:



1600 Osgood Street Building 20 North, Suite 3090
North Andover, MA 01845
Phone: (978) 557-5553

www.hudsondesigngroupplc.com





SCOPE OF WORK:

Hudson Design Group LLC (HDG) has been authorized by AT&T to conduct a structural evaluation of the structure that will support the existing AT&T equipment located in the areas depicted in the latest HDG's construction drawings.

This report represents this office's findings, conclusions and recommendations pertaining to the support of AT&T's proposed equipment.

This office performed an on-site visual survey of the above areas on January 27, 2016. Attendees included Rick Greene (HDG – Field Technician).

CONCLUSION SUMMARY:

As-built plans prepared by Donald L. Dimick dated May 1970 were available for our use. A limited visual survey of the structure was completed in or near the areas of the Proposed Work. The following documents were used for our reference:

- Original construction drawings prepared by Aerial Spectrum dated April 26, 2006.
- Previous HDG Structural Analysis Report dated March 8, 2012.

Based on our evaluation, we have determined that the existing structure **IS CAPABLE** of supporting the proposed equipment loading with the following modification:

- **Brace the existing parapets with new steel angle kickers tied back to the roof structure secured with epoxy anchors at both ends (See the latest HDG construction drawings for details).**
- **Reinforce the existing H-Frame supporting the existing Purcell Cabinet with new pipe masts and new angle kickers secured to the roof with epoxy anchors (See the latest HDG construction drawings for details).**



APPURTENANCE/EQUIPMENT CONFIGURATION:

- (3) 7770 Antennas (55"x11"x5" – Wt. = 35 lbs. /each) (One per sector)**
- (1) SBNH-1D6565C Antenna (96.4"x11.9"x7.1" – Wt. = 61 lbs. each) (Alpha)**
- (1) HPA-65R-BUU-H8 Antenna (92.4"x14.8"x7.4" – Wt. = 73 lbs. each) (Alpha)**
- (1) TPA-65R-LCUUUU-H8 Antenna (96"x14.4"x8.6" – Wt. = 75 lbs. each) (Alpha)**
- (1) AM-X-CD-14-65-00T-RET Antenna (48"x11.8"x5.9" – Wt. = 37 lbs. each) (Beta)**
- (1) SBNHH-1D65A Antenna (55"x11.85"x7.1" – Wt. = 41 lbs. each) (Beta)**
- (2) QS66512-3 Antennas (72"x12"x9.6" – Wt. = 105 lbs. each) (Beta & Gamma)**
- (1) AM-X-CD-16-65-00T-RET Antenna (72"x11.8"x5.9" – Wt. = 49 lbs. each) (Gamma)**
- (1) HPA-65R-BUU-H6 Antenna (72"x14.8"x9" – Wt. = 56 lbs. each) (Gamma)**
- (9) RRUS-11 RRH (19.7"x17"x7.2" – Wt. = 51 lbs. /each) (Three per sector)**
- (6) A2 Modules (16.4"x15.2"x3.4" – Wt. = 22 lbs. /each) (Two per sector)**
- (3) RRH (RRUS-32) (26.7"x12.1"x6.7" – Wt. = 60 lbs. /each) (One per sector)**
- (3) Squid Surge Suppressors (24"x9.7"ø - Wt. = 33 lbs. /each) (One per sector)**
- (3) 9E Surge Suppressors (11.5"x10.4"x6.3" - Wt. = 43.5 lbs. /each) (One per sector)**



DESIGN CRITERIA:

1. International Building Code (IBC) 2009, and ASCE 7-05 (Minimum Design Loads for Buildings and Other Structures).

Wind Analysis:

| | | |
|-----------------------|---------|------------------------------|
| Reference Wind Speed: | 100 mph | (FIG 6-1C; ASCE 7-05) |
| Category: | C | (Section 6.5.6.3; ASCE 7-05) |

Roof:

| | | |
|-----------------------------|---------------|---|
| Ground Snow, P_g : | 60 psf | (FIG 7-1; ASCE 7-05) |
| Importance Factor, I : | 1.0 | (Category II) |
| Exposure Factor, C_e : | 1.0 | (Exp. B- Partially Exposed) |
| Thermal Factor, C_t : | 1.0 | (Typical Structure) |
| Flat Roof Snow Load: | 42 psf | ($P_r=0.7*C_e*C_t*I*P_g$) |

2. EIA/TIA -222- G Structural Standards for Steel Antenna Towers and Antenna Supporting Structures

| | |
|------------------------|------------|
| City/Town: | Portland |
| County: | Cumberland |
| Wind Load: | 100 mph |
| Nominal Ice Thickness: | 1 inch |

3. Approximate height above grade to the center of the Antennas:

92'-5"+/- (Alpha)
88'-3"+/- (Beta & Gamma)



EXISTING ROOF CONSTRUCTION:

The existing roof construction consists of a roofing membrane over a reinforced concrete slab supported by reinforced concrete columns and bearing walls.

ANTENNA SUPPORT RECOMMENDATIONS:

- The new Alpha sector antenna is proposed to be mounted on a new pipe mast attached to existing angle wall mounts secured to the existing penthouse façade with epoxy anchors.
- The new Beta and Gamma sector antennas are proposed to be mounted on new pipe masts attached to existing steel angles secured to the existing parapet walls with epoxy anchors.

HDG recommends bracing the existing parapets with new steel angle kickers tied back to the roof structure secured with epoxy anchors at both ends.

RRH SUPPORT RECOMMENDATIONS:

- The new Alpha sector RRH's are proposed to be mounted on new unistrut components secured to the existing penthouse façade with epoxy anchors.
- The new Beta & Gamma sector RRH's are proposed to be mounted on new unistrut components attached to existing steel angles secured to the existing parapets with epoxy anchors.

Limitations and assumptions:

1. Reference the latest HDG construction drawings for all the equipment locations details.
2. Mount all equipment per manufacturer's specifications.
3. All structural members and their connections are assumed to be in good condition and are free from defects with no deterioration to its member capacities.
4. All antennas, coax cables and waveguide cables are assumed to be properly installed and supported as per the manufacturer requirements.
5. HDG is not responsible for any modifications completed prior to and hereafter which HDG was not directly involved.
6. If field conditions differ from what is assumed in this report, then the engineer of record is to be notified as soon as possible.
7. A condition assessment of the roof was not part of the scope of work.

FIELD PHOTOS:



Photo 1: Sample photo illustrating the existing antennas.



Photo 2: Sample photo illustrating the existing antennas.

FIELD PHOTOS (Cont.):



Photo 3: Sample photo illustrating the existing antennas.



Photo 4: Sample photo illustrating the existing Purcell cabinet on existing H-Frame (to be reinforced).



Alpha Sector Calculations

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



ALPHA

2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

$K_z =$ **1.245**
 $z =$ 92.42 (ft)
 $z_g =$ 900 (ft)
 $\alpha =$ 9.5

$K_{zmin} \leq K_z \leq 2.01$

Table 2-4

| Exposure | Z_g | α | K_{zmin} | K_e |
|----------|---------|----------|------------|-------|
| B | 1200 ft | 7.0 | 0.70 | 0.9 |
| C | 900 ft | 9.5 | 0.85 | 1.0 |
| D | 700 ft | 11.5 | 1.03 | 1.1 |

2.6.6.4 Topographic Factor:

Table 2-5

| Topo. Category | K_t | f |
|----------------|-------|------|
| 2 | 0.43 | 1.25 |
| 3 | 0.53 | 2.0 |
| 4 | 0.72 | 1.5 |

$K_{zt} = [1 + (K_e K_t / K_h)]^2$

$K_h = e^{(f \cdot z / H)}$

$K_{zt} =$ **#DIV/0!**

$K_h =$ **#DIV/0!**

$K_e =$ 0 (from Table 2-4)

$K_t =$ 0 (from Table 2-5)

f = 0 (from Table 2-5)

z = 92.42

H = 0 (Ht. of the crest above surrounding terrain)

$K_{zt} =$ 1.00

(If Category 1 then $K_{zt} = 1.0$)

Category = **1**

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



2.6.7 Gust Effect Factor

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

h= 85 Gh= 0.85

2.6.7.2 Guyed Masts Gh= 0.85

2.6.7.3 Pole Structures Gh= 1.1

2.6.9 Appurtenances Gh= 1.0

2.6.7.4 Structures Supported on Other Structures

(Cantilevered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35 Gh= 1.35

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



2.6.9.2 Design Wind Force on Appurtenances

$$F = q_z * G_h * (EPA)_A$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2 * I$$

q_z = 30.27

K_z = 1.245

K_{zt} = 1.0

K_d = 0.95

V_{max} = 100

I = 1.0

Table 2-2

| Structure Type | Wind Direction Probability Factor, Kd |
|---|---------------------------------------|
| Latticed structures with triangular, square or rectangular cross sections | 0.85 |
| Tubular pole structures, latticed structures with other cross sections, appurtenances | 0.95 |

Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

| C | Round | 18 Sided | 16 Sided | 12 Sided | 8 Sided |
|----------------------------|-----------------------|-------------------------|-------------------------|-------------------------|---------|
| < 32 (Subcritical) | 1.2 | 1.2 | 1.2 | 1.2 | 1.2 |
| 32 to 64 (Transitional) | 38.4/C ^{1.0} | 25.8/C ^{0.885} | 12.6/C ^{0.678} | 2.99/C ^{0.263} | 1.2 |
| > 64 (Supercritical) | 0.6 | 0.65 | 0.75 | 1 | 1.2 |

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

D = Outside diameter for rounds: 0.25 feet

C = 27.89

Cf = 1.2

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



Determine Ca:

Table 2-8

| Force Coefficients (Ca) for Appurtenances | | | | |
|---|-------------------------------|--------------------|--------------------|-------------------|
| Member Type | | Aspect Ratio ≤ 2.5 | Aspect Ratio = 7 | Aspect Ratio ≥ 25 |
| | | Ca | Ca | Ca |
| Flat | | 1.2 | 1.4 | 2.0 |
| Round | C < 32 (Subcritical) | 0.7 | 0.8 | 1.2 |
| | 32 ≤ C ≤ 64 (Transitional) | $3.76/(C^{0.485})$ | $3.37/(C^{0.415})$ | $38.4/(C^{1.0})$ |
| | C > 64 (Supercritical) | 0.5 | 0.6 | 0.6 |

Aspect Ratio is the overall length/width ratio in the plane normal to the wind direction.
 (Aspect ratio is independent of the spacing between support points of a linear appurtenance,
 and the section length considered to have uniform wind load).

Note: Linear interpolation may be used for aspect ratios other than those shown.

| <u>Appurtenances</u> | <u>Height</u> | <u>Width</u> | <u>Depth</u> | <u>Flat Area</u> | <u>Aspect Ratio</u> | <u>Ca</u> | <u>Force (lbs)</u> |
|----------------------|---------------|--------------|--------------|------------------|---------------------|-----------|--------------------|
| TPA-65R-LCUUUU-H8 | 96.0 | 14.4 | 8.6 | 9.60 | 6.67 | 1.39 | 543 |
| RRUS-32 | 26.7 | 12.1 | 6.7 | 2.24 | 2.21 | 1.20 | 110 |

ICE WEIGHT CALCULATIONS

Project: ME5045 - Portland USM

Thickness of ice: 1 in.
Density of ice: 56 pcf

TPA-65R-LCUUUU-H8 Antenna

Weight of ice based on total radial SF area:
Depth (in): 8.6
height (in): 96
Width (in): 14.4
Total weight of ice on object: 167 lbs
Weight of object: 75 lbs
Combined weight of ice and object: 242 lbs

QS66512-3 Antenna

Weight of ice based on total radial SF area:
Depth (in): 9.6
height (in): 72
Width (in): 12
Total weight of ice on object: 121 lbs
Weight of object: 105 lbs
Combined weight of ice and object: 226 lbs

HPA-65R-BUU-H6 Antenna

Weight of ice based on total radial SF area:
Depth (in): 9
height (in): 72
Width (in): 14.8
Total weight of ice on object: 132 lbs
Weight of object: 56 lbs
Combined weight of ice and object: 188 lbs

AM-X-CD-16-65-00T-RET Antenna

Weight of ice based on total radial SF area:
Depth (in): 5.9
height (in): 72
Width (in): 11.8
Total weight of ice on object: 99 lbs
Weight of object: 49 lbs
Combined weight of ice and object: 148 lbs

9E Surge Suppressor

Weight of ice based on total radial SF area:
Depth (in): 6.3
height (in): 11.5
Width (in): 10.4
Total weight of ice on object: 21 lbs
Weight of object: 43.5 lbs
Combined weight of ice and object: 64 lbs

2-3/8" Pipe

Per foot weight of ice:
diameter (in): 2.38
Per foot weight of ice on object: 3 plf

RRUS-11 RRH

Weight of ice based on total radial SF area:
Depth (in): 7.2
height (in): 19.7
Width (in): 17
Total weight of ice on object: 45 lbs
Weight of object: 51 lbs
Combined weight of ice and object: 96 lbs

RRUS-32 RRH

Weight of ice based on total radial SF area:
Depth (in): 6.7
height (in): 26.7
Width (in): 12.1
Total weight of ice on object: 44 lbs
Weight of object: 60 lbs
Combined weight of ice and object: 104 lbs

LGP21401 TMA

Weight of ice based on total radial SF area:
Depth (in): 2.7
height (in): 14.4
Width (in): 9
Total weight of ice on object: 16 lbs
Weight of object: 19 lbs
Combined weight of ice and object: 35 lbs

A2 Module

Weight of ice based on total radial SF area:
Depth (in): 3.4
height (in): 16.4
Width (in): 15.2
Total weight of ice on object: 28 lbs
Weight of object: 22 lbs
Combined weight of ice and object: 50 lbs

Fiber Box

Weight of ice based on total radial SF area:
Depth (in): 6
height (in): 13
Width (in): 13
Total weight of ice on object: 25 lbs
Weight of object: 20 lbs
Combined weight of ice and object: 45 lbs

3.5x3.5x0.3125 Angle

Weight of ice based on total radial SF area:
Depth (in): 0.3125
height (in): 12
Width (in): 7
Per foot weight of ice on object: 6 plf

Project:

Location: Alpha sector pipe mast
Multi-Loaded Multi-Span Beam
[2009 International Building Code(AISC 13th Ed ASD)]
Pipe 2 Std. x 9.0 FT (1 + 5.5 + 2.5) / ASTM A53-GR.B
Section Adequate By: 35.4%
Controlling Factor: Deflection



Gregory Haggstrom, EIT
Hudson Design Group LLC
1600 Osgood Street, Bldg 20N, Suite 3090
North Andover, MA 01845

page
of

StruCalc Version 8.0.113.0

3/2/2016 10:24:41 AM

| DEFLECTIONS | Left | Center | Right |
|--|-----------------|---------------|-----------------|
| Live Load | -0.08 IN 2L/292 | 0.16 IN L/408 | -0.25 IN 2L/244 |
| Dead Load | 0.00 in | 0.00 in | 0.00 in |
| Total Load | -0.08 IN 2L/288 | 0.16 IN L/404 | -0.25 IN 2L/244 |
| Live Load Deflection Criteria: L/180 Total Load Deflection Criteria: L/180 | | | |

| REACTIONS | A | B |
|----------------|---------|---------|
| Live Load | 197 lb | 346 lb |
| Dead Load | 12 lb | 21 lb |
| Total Load | 209 lb | 367 lb |
| Bearing Length | 0.29 in | 0.29 in |

| BEAM DATA | Left | Center | Right |
|------------------------|------|--------|--------|
| Span Length | 1 ft | 5.5 ft | 2.5 ft |
| Unbraced Length-Top | 1 ft | 5.5 ft | 2.5 ft |
| Unbraced Length-Bottom | 1 ft | 5.5 ft | 2.5 ft |

STEEL PROPERTIES

Pipe 2 Std. - A53-GR.B

Properties:

| | | |
|------------------------------|------|----------------------|
| Steel Yield Strength: | Fy = | 35 ksi |
| Modulus of Elasticity: | E = | 29000 ksi |
| Tube Steel Section (X Axis): | dx = | 2.38 in |
| Tube Steel Section (Y Axis): | dy = | 2.38 in |
| Tube Steel Wall Thickness: | t = | 0.143 in |
| Area: | A = | 1 in ² |
| Moment of Inertia (X Axis): | Ix = | 0.63 in ⁴ |
| Section Modulus (X Axis): | Sx = | 0.53 in ³ |
| Plastic Section Modulus: | Z = | 0.71 in ³ |

Design Properties per AISC 13th Edition Steel Manual:

| | | |
|---|-----------|------------|
| Flange Buckling Ratio: | FBR = | 16.61 |
| Allowable Flange Buckling Ratio: | AFBR = | 58 |
| Allowable Flange Buckling Ratio non-compact: | AFBR_NC = | 256.86 |
| Nominal Flexural Strength w/ Safety Factor: | Mn = | 1245 ft-lb |
| Controlling Equation: | F8-1 | |
| Shear Buckling Stress Coefficient Eqn. G6-2a: | Fcr = | 21 ksi |
| Nominal Shear Strength w/ Safety Factor: | Vn = | 6287 lb |

Controlling Moment:

689 ft-lb

3.47 Ft from left support of span 2 (Center Span)

Created by combining all dead loads and live loads on span(s) 1, 2, 3

Controlling Shear:

-357 lb


6.0 Ft from left support of span 2 (Center Span)

Created by combining all dead loads and live loads on span(s)

Comparisons with required sections:

| | Req'd | Provided |
|---------------------------------|----------------------|----------------------|
| Moment of Inertia (deflection): | 0.46 in ⁴ | 0.63 in ⁴ |
| Moment: | 689 ft-lb | 1245 ft-lb |
| Shear: | -357 lb | 6287 lb |

LOADING DIAGRAM



UNIFORM LOADS

| | Left | Center | Right |
|--------------------|-------|--------|-------|
| Uniform Live Load | 0 plf | 0 plf | 0 plf |
| Uniform Dead Load | 0 plf | 0 plf | 0 plf |
| Beam Self Weight | 4 plf | 4 plf | 4 plf |
| Total Uniform Load | 4 plf | 4 plf | 4 plf |

POINT LOADS - CENTER SPAN

| Load Number | One |
|-------------|--------|
| Live Load | 543 lb |
| Dead Load | 0 lb |
| Location | 3.5 ft |

NOTES

Site Name: Portland USM

Site No. ME5045

Done by: GH

Checked by: MSC

Date: 3/2/2016



CHECK CONNECTION CAPACITY (ALPHA)

Reference: Original CD's by Aerial Spectrum

Epoxy Type = HIT-HY20
 Anchor Diameter = 1/2 in.
 Min. Embedment Depth = 2 in.

Allowable Tensile Load =
 $F_{Tall} = 525 \text{ lbs.}$

Allowable Shear Load =
 $F_{Vall} = 1230 \text{ lbs.}$

TENSILE FORCES

Reaction $F = 346 \text{ lbs.}$
 (See StruCalc Results)

GRAVITY LOADS

Weight + Ice 310 lbs.

No. of Supports = 2

No. of Anchors / Support = 2

Tension Design Load / Anchor =


$$f_t = 173.00 \text{ lbs.} < 525 \text{ lbs.} \text{ Therefore, OK!}$$

Shear Design Load / Anchor =

$$f_v = 77.50 \text{ lbs.} < 1230 \text{ lbs.} \text{ Therefore, OK!}$$

CHECK COMBINED TENSION AND SHEAR

$$\begin{array}{rclcl}
 f_t / F_T & + & f_v / F_V & \leq & 1.0 \\
 0.330 & + & 0.063 & = & 0.393 < 1.0 \text{ Therefore, OK!}
 \end{array}$$



**Beta & Gamma Sector
Calculations**

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



BETA & GAMMA

2.6.5.2 Velocity Pressure Coeff:

$$K_z = 2.01 (z/z_g)^{2/\alpha}$$

$z = 88.25 \text{ (ft)}$
 $z_g = 900 \text{ (ft)}$
 $\alpha = 9.5$

$K_z = 1.233$

$K_{zmin} \leq K_z \leq 2.01$

Table 2-4

| Exposure | Z_g | α | K_{zmin} | K_e |
|----------|---------|----------|------------|-------|
| B | 1200 ft | 7.0 | 0.70 | 0.9 |
| C | 900 ft | 9.5 | 0.85 | 1.0 |
| D | 700 ft | 11.5 | 1.03 | 1.1 |

2.6.6.4 Topographic Factor:

Table 2-5

| Topo. Category | K_t | f |
|----------------|-------|------|
| 2 | 0.43 | 1.25 |
| 3 | 0.53 | 2.0 |
| 4 | 0.72 | 1.5 |

$K_{zt} = [1 + (K_e K_t / K_h)]^2$

$K_h = e^{(f * z / H)}$

$K_{zt} = \text{\#DIV/0!}$

$K_h = \text{\#DIV/0!}$

$K_e = 0$ (from Table 2-4)

$K_t = 0$ (from Table 2-5)

f = 0 (from Table 2-5)

z = 88.25

H = 0 (Ht. of the crest above surrounding terrain)

$K_{zt} = 1.00$

(If Category 1 then $K_{zt} = 1.0$)

Category = 1

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



2.6.7 Gust Effect Factor

2.6.7.1 Self Supporting Lattice Structures

Gh = 1.0 Latticed Structures > 600 ft

Gh = 0.85 Latticed Structures 450 ft or less

Gh = 0.85 + 0.15 [h/150 - 3.0] h= ht. of structure

 h= 280 Gh= 0.85

2.6.7.2 Guyed Masts Gh= 0.85

2.6.7.3 Pole Structures Gh= 1.1

2.6.9 Appurtenances Gh= 1.0

2.6.7.4 Structures Supported on Other Structures

(Cantilivered tubular or latticed spines, pole, structures on buildings (ht. : width ratio > 5)

Gh= 1.35 Gh= 1.35

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



2.6.9.2 Design Wind Force on Appurtenances

$$F = q_z * G_h * (EPA)_A$$

$$q_z = 0.00256 * K_z * K_{zt} * K_d * V_{max}^2 * I$$

q_z = 29.98

K_z = 1.233

K_{zt} = 1.0

K_d = 0.95

V_{max} = 100

I = 1.0

Table 2-2

| Structure Type | Wind Direction Probability Factor, Kd |
|---|---------------------------------------|
| Latticed structures with triangular, square or rectangular cross sections | 0.85 |
| Tubular pole structures, latticed structures with other cross sections, appurtenances | 0.95 |

Determine Cf:

If lattice Structure See Manual

If Tubular Pole Structure, Use Corrected Value from Table 2.7 Below

| C mph.ft | Round | 18 Sided | 16 Sided | 12 Sided | 8 Sided |
|----------------------------|-----------------------|-------------------------|-------------------------|-------------------------|---------|
| < 32 (Subcritical) | 1.2 | 1.2 | 1.2 | 1.2 | 1.2 |
| 32 to 64 (Transitional) | 38.4/C ^{1.0} | 25.8/C ^{0.885} | 12.6/C ^{0.678} | 2.99/C ^{0.263} | 1.2 |
| > 64 (Supercritical) | 0.6 | 0.65 | 0.75 | 1 | 1.2 |

$$C = (I * K_{zt} * K_z)^{0.5} * V * D$$

D = Outside diameter for rounds: 0.25 feet

C = 27.76

Cf = 1.2

Date: 03-02-2016

Project Name: Portland USM

Project Number: ME5045

Designed By: GH Checked By: MSC



Determine Ca:

Table 2-8

| Force Coefficients (Ca) for Appurtenances | | | | |
|---|-------------------------------|--------------------|--------------------|-------------------|
| Member Type | | Aspect Ratio ≤ 2.5 | Aspect Ratio = 7 | Aspect Ratio ≥ 25 |
| | | Ca | Ca | Ca |
| Flat | | 1.2 | 1.4 | 2.0 |
| Round | C < 32 (Subcritical) | 0.7 | 0.8 | 1.2 |
| | 32 ≤ C ≤ 64 (Transitional) | $3.76/(C^{0.485})$ | $3.37/(C^{0.415})$ | $38.4/(C^{1.0})$ |
| | C > 64 (Supercritical) | 0.5 | 0.6 | 0.6 |

Aspect Ratio is the overall length/width ratio in the plane normal to the wind direction.
(Aspect ratio is independent of the spacing between support points of a linear appurtenance, and the section length considered to have uniform wind load).

Note: Linear interpolation may be used for aspect ratios other than those shown.

| <u>Appurtenances</u> | <u>Height</u> | <u>Width</u> | <u>Depth</u> | <u>Flat Area</u> | <u>Aspect Ratio</u> | <u>Ca</u> | <u>Force (lbs)</u> |
|-----------------------|---------------|--------------|--------------|------------------|---------------------|-----------|--------------------|
| QS66512-3 | 72.0 | 12.0 | 9.6 | 6.00 | 6.00 | 1.36 | 329 |
| HPA-65R-BUU-H6 | 72.0 | 14.8 | 9.0 | 7.40 | 4.86 | 1.31 | 391 |
| AM-X-CD-16-65-00T-RET | 72.0 | 11.8 | 5.9 | 5.90 | 6.10 | 1.36 | 325 |
| RRUS-11 (Shielded) | 19.7 | 5.0 | 7.2 | 0.68 | 3.94 | 1.26 | 35 |
| RRUS-32 | 26.7 | 12.1 | 6.7 | 2.24 | 2.21 | 1.20 | 109 |
| 9E Surge | 11.5 | 10.4 | 6.3 | 0.83 | 1.11 | 1.20 | 40 |
| Fiber Box | 13.0 | 13.0 | 6.0 | 1.17 | 1.00 | 1.20 | 57 |

ICE WEIGHT CALCULATIONS

Project: ME5045 - Portland USM

Thickness of ice: 1 in.
Density of ice: 56 pcf

TPA-65R-LCUUUU-H8 Antenna

Weight of ice based on total radial SF area:
Depth (in): 8.6
height (in): 96
Width (in): 14.4
Total weight of ice on object: 167 lbs
Weight of object: 75 lbs
Combined weight of ice and object: 242 lbs

QS66512-3 Antenna

Weight of ice based on total radial SF area:
Depth (in): 9.6
height (in): 72
Width (in): 12
Total weight of ice on object: 121 lbs
Weight of object: 105 lbs
Combined weight of ice and object: 226 lbs

HPA-65R-BUU-H6 Antenna

Weight of ice based on total radial SF area:
Depth (in): 9
height (in): 72
Width (in): 14.8
Total weight of ice on object: 132 lbs
Weight of object: 56 lbs
Combined weight of ice and object: 188 lbs

AM-X-CD-16-65-00T-RET Antenna

Weight of ice based on total radial SF area:
Depth (in): 5.9
height (in): 72
Width (in): 11.8
Total weight of ice on object: 99 lbs
Weight of object: 49 lbs
Combined weight of ice and object: 148 lbs

9E Surge Suppressor

Weight of ice based on total radial SF area:
Depth (in): 6.3
height (in): 11.5
Width (in): 10.4
Total weight of ice on object: 21 lbs
Weight of object: 43.5 lbs
Combined weight of ice and object: 64 lbs

2-3/8" Pipe

Per foot weight of ice:
diameter (in): 2.38
Per foot weight of ice on object: 3 plf

RRUS-11 RRH

Weight of ice based on total radial SF area:
Depth (in): 7.2
height (in): 19.7
Width (in): 17
Total weight of ice on object: 45 lbs
Weight of object: 51 lbs
Combined weight of ice and object: 96 lbs

RRUS-32 RRH

Weight of ice based on total radial SF area:
Depth (in): 6.7
height (in): 26.7
Width (in): 12.1
Total weight of ice on object: 44 lbs
Weight of object: 60 lbs
Combined weight of ice and object: 104 lbs

LGP21401 TMA

Weight of ice based on total radial SF area:
Depth (in): 2.7
height (in): 14.4
Width (in): 9
Total weight of ice on object: 16 lbs
Weight of object: 19 lbs
Combined weight of ice and object: 35 lbs

A2 Module

Weight of ice based on total radial SF area:
Depth (in): 3.4
height (in): 16.4
Width (in): 15.2
Total weight of ice on object: 28 lbs
Weight of object: 22 lbs
Combined weight of ice and object: 50 lbs


Fiber Box

Weight of ice based on total radial SF area:
Depth (in): 6
height (in): 13
Width (in): 13
Total weight of ice on object: 25 lbs
Weight of object: 20 lbs
Combined weight of ice and object: 45 lbs

3.5x3.5x0.3125 Angle


Weight of ice based on total radial SF area:
Depth (in): 0.3125
height (in): 12
Width (in): 7
Per foot weight of ice on object: 6 plf






Loads

Concentrated - Members




Loads

Concentrated - Members






Loads


- Global distributed - Members
- Local distributed - Members
- Concentrated - Members



Design status

-  Not designed
-  Error on design
-  Design O.K.
-  With warnings





Steel Code Check

Report: Summary - For all selected load conditions


Load conditions to be included in design :

- LC1=1.2DL+1.6W
- LC2=0.9DL+1.6W
- LC3=1.2DL+W+I
- LC4=1.2DL
- LC5=0.9DL

| Description | Section | Member | Ctrl Eq. | Ratio | Status | Reference |
|-----------------------|---------------------------|--------|----------------|-------------|-----------|-----------|
| | <i>L 3-1_2X3-1_2X5_16</i> | 1 | LC1 at 21.25% | 0.36 | OK | Eq. H1-1b |
| | | | LC2 at 21.25% | 0.37 | OK | Eq. H1-1b |
| | | | LC3 at 80.00% | 0.23 | OK | Eq. H1-1b |
| | | | LC4 at 80.00% | 0.10 | OK | Eq. H1-1b |
| | | | LC5 at 80.00% | 0.08 | OK | Eq. H1-1b |
| | | 2 | LC1 at 20.00% | 0.37 | OK | Eq. H1-1b |
| | | | LC2 at 20.00% | 0.35 | OK | Eq. H1-1b |
| | | | LC3 at 20.00% | 0.35 | OK | Eq. H1-1b |
| | | | LC4 at 80.00% | 0.10 | OK | Eq. H1-1b |
| | | | LC5 at 80.00% | 0.07 | OK | Eq. H1-1b |
| <i>P1000 Unistrut</i> | | 9 | LC1 at 37.50% | 0.13 | OK | Eq. H1-1b |
| | | | LC2 at 37.50% | 0.13 | OK | Eq. H1-1b |
| | | | LC3 at 37.50% | 0.09 | OK | Eq. H1-1b |
| | | | LC4 at 100.00% | 0.02 | OK | Eq. H1-1b |
| | | | LC5 at 100.00% | 0.01 | OK | Eq. H1-1b |
| | | 10 | LC1 at 37.50% | 0.13 | OK | Eq. H1-1b |
| | | | LC2 at 37.50% | 0.13 | OK | Eq. H1-1b |
| | | | LC3 at 37.50% | 0.08 | OK | Eq. H1-1b |
| | | | LC4 at 100.00% | 0.01 | OK | Eq. H1-1b |
| | | | LC5 at 100.00% | 0.01 | OK | Eq. H1-1b |
| <i>PIPE 2x0.154</i> | | 7 | LC1 at 50.00% | 0.32 | OK | Eq. H1-1b |
| | | | LC2 at 50.00% | 0.32 | OK | Eq. H1-1b |
| | | | LC3 at 68.75% | 0.29 | OK | Eq. H1-1b |
| | | | LC4 at 29.17% | 0.12 | OK | Eq. H1-1b |
| | | | LC5 at 29.17% | 0.09 | OK | Eq. H1-1b |
| | | 8 | LC1 at 50.00% | 0.27 | OK | Eq. H1-1b |
| | | | LC2 at 50.00% | 0.27 | OK | Eq. H1-1b |
| | | | LC3 at 68.75% | 0.29 | OK | Eq. H1-1b |
| | | | LC4 at 29.17% | 0.12 | OK | Eq. H1-1b |
| | | | LC5 at 29.17% | 0.09 | OK | Eq. H1-1b |

Analysis result

Reactions




Direction of positive forces and moments

| Node | Forces [Kip] | | | Moments [Kip*ft] | | |
|---------------------------------|--------------|----------|----------|------------------|---------|---------|
| | FX | FY | FZ | MX | MY | MZ |
| Condition LC1=1.2DL+1.6W | | | | | | |
| 1 | -0.14232 | 0.02430 | 0.35193 | 0.00000 | 0.00000 | 0.00000 |
| 2 | 0.14231 | 0.05886 | 0.32074 | 0.00000 | 0.00000 | 0.00000 |
| 5 | 0.14232 | 0.26178 | 0.38740 | 0.00000 | 0.00000 | 0.00000 |
| 6 | -0.14231 | 0.26151 | 0.36073 | 0.00000 | 0.00000 | 0.00000 |
| SUM | 0.00000 | 0.60644 | 1.42080 | 0.00000 | 0.00000 | 0.00000 |
| Condition LC2=0.9DL+1.6W | | | | | | |
| 1 | -0.12701 | -0.01227 | 0.35511 | 0.00000 | 0.00000 | 0.00000 |
| 2 | 0.12735 | 0.01788 | 0.32451 | 0.00000 | 0.00000 | 0.00000 |
| 5 | 0.12701 | 0.22669 | 0.38422 | 0.00000 | 0.00000 | 0.00000 |
| 6 | -0.12735 | 0.22254 | 0.35696 | 0.00000 | 0.00000 | 0.00000 |
| SUM | 0.00000 | 0.45483 | 1.42080 | 0.00000 | 0.00000 | 0.00000 |
| Condition LC3=1.2DL+W+I | | | | | | |
| 1 | -0.16192 | 0.20511 | 0.20167 | 0.00000 | 0.00000 | 0.00000 |
| 2 | 0.16165 | 0.23003 | 0.18173 | 0.00000 | 0.00000 | 0.00000 |
| 5 | 0.16192 | 0.34378 | 0.26042 | 0.00000 | 0.00000 | 0.00000 |
| 6 | -0.16165 | 0.34652 | 0.24419 | 0.00000 | 0.00000 | 0.00000 |
| SUM | 0.00000 | 1.12544 | 0.88800 | 0.00000 | 0.00000 | 0.00000 |
| Condition LC4=1.2DL | | | | | | |
| 1 | -0.06124 | 0.14628 | -0.01272 | 0.00000 | 0.00000 | 0.00000 |
| 2 | 0.05984 | 0.16392 | -0.01508 | 0.00000 | 0.00000 | 0.00000 |
| 5 | 0.06124 | 0.14037 | 0.01272 | 0.00000 | 0.00000 | 0.00000 |
| 6 | -0.05984 | 0.15587 | 0.01508 | 0.00000 | 0.00000 | 0.00000 |
| SUM | 0.00000 | 0.60644 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |

Condition LC5=0.9DL

| | | | | | | |
|-------|----------|---------|----------|---------|---------|---------|
| 1 | -0.04593 | 0.10971 | -0.00954 | 0.00000 | 0.00000 | 0.00000 |
| 2 | 0.04488 | 0.12294 | -0.01131 | 0.00000 | 0.00000 | 0.00000 |
| 5 | 0.04593 | 0.10528 | 0.00954 | 0.00000 | 0.00000 | 0.00000 |
| 6 | -0.04488 | 0.11690 | 0.01131 | 0.00000 | 0.00000 | 0.00000 |
| <hr/> | | | | | | |
| SUM | 0.00000 | 0.45483 | 0.00000 | 0.00000 | 0.00000 | 0.00000 |



Site Name: Portland USM

Site No. ME5045

Done by: GH

Checked by: MSC

Date: 3/2/2016



CHECK CONNECTION CAPACITY (BETA & GAMMA)

Reference: Original CD's by Aerial Spectrum

Epoxy Type = HIT-HY20
Anchor Diameter = 1/2 in.
Min. Embedment Depth = 2 in.

Allowable Tensile Load =

$F_{Tall} = 525 \text{ lbs.}$

Allowable Shear Load =

$F_{Vall} = 1230 \text{ lbs.}$

TENSILE FORCES

Reaction $F = 387 \text{ lbs.}$
(See Ram Output)

SHEAR FORCES

Reaction 347 lbs.

No. of Supports = 4

No. of Anchors / Support = 2

Tension Design Load / Anchor =

$f_t = 193.50 \text{ lbs.} < 525 \text{ lbs.}$ Therefore, OK !

Shear Design Load / Anchor =


$f_v = 173.50 \text{ lbs.} < 1230 \text{ lbs.}$ Therefore, OK !

CHECK COMBINED TENSION AND SHEAR

$f_t / F_T + f_v / F_v \leq 1.0$
0.369 + 0.141 = 0.510 < 1.0 Therefore, OK !

Referenced Documents

SECTION
SCALE 1/4" = 1'-0"



ROOF FRAMING PLAN
SCALE 1/8" = 1'-0"
DESIGN NO. 40 P.S.P.
150 P.S.P. INSIDE MECH. EQUIP. RM.
ROOF ELEV. 150'-00"

NOTE: REINFORCING BARS TO BE PLACED AT 12" ON CENTER.
SEE DRAWING FOR REINFORCING BARS.
USE A MINIMUM OF 3 BARS PER COLUMN.
SEE DRAWING FOR CONNECTIONS.

ROOF FRAMING
SCALE 1/4" = 1'-0"



MACHINE ROOM FRAMING
SCALE 1/4" = 1'-0"



SERVICE ELEVATOR
SCALE 1/4" = 1'-0"




REINFORCING BARS TO BE PLACED AT 12" ON CENTER.
SEE DRAWING FOR REINFORCING BARS.
USE A MINIMUM OF 3 BARS PER COLUMN.
SEE DRAWING FOR CONNECTIONS.

MECH. EQUIP. ROOM
SCALE 1/4" = 1'-0"



REINFORCING BARS TO BE PLACED AT 12" ON CENTER.
SEE DRAWING FOR REINFORCING BARS.
USE A MINIMUM OF 3 BARS PER COLUMN.
SEE DRAWING FOR CONNECTIONS.



5th THRU 7th FLOOR FRAMING PLAN
SCALE 1/8" = 1'-0"
DESIGN NO. 40 P.S.P.
PARTITIONS 20 P.S.P.
FIN. CORE FLOOR ELEV. 108'-00"
FIN. CORE FLOOR ELEV. 108'-00"
FIN. CORE FLOOR ELEV. 112'-00"
FIN. CORE FLOOR ELEV. 112'-00"
FIN. CORE FLOOR ELEV. 112'-00"
FIN. CORE FLOOR ELEV. 112'-00"

NOTE: REINFORCING BARS TO BE PLACED AT 12" ON CENTER.
SEE DRAWING FOR REINFORCING BARS.
USE A MINIMUM OF 3 BARS PER COLUMN.
SEE DRAWING FOR CONNECTIONS.



MECH. EQUIP. ROOM
SCALE 1/4" = 1'-0"



ROOF FRAMING
SCALE 1/4" = 1'-0"




MACHINE ROOM FRAMING
SCALE 1/4" = 1'-0"




PASSENGER ELEVATOR
SCALE 1/4" = 1'-0"



SECTION
NO SCALE



NOTE: REINFORCING BARS TO BE PLACED AT 12" ON CENTER.
SEE DRAWING FOR REINFORCING BARS.
USE A MINIMUM OF 3 BARS PER COLUMN.
SEE DRAWING FOR CONNECTIONS.



CROSS SECTION ON C-A LINE TOWARDS WEST


CROSS SECTION ON B-D LINE TOWARDS SOUTH

AS-BUILT DRAWING

STATE OF MAINE


REVISIONS

| NO. | DATE | REVISION |
|-----|------|----------|
| 1 | | |
| 2 | | |
| 3 | | |
| 4 | | |
| 5 | | |
| 6 | | |
| 7 | | |
| 8 | | |
| 9 | | |
| 10 | | |
| 11 | | |
| 12 | | |
| 13 | | |
| 14 | | |
| 15 | | |
| 16 | | |
| 17 | | |
| 18 | | |
| 19 | | |
| 20 | | |
| 21 | | |
| 22 | | |
| 23 | | |
| 24 | | |
| 25 | | |
| 26 | | |
| 27 | | |
| 28 | | |
| 29 | | |
| 30 | | |
| 31 | | |
| 32 | | |
| 33 | | |
| 34 | | |
| 35 | | |
| 36 | | |
| 37 | | |
| 38 | | |
| 39 | | |
| 40 | | |
| 41 | | |
| 42 | | |
| 43 | | |
| 44 | | |
| 45 | | |
| 46 | | |
| 47 | | |
| 48 | | |
| 49 | | |
| 50 | | |




NOTES:
 1. PRIME AND PAINT ALL MOUNTING BRACKETS AND ANCHORS WHICH (C) BUILDING FACADE W/O/ROUT LINES.

FAÇADE ANTENNA MOUNTING DETAIL
 SCALE: N.T.S.




NOTES:
 1. PRIME AND PAINT ALL MOUNTING BRACKETS AND ANCHORS WHICH (C) BUILDING FACADE W/O/ROUT LINES.

ANTENNA MOUNTING DETAILS
 SCALE: N.T.S.



TMA NOTE:
 THE NUMBER OF TMA'S PER ANTENNA MUST BE AS PER REQUIREMENTS CONTRACTOR TO VERIFY PRIOR TO CONSTRUCTION


ANTENNA DETAIL
 SCALE: N.T.S.



NOTES:
 1. CUT AND BEAD ANGLE FLUSH WITH PARAPET WINK. (TYP. OF 2 PER ANGLE).

ANTENNA MOUNTING DETAILS
 SCALE: N.T.S.

ANGLE MOUNTING DETAIL
 SCALE: N.T.S.



| | | | | | | | | |
|--|--|---|--|---|---------------------------------------|---------------------------------------|---|---|
| One General Way PO Box 373 Reading, MA 01880 Tel: (781) 942 0024 Fax: (781) 942 0551 e-mail: eamson@erialspectrum.com | MES045 USM PORTLAND DEERING AVENUE PORTLAND, ME 03082 | CONSTRUCTION DEPARTMENT BOSTON, MA 02140 PHONE: (781) 666-7422 FAX: (781) 666-7424 | | REVISIONS NO. DATE BY (DW, JPP) | AS SHOWN SECOND: PRC EN DRAWN: PRC | PROJECT: _____ DRAWING: _____ | CIRCULAR WIRELESS CONSTRUCTION DETAILS | SHEET NUMBER: C-4 OF: D |
| | | | | T D (M-25-05) FOR COMMENT PRC PJA EN T C (M-13-05) FOR COMMENT PRC PJA EN T B (M-14-05) FOR COMMENT PRC PJA EN T A (1-0-05) FOR COMMENT PRC PJA EN | REVISIONS NO. DATE BY (DW, JPP) | AS SHOWN SECOND: PRC EN DRAWN: PRC | PROJECT: _____ DRAWING: _____ | CIRCULAR WIRELESS CONSTRUCTION DETAILS |