

DISPLAY THIS CARD ON PRINCIPAL FRONTAGE OF WORK



# CITY OF PORTLAND BUILDING PERMIT



**This is to certify that**

UNIVERSITY OF MAINE /no contractor / self

**Located at**

39 EXETER ST

**PERMIT ID:** 2013-01806

**ISSUE DATE:** 10/02/2013

**CBL:** 051 E019001

has permission to **Add exterior ramp and modify width of 3 doors.**

provided that the person or persons, firm or corporation accepting this permit shall comply with all of the provisions of the Statues of Maine and of the Ordinances of the City of Portland regulating the construction, maintenance and use of the buildings and structures, and of the application on file in the department.

Notification of inspection and written permission procured before this building or part thereof is lathed or otherwise clsoed-in. 48 HOUR NOTICE IS REQUIRED.	A final inspection must be completed by owner before this building or part thereof is occupied. If a certificate of occupancy is required, it must be procured prior to occupancy.
---	--

/s/ Chris Pirone

/s/ Jeanie Bourke

**Fire Official**

**Building Official**

**THIS CARD MUST BE POSTED ON THE STREET SIDE OF THE PROPERTY  
THERE IS A PENALTY FOR REMOVING THIS CARD**

***Approved Property Use - Zoning***

University of Southern Maine (under the USM overlay zone)

***Building Inspections***

**Use Group:** B

Business

ENTIRE

MUBEC/IBC 2009

**Type:** 5B

***Fire Department***

**Classification:**

Business

ENTIRE

2009 NFPA

BUILDING PERMIT INSPECTION PROCEDURES  
Please call 874-8703 (ONLY)  
or email: [buildinginspections@portlandmaine.gov](mailto:buildinginspections@portlandmaine.gov)

**Check the Status or Schedule an Inspection On-Line at  
<http://www.portlandmaine.gov/planning/permitstatus.asp>**

With the issuance of this permit, the owner, builder or their designee is required to provide adequate notice to the city of Portland Inspections Services for the following inspections. Appointments must be requested 48 to 72 hours in advance of the required inspection. The inspection date will need to be confirmed by this office.

- **Please read the conditions of approval that is attached to this permit!! Contact this office if you have any questions.**
- **Permits expire in 6 months. If the project is not started or ceases for 6 months.**
- **If the inspection requirements are not followed as stated below additional fees may be incurred due to the issuance of a "Stop Work Order" and subsequent release to continue.**
- **Per Section 107.3.1 of the Maine Uniform Building and Energy Code (MUBEC). One set of printed approved stamped construction documents shall be kept at the site of work and shall be open to inspection by building officials.**

## **REQUIRED INSPECTIONS:**

Footings/Setbacks

Framing Only

Final - Commercial

Final - Fire

The project cannot move to the next phase prior to the required inspection and approval to continue, REGARDLESS OF THE NOTICE OF CIRCUMSTANCES.

IF THE PERMIT REQUIRES A CERTIFICATE OF OCCUPANCY, IT MUST BE PAID FOR AND ISSUED TO THE OWNER OR DESIGNEE BEFORE THE SPACE MAY BE OCCUPIED.

<b>City of Portland, Maine - Building or Use Permit</b>		<b>Permit No:</b> 2013-01806	<b>Date Applied For:</b> 08/14/2013	<b>CBL:</b> 051 E019001
389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716				
<b>Proposed Use:</b> Same: University of Southern Maine	<b>Proposed Project Description:</b> Add exterior ramp and modify width of 3 doors.			
<hr/>				
<b>Dept:</b> Zoning	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Marge Schmuckal	<b>Approval Date:</b> 08/22/2013	
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>			
<b>Conditions:</b>				
1) This work requires a site plan review (probably an Administrative Authorization) thru the Planning Division.				
2) All required setbacks are to property lines. 8' minimum required where 15' shown on recently submitted plans.				
<hr/>				
<b>Dept:</b> Building	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Jeanie Bourke	<b>Approval Date:</b> 09/13/2013	
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>			
<b>Conditions:</b>				
1) Separate permits are required for any electrical, plumbing, sprinkler, fire alarm, HVAC systems, heating appliances, including pellet/wood stoves, commercial hood exhaust systems and fuel tanks. Separate plans may need to be submitted for approval as a part of this process.				
2) Permit approved based upon information provided by the applicant or design professional. Any deviation from the final approved plans requires separate review and approval prior to work.				
<hr/>				
<b>Dept:</b> Fire	<b>Status:</b> Approved w/Conditions	<b>Reviewer:</b> Chris Pirone	<b>Approval Date:</b> 08/28/2013	
<b>Note:</b>	<b>Ok to Issue:</b> <input checked="" type="checkbox"/>			
<b>Conditions:</b>				
1) Street addresses shall be marked on the structure.				
2) All construction shall comply with City Code Chapter 10.				
3) Shall comply with 2009 NFPA 101 Chapter 39 Existing Business Occupancy				