



LEGEND:

RISER DIAG SYM	CONTRACT DWG SYM	NFPA SYMBOL*	DESCRIPTION	CATALOG #
FACP	FACP	FACP	Fire Alarm Control Panel (Existing)	EST 10500RD
BPS		FACU	Addressable Manual Pull Station	SIGA-278
F	F	P	Addressable Relay Control Module	SIGA-CR
?	S	?	Addressable Smoke Detector w/ Base	SIGA2-PS / SIGA-SB
↓	H	↓	Addressable Heat Detector w/ Base	SIGA2-HFS / SIGA-SB
?	?	?	Addressable Duct Smoke Detector w/ Sampling Tube	SIGA2-SD
RTS	RTS	RTS	Remote Test and Indicating Station	SD-TRK
CT1		AM	RemAddressable Single Input Module	SIGA-CT1
CC1S	CC1S	ACM	Addressable Synchronization Module	SIGA-CC1S
CR	CR	ACM	Addressable Relay Control Module	SIGA-CR
DH	DH		Door Holdback	FBO
PR1		R	Intermediate Auxiliary Relay	System Sensor
#	H	#	Horn/Strobe Unit - Red Wall Mount (# Indicates Candela)	G1RF-HDVM
#	V	#	Strobe Only Unit - Red Wall Mount (# Indicates Candela)	G1RF-VM
AES			Subscriber Unit Radio Box w/ Accessories	AES

* NFPA 70 (2009)
Tables: 6.5, 6.7.1, 6.7.2, & 6.7.3

**Fire Alarm System
First Floor Plan**

32"
16" Scale

DWG NAME:
**The IRIS Network
189 Park Avenue
Portland, Maine
1st Flr Fire Alarm Floor Plan**
DWG No: 86537.FA-101

JOB NAME:
**The IRIS Network
189 Park Avenue
Portland, Maine
First Floor Fire Alarm Floor Plan**
Contractor: **Don's Electric**

REV.	DESCRIPTION	DATE	DRWN:	IRW'D:
0	Original Issue	12/14		