


City of Portland, Maine - Building or Use Permit Application

389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0034	Issue Date: JAN 17 2006	CBL: 7052-C004001
-----------------------	----------------------------	----------------------



Location of Construction: 189 PARK AVE	Owner Name: HAMILTON REALTY LLC	Owner Address: 205 PARK AVE	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	Phone: 2078839515
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	Zone:

Past Use: Commercial/ Hamilton's Service Station	Proposed Use: Hamilton's Service Station/ replace 275 Gallon oil tank in basement	Permit Fee: \$39.00	Cost of Work: \$1,500.00	CEO District: 1
		FIRE DEPT: <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied TO NFPA 31	INSPECTION: Use Group: Type: Tank IMC 2003	

Proposed Project Description: replace 275 Gallon oil tank in basement	Signature: Greg Cross	Signature:
PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)		
Action: <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied		
Signature:	Date:	

Idobson | 01/05/2006

- This permit application does not preclude the Applicant(s) from meeting applicable State and Federal Rules.
- Building permits do not include plumbing, septic or electrical work.
- Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work.

Special Zone or Reviews	Zoning Appeal	Historic Preservation
<input type="checkbox"/> Shoreland <input type="checkbox"/> Wetland <input type="checkbox"/> Flood Zone <input type="checkbox"/> Subdivision <input type="checkbox"/> Site Plan Maj <input type="checkbox"/> Minor <input type="checkbox"/> MM <input type="checkbox"/> Date: 01/13/06	<input type="checkbox"/> Variance <input type="checkbox"/> Miscellaneous <input type="checkbox"/> Conditional Use <input type="checkbox"/> Interpretation <input type="checkbox"/> Approved <input type="checkbox"/> Denied Date:	<input checked="" type="checkbox"/> Not in District or Landmark <input type="checkbox"/> Does Not Require Review <input type="checkbox"/> Requires Review <input type="checkbox"/> Approved <input type="checkbox"/> Approved w/Conditions <input type="checkbox"/> Denied Date: 01/13/06

CERTIFICATION

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provision of the code(s) applicable to such permit,

SIGNATURE OF APPLICANT	ADDRESS	DATE	PHONE
RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE		DATE	PHONE



FILL IN AND SIGN WITH INK

APPLICATION FOR PERMIT HEATING OR POWER EQUIPMENT

PERMIT ISSUED
 JAN 17 2006
 CITY OF PORTLAND

To the INSPECTOR OF BUILDINGS, PORTLAND, Me.

The undersigned hereby applies for a permit to install the following heating, cooking or power equipment in accordance with the Laws of Maine, the Building Code of the City of Portland, and the following specifications:

Location / CBL 205 Park Ave S2 C 4 Use of Building commercial Date 1-4-06
 Name and address of owner of appliance Hamilton's Service Station
 Installer's name and address Dead River Co. 73 Pleasant Hill Rd - Scarborough, ME 04074
 Telephone 207-883-9515

Location of appliance:

- Basement
- Attic
- Floor
- Roof

Type of Fuel:

- Gas
- Oil
- Solid

Appliance Name: _____

U.L. Approved Yes No

Will appliance be installed in accordance with the manufacture's installation instructions? Yes No

IF NO Explain: _____

The Type of License of Installer:

- Master Plumber # _____
- Solid Fuel # _____
- Oil # MS20008108

Type of Chimney:

- Masonry Lined
Factory built _____
- Metal
Factory Built U.L. Listing # _____
- Direct Vent
Type _____

Type of Fuel Tank

- Oil
- Gas

Size of Tank 275 (replacement)

Number of Tanks 1

Distance from Tank to Center of Flame 5' min feet.

Cost of Work: \$ 1500.00

Permit Fee: \$ 39.00

RECEIVED
 JAN - 5 - 2006
 DEPT. OF BUILDING INSPECTION
 CITY OF PORTLAND, ME

Approved

Approved with Conditions

- See attached letter or requirement

Fire: _____

Ele.: _____

Bldg.: _____

Inspector's Signature _____

Date Approved _____

Signature of Installer

Dead River Co by Jayme Lavigne

White - Inspection Yellow - File Pink - Applicant's Gold - Assessor's Copy

City of Portland, Maine - Building or Use Permit


389 Congress Street, 04101 Tel: (207) 874-8703, Fax: (207) 874-8716

Permit No: 06-0034	Date Applied For: 01/05/2006	CBL: 052 C004001
-----------------------	---------------------------------	---------------------


Location of Construction: 189 PARK AVE	Owner Name: HAMILTON REALTY LLC	Owner Address: 205 PARK AVE	Phone:
Business Name:	Contractor Name: Dead River Company	Contractor Address: PO Box 467 Scarborough	Phone (207) 883-9515
Lessee/Buyer's Name	Phone:	Permit Type: Tanks - Commercial	

Proposed Use: Hamilton's Service Station/ replace 275 Gallon oil tank in basement	Proposed Project Description: replace 275 Gallon oil tank in basement
--	--

Dept: Zoning	Status: Approved	Reviewer: Tammy Munson	Approval Date: 01/13/2006
Note:			Ok to Issue: <input checked="" type="checkbox"/>
Dept: Building	Status: Approved with Conditions	Reviewer: Tammy Munson	Approval Date: 01/13/2006
Note:			Ok to Issue: <input checked="" type="checkbox"/>
1) Installation shall comply with 2003 International Mechanical Code and State of Maine Oil and Solid Fuel Board Laws and Rules			




Limited Partnership



UL 80

Domestic Oil Tanks


#PRODUIT	MODELS	DIMENSIONS			GAUGE	WEIGHT
		H	W	L		
2090	120 us gals vertical	47"	23"	30"	12 ga	165 lb
2095	120 us gals horizontal	23"	47"	30"	12 ga	165 lb
2080	138 us gals vertical	44"	27"	30"	12 ga	175 lb
2085	138 us gals horizontal	27"	44"	30"	12 ga	175 lb
2070	220 us gals vert./stubbies	44"	27"	48"	12 ga	240 lb
2075	220 us gals horizontal	27"	44"	48"	12 ga	240 lb
2020	240 us gals narrow/vert.	47"	23"	60"	12 ga	260 lb
2025	240 us gals narrow/horiz.	23"	47"	60"	12 ga	260 lb
2040	275 us gals vertical	44"	27"	60"	12 ga	280 lb
2045	275 us gals horizontal	27"	44"	60"	12 ga	280 lb
2050	330 us gals vertical	44"	27"	72"	12 ga	320 lb
2055	330 us gals horizontal	27"	44"	72"	12 ga	320 lb



TECHNICAL SPECIFICATIONS

- Steel ASTM A-569
- Female openings NPT
- Tested at pressure 5 to 7 PSIG
- UL 80 label
- Operation at atmospheric pressure only
- Also available UL 142 labeled on 275 & 330 gals (including a 3" diameter emergency vent opening). Other models on request only.

2'0" 2'0" 2'0" 2'0"
12" 12" 12" 12"



Installation and maintenance guidelines for aboveground domestic fuel oil tanks. (PDF)

OUTSIDE FINISH

- Preparation: **Washed and phosphated**
- Electrostatic powder paint "black or gray".

GENERAL CHARACTERISTICS

- Always a tough tank
- Welded lap joint: the strongest one
- Ergonomic handle on each head for easy handling

NEW PRODUCTS:

- 275 gals. UL 80 labelled 10 gauge shell &

IN REFERENCE TO: UL LISTING

UL Listing: Requires outlet opening of 1/2" minir to be located underneath the tank only. Requires openings to be 2" minimum diameter. Tanks which not meet above requirements cannot be UL 80 la

NOTICE: N.F.P.A. Codes, UL and Granby Steel Tanks require t these tanks be tested at job site before being put in service. To te tank, apply internal air pressure of not less than 3 PSIG or more t PSIG and soap all seams and welded areas. **Warning:** Over pressurization may cause tank to fail.

