

**City of Portland, Maine – Building or Use Permit Application** 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 339 Park Avenue (parking lot)		Owner: City of Portland Dept. of Public Works		Phone: 874-8703		Permit No. <b>9 062 2</b>	
Owner Address: 389 Congress St.		Lessee/Buyer's Name:		Phone:		Business Name:	
Contractor Name:		Address:		Phone:		Permit Issued: <b>PERMIT ISSUED</b> JUN 15 1999	
Past Use: municipal bldg.		Proposed Use: none		COST OF WORK: \$		PERMIT FEE: \$ 35.00	
				FIRE DEPT. <input checked="" type="checkbox"/> Approved <input type="checkbox"/> Denied		INSPECTION: Use Group: ( ) Type:	
				Signature: [Signature]		Signature:	
Proposed Project Description: erect a 40 x 60 tent for Ideas event on 6/15/99				PEDESTRIAN ACTIVITIES DISTRICT (P.A.D.)			
				Action: Approved <input type="checkbox"/> Approved with Conditions: <input type="checkbox"/> Denied <input type="checkbox"/>			
				Signature: Date:			
Permit Taken By: [Signature]		Date Applied For: 6/11/99					

1. This permit application does not preclude the Applicant(s) from meeting applicable State and Federal rules.
2. Building permits do not include plumbing, septic or electrical work.
3. Building permits are void if work is not started within six (6) months of the date of issuance. False information may invalidate a building permit and stop all work..

PERMIT ISSUED  
WITH REQUIREMENTS

**CERTIFICATION**

I hereby certify that I am the owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his authorized agent and I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in the application is issued, I certify that the code official's authorized representative shall have the authority to enter all areas covered by such permit at any reasonable hour to enforce the provisions of the code(s) applicable to such permit

SIGNATURE OF APPLICANT ADDRESS: DATE: PHONE:

RESPONSIBLE PERSON IN CHARGE OF WORK, TITLE PHONE:

**Zoning Appeal**

☐ Variance  
☐ Miscellaneous  
☐ Conditional Use  
☐ Interpretation  
☐ Approved  
☐ Denied

**Historic Preservation**


☒ Not in District or Landmark  
☐ Does Not Require Review  
☐ Requires Review

**Action:**

☐ Approved  
☐ Approved with Conditions  
☐ Denied

Date: \_\_\_\_\_

CEO DISTRICT



# BUILDING PERMIT REPORT

DATE: 12/June/99 ADDRESS: 239 Park Ave. CBL: \_\_\_\_\_  
REASON FOR PERMIT: Tent (Temp)  
BUILDING OWNER: City of Portland  
PERMIT APPLICANT: \_\_\_\_\_ /Contractor Owner  
USE GROUP U. BOCA 1996 CONSTRUCTION TYPE \_\_\_\_\_


## CONDITION(S) OF APPROVAL

This permit is being issued with the understanding that the following conditions are met:

Approved with the following conditions: \*1/

- ✓ 1. This permit does not excuse the applicant from meeting applicable State and Federal rules and laws.
2. Before concrete for foundation is placed, approvals from the Development Review Coordinator and Inspection Services must be obtained. (A 24 hour notice is required prior to inspection)
3. Foundation drain shall be placed around the perimeter of a foundation that consists of gravel or crushed stone containing not more than 10 percent material that passes through a No. 4 sieve. The drain shall extend a minimum of 12 inches beyond the outside edge of the footing. The thickness shall be such that the bottom of the drain is not higher than the bottom of the base under the floor, and that the top of the drain is not less than 6 inches above the top of the footing. The top of the drain shall be covered with an approved filter membrane material. Where a drain tile or perforated pipe is used, the invert of the pipe or tile shall not be higher than the floor elevation. The top of joints or top of perforations shall be protected with an approved filter membrane material. The pipe or tile shall be placed on not less than 2" of gravel or crushed stone, and shall be covered with not less than 6" of the same material. Section 1813.5.2
4. Foundations anchors shall be a minimum of 1/2" in diameter, 7" into the foundation wall, minimum of 12" from corners of foundation and a maximum 6' o.c. between bolts. (Section 2305.17)
5. Waterproofing and damp proofing shall be done in accordance with Section 1813.0 of the building code.
6. Precaution must be taken to protect concrete from freezing. Section 1908.0
7. It is strongly recommended that a registered land surveyor check all foundation forms before concrete is placed. This is done to verify that the proper setbacks are maintained.
8. Private garages located beneath habitable rooms in occupancies in Use Group R-1, R-2, R-3 or I-1 shall be separated from adjacent interior spaces by fire partitions and floor/ceiling assembly which are constructed with not less than 1-hour fire resisting rating. Private garages attached side-by-side to rooms in the above occupancies shall be completely separated from the interior spaces and the attic area by means of 1/2 inch gypsum board or the equivalent applied to the garage means of 1/2 inch gypsum board or the equivalent applied to the garage side. (Chapter 4, Section 407.0 of the BOCA/1996)
9. All chimneys and vents shall be installed and maintained as per Chapter 12 of the City's Mechanical Code. (The BOCA National Mechanical Code/1993). Chapter 12 & NFPA 211
10. Sound transmission control in residential building shall be done in accordance with Chapter 12, Section 1214.0 of the City's Building Code.
11. Guardrails & Handrails: A guardrail system is a system of building components located near the open sides of elevated walking surfaces for the purpose of minimizing the possibility of an accidental fall from the walking surface to the lower level. Minimum height all Use Groups 42", except Use Group R which is 36". In occupancies in Use Group A, B, H-4, I-1, I-2, M and R and public garages and open parking structures, open guards shall have balusters or be of solid material such that a sphere with a diameter of 4" cannot pass through any opening. Guards shall not have an ornamental pattern that would provide a ladder effect. (Handrails shall be a minimum of 3e4" but not more than 38". Use Group R-3 shall not be less than 30", but not more than 38".) Handrail grip size shall have a circular cross section with an outside diameter of at least 1 1/4" and not greater than 2". (Sections 1021 & 1022.0) - Handrails shall be on both sides of stairway. (Section 1014.7)
12. Headroom in habitable space is a minimum of 7'6". (Section 1204.0)
13. Stair construction in Use Group R-3 & R-4 is a minimum of 10" tread and 7 3/4" maximum rise. All other Use Group minimum 11" tread, 7" maximum rise. (Section 1014.0)
14. The minimum headroom in all parts of a stairway shall not be less than 80 inches. (6'8") 1014.4
15. Every sleeping room below the fourth story in buildings of Use Groups R and I-1 shall have at least one operable window or exterior door approved for emergency egress or rescue. The units must be operable from the inside without the use of special knowledge or separate tools. Where windows are provided as means of egress or rescue they shall have a sill height not more than 44 inches (1118mm) above the floor. All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)
16. Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. (Section 1010.1)
17. All vertical openings shall be enclosed with construction having a fire rating of at least one (1) hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) (Section 710.0)

18. The boiler shall be protected by enclosing with (1)hour fire rated construction including fire doors and ceiling, or by providing automatic extinguishment. (Table 302.1.1)
19. All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9, Section 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
- In the immediate vicinity of bedrooms
  - In all bedrooms
  - In each story within a dwelling unit, including basements
- In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2.
20. A portable fire extinguisher shall be located as per NFPA #10. They shall bear the label of an approved agency and be of an approved type. (Section 921.0)
21. The Fire Alarm System shall maintained to NFPA #72 Standard.
22. The Sprinkler System shall maintained to NFPA #13 Standard.
23. All exit signs, lights and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023.0 & 1024.0 of the City's Building Code. (The BOCA National Building Code/1996)
24. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
25. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification the Division of Inspection Services.
26. Ventilation shall meet the requirements of Chapter 12 Sections 1210.0 of the City's Building Code. (Crawl spaces & attics).
27. All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade. **No closing in of walls until all electrical (min. 72 hours notice) and plumbing inspections have been done.**
28. All requirements must be met before a final Certificate of Occupancy is issued.
29. All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code (the BOCA National Building Code/1996).
30. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)
31. Please read and implement the attached Land Use Zoning report requirements.
32. Boring, cutting and notching shall be done in accordance with Sections 2305.4.4, 2305.5.1 and 2305.5.3 of the City's Building Code.
33. Glass and glazing shall meet the requirements of Chapter 24 of the building code.
- ✓ 34. All Test requirements in Section 3104.0 shall be adhered too. (The BOCA National Building Code 1996).
35. \_\_\_\_\_
36. \_\_\_\_\_

 P. Samuels, Building Inspector  
cc: Lt. McDougall, PFD  
Marge Schmuckal, Zoning Administrator

PSH 12-14-98 

**\*\*On the basis of plans submitted and conditions placed on these plans any deviations shall require a separate approval.**

**THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE  
PERMIT IS ISSUED**

**Building or Use Permit Pre-Application  
Additions/Alterations/Accessory Structures  
To Detached Single Family Dwelling**

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

**NOTE\*\*If you or the property owner owes real estate or personal property taxes or user charges on any property within the City, payment arrangements must be made before permits of any kind are accepted.**

Location/Address of Construction: *Portland Expo - 239 Park Ave, Portland ME*

Tax Assessor's Chart, Block & Lot Number Chart# <i>052</i> Block# <i>C</i> Lot# <i>005</i>		Owner: <i>City of Portland</i>	Telephone#: <i>874-8200 x227</i>
Owner's Address: <i>Portland Expo</i>		Lessee/Buyer's Name (If Applicable)	Cost Of Work: <i>\$35.00</i>
Proposed Project Description: (Please be as specific as possible) <i>40 x 80 tent for Idexx Event June 18, 1999</i>			
Contractor's Name, Address & Telephone <i>Party Plus (Taylor Rental)</i>		Rec'd By: <i>DM</i>	

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

- All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II.
- All plumbing must be conducted in compliance with the State of Maine Plumbing Code.
- All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.
- HVAC (Heating, Ventilation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code.

You must Include the following with you application:

- 1) A Copy of Your Deed or Purchase and Sale Agreement
- 2) A Copy of your Construction Contract, if available
- 3) A Plot Plan (Sample Attached)

If there is expansion to the structure, a complete plot plan (Site Plan) must include:

- The shape and dimension of the lot, all existing buildings (if any), the proposed structure and the distance from the actual property lines. Structures include decks porches, a bow windows cantilever sections and roof overhangs, as well as, sheds, pools, garages and any other accessory structures.
- Scale and required zoning district setbacks

**4) Building Plans (Sample Attached)**

A complete set of construction drawings showing all of the following elements of construction:

- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas equipment. HVAC equipment (air handling) or other types of work that may require special review must be included.

**Certification**

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant: <i>Jean Robinson</i>	Date: <i>6/11/99</i>
--	----------------------

Building Permit Fee: \$25.00 for the 1st \$1000.00 cost plus \$5.00 per \$1,000.00 construction cost thereafter.  
O:\INSP\CORRESP\MNUGENT\APADSFD.WPD

*Call Jean When Ready!  
874-8200 - 2227*

## Submission Requirements Residential Construction

When a property owner is proposing either a new structure or an addition, this office requires:

- A plot or site plan, showing the shape and dimensions of the entire lot, all existing and proposed structures on the lot and the distance that the structures are from all lot lines. For a new dwelling the plan must be prepared by a registered design professional. For dwelling additions, the plan can be prepared by the owner or agent. (See Figure 1)




Figure 1. Typical Plot Plan

As can be seen, it is easy to establish the extent of compliance with the required setbacks and lot coverage.

- For new construction, structural alterations, or additions, plans showing structural details must be provided. Minimally they should include foundation plans, including drainage and support column spacing framing details, floor plans and a cross section. (See Figures 2, 3 & 4)




Figure 3. Typical Floor Plan




Figure 2. Typical Foundation Plan





**CITY OF PORTLAND**

March 6, 2000

Frank LaTorre  
Portland Public Assembly  
Park Avenue  
Portland ME 04101

RE: Hadlock Field


389 Park Ave

Dear Frank:

This letter is to confirm that the Portland Planning Authority has reviewed and approved the site plan and building elevations for the proposal to enclose an area of Hadlock Field (under the stands) into a storage room. The approved plan is dated 2-21-00 (revised) and prepared by Brian Duffy.

Should you have any questions on this letter please call me.

Sincerely,

  
Joseph E. Gray, Jr.  
Director of Planning and Urban Development

cc: Alexander Jaegerman, Chief Planner  
Richard Knowland, Senior Planner  
P. Samuel Hoffses, Building Inspector  
Marge Schmuckal, Zoning Administrator  
Tony Lombardo, Project Engineer  
Development Review Coordinator  
William Bray, Director of Public Works  
Nancy Knauber, Associate Engineer  
Jeff Tarling, City Arborist  
Charlie Lane, Associate Corporation Counsel  
Lt. Gaylen McDougall, Fire Prevention  
Inspection Department  
Lee Urban, Director of Economic Development  
Don Hall, Appraiser, Assessor's Office  
Susan Doughty, Assessor's Office  
Approval Letter File  
John Walker, Rich Aluminum, 315 Park Street, Portland ME 04102

# City of Portland

## Public Assembly Facilities Division

Merrill Auditorium at City Hall  
Hadlock Field

Portland Exposition Building  
Fitzpatrick Stadium

---

239 Park Avenue Portland, Maine 04102

Phone (207) 874 - 8200

Fax (207) 874 - 8130

To: City of Portland Inspection Department  
From: Jean Robinson, City of Portland Event Coordinator  
Date: June 10, 1999  
Re: Tent Permit Request for June 18, 1999  
Idexx Corp. 15<sup>th</sup> Anniversary Employee Celebration

The letter is intended to confirm that Party Plus from Biddeford, ME has approval from the Public Assembly Facilities Division of the City of Portland to erect one 40' x 80' flame retardant tent in the parking lot between the Portland Expo and the Ice Arena on Friday, June 18. This tent will be used by the Idexx Corporation for their 15<sup>th</sup> Anniversary Employee Celebration. It has been agreed that the tent will be removed immediately following the event at 12:00am on Saturday, June 19, 1999.

Please direct all questions to PAFD Event Coordinator, Jean Robinson at 874-8200 ext. 227.



# Certificate of Flame Resistance



REGISTERED  
FABRIC  
NUMBER

F121.4

ISSUED BY

TOPTEC, INC.  
1905 N.E. MAIN ST.  
SIMPSONVILLE, S.C. 29681

Date  
manufactured

4/12/93

*This is to certify that the materials described on the reverse side hereof have been flame-retardant treated (or are inherently nonflammable).*

FOR Taylor Rental Center ADDRESS PO Box 528 Route 111  
CITY Biddeford STATE ME

*Certification is hereby made that: (Check "a" or "b")*



- (a) The articles described on the obverse side of this Certificate have been treated with a flame-retardant chemical approved and registered by the State Fire Marshal and that the application of said chemical was done in conformance with the laws of the State of California and the Rules and Regulations of the State Fire Marshal.

Name of chemical used..... Chem. Reg. No.....


Method of application.....



- (b) The articles described on the obverse side hereof are made from a flame-resistant fabric or material registered and approved by the State Fire Marshal for such use.

**The Flame Retardant Process Used WILL NOT Be Removed By Washing**


TOPTEC, INC.

  
Name of Production Superintendent

MODEL TTA73000Y

SERIAL# 930930

IDEXX 15TH ANNIVERSARY  
JUNE 18, 99



IDEXX 15TH ANNIVERSARY  
JUNE 18, 99

