


CITY OF PORTLAND
 FIRE PREVENTION BUREAU
 380 Congress Street, Portland, Maine 04101
 fireprevention@portlandmaine.gov
 (207) 874-8400



NOTICE OF VIOLATION AND ORDER TO CORRECT

August 23, 2017

Responsible Party 1: LIBBY JR GEORGE A 144 WASHBURN AVE PORTLAND, ME 04102		
Location 144 WASHBURN AVE	CBL 052 H002001	Inspection Date 7/26/2017
Inspector Brendan Joyce	Inspection Type FP Routine Inspection	Status Failed

The City of Portland Fire Department inspected this property, and found the fire and life safety code violations listed below, which you are hereby ordered to correct. You must propose a date of completion to remedy each violation, a final date of completion, and a date of re-inspection.

You must send this form to the Fire Prevention Bureau no later than 9/15/2017.

Your failure to submit a plan of action by the date provided, or to correct any violation within the applicable time frame, may result in legal action against you, the imposition of civil penalties, and the pursuit of other legal remedies.

Violation	Proposed Date of Completion
<p>NFPA 80- ANNEX D.4 1-HOUR FIRE DOORS ASSEMBLIES REQ; Listings are provided for floor fire door assemblies that are installed in fire-rated floor-ceiling or roof-ceiling assemblies that have been tested in accordance with the methods described in NFPA 288. The listing indicates the fire-rated assembly and the hourly rating (3 hours, 2 hours, 1.5 hours, 1 hour, .75 hours) for which the door can be permitted to be used so that access to the space above the ceiling or to the floor above can be provided without adversely affecting the fire resistance rating of the entire assembly. The listing provides limitations on the maximum size of an individual door opening and the total area of all door openings permitted for each 100 square feet of floor or ceiling.</p> <p>Dwelling unit doors and basement doors into a hallways or stairs must be 60 min rated fire doors and labelled with a visible tag. <i>g Doors</i></p>	<p>within 3 years Overall status <i>5/31/18</i> <i>(Signature)</i></p>
<p>NFPA 101- 7.2.1.8.1 FIRE DOOR(S) MUST SELF-CLOSE; A door leaf normally required to be kept closed shall not be secured in the open position at any time and shall be self-closing or automatic-closing in accordance with 7.2.1.8.2, unless otherwise permitted by 7.2.1.8.3. Dwelling unit doors and basement doors into hallways or stairs must self close.</p>	<p>within 3 years <i>5/31/18</i> <i>(Signature)</i></p>
<p>NFPA 72- 10.2.1.2.2 SMOKE DETECTOR NEEDS REPAIR; System defects and malfunctions shall be corrected.</p> <p>All sleeping rooms must have a hardwired smoke alarm in the room and immediately outside the sleeping room.</p>	<p>within 1 year <i>5/31/18</i> <i>(Signature)</i></p>

Violation	Proposed Date of Completion
<p>NFPA 70- ARTICLE 590.6 EXT. CORD USED FOR PERMENANT WIRING; Ground-fault protection for personnel for all TEMPORARY wiring installations shall be provided to comply with 590.6 (A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment or similar activities. Orange cord in center of building. Possibly powering the potentially illegal apartment area.</p>	<p>I had an outlet w/ broken installed</p>
<p>1-14.9.1 MINIMUM OF TWO MEANS OF EGRESS; THE NUMBER OF MEANS OF EGRESS FROM ANY BALCONY, MEZZANINE, STORY, OR PORTION THERE OF SHALL BE NOT LESS THAN TWO, EXCEPT UNDER ONE OF THE FOLLOWING CONDITIONS (1) A SINGLE MEANS OF EGRESS SHALL BE PERMITTED WHERE PERMITTED IN CHAPTERS 11 THROUGH 43 OF NFPA 101. (2) A SINGLE MEANS OF EGRESS SHALL BE PERMITTED FOR A MEZZANINE OR BALCONY AND THE COMMON PATH OF TRAVEL LIMITATIONS OF CHAPTERS 11 THROUGH 43 OF NFPA 101 ARE MET. Evidence of basement being used as a dwelling unit, either permanently or transiently. Possibly illegal apartment. Bed, clothing, toilet, bath tub, towels were all present in the area.</p>	<p>Man Cave - No living my cellar egress</p> <p>WILL CONFIRM ON RE-INSPECTION</p>
<p>PORTLAND FIRE DEPARTMENT CHAPTER 10 4.6.1, 4.6.2 UNIT/SUITE NUMBERS NOT MARKED; 4.6.1 Residential units shall be designated using numerals. 4.6.2 The first numeral of each residential unit shall be the floor designation. All apartment entry doors must be labeled with their appropriate apartment number (front and rear entrances).</p>	<p>Done</p>
<p>PORTLAND FIRE DEPARTMENT CHAPTER 10 4.3.1, 4.3.2 BUILDING ADDRESS NOT MARKED ON BUILDING; 4.3.1 Signs shall be located in a position readily visible as approaching from the main access and approved by the Fire Department. Signs shall be illuminated or retro reflective on a contrasting background and the letter(s) size shall be approved by the Fire Department. 4.3.2 Street Address shall be clearly marked on the front of the building and building sign as approved by the Fire Department. Building number must be visible from the street.</p>	<p>Done</p>
<p>FINAL DATE OF COMPLETED VIOLATION(S)</p>	<p>5/31/18</p>
<p>FIRE PREVENTION BUREAU RE-INSPECTION OF COMPLETED VIOLATION(S)</p>	<p>— / — / —</p>

The Bureau reserves the right to reject or modify any proposed plan of action, and may require evidence of sufficient financial and technical capacity to complete the proposed plan. Please contact the Bureau with any questions.


VIOLATOR CERTIFICATION

I agree to remedy the violations listed within the timeframes provided. If I require additional time to comply, I understand that I must contact the Fire Prevention Bureau prior to the deadline to request an extension, which is entirely within the Bureau's discretion to grant or deny.

I further understand that it is my responsibility to schedule a reinspection of my property once the violations have been remedied to do so. My failure to schedule a reinspection shall be deemed an admission that the violations have not been remedied.

If I fail to comply with this agreement, I understand that I am liable for penalties pursuant to the City of Portland Code of Ordinances §§ 1-15 and 10-25, and 30-A M.R.S. § 4452 and may be subject to further legal action.

9-9-17
Date


Responsible Party


George Libby
144 Washburn Ave
Portland, Maine 04102

Date

Responsible Party

SEEN AND AGREED

9/12/17
Date

 # 17
Fire Prevention Bureau