

To: Jeanie Bourke <jmb@portlandmaine.gov>

Great. Thank you!

Sent from my iPhone

[Quoted text hidden]

Daniel Paul <danielpaulconstruction@gmail.com>

Sun, Apr 2, 2017 at 10:41 PM

To: Jeanie Bourke <jmb@portlandmaine.gov>

Hi Jeanie,

Here is a revised set of drawings. One question: does the graspable handrail on the outside of the stairs need to extend the 11" beyond the bottom step (as drawn), or can it end at the post? The inside handrail would definitely extend the 11".

Thank you,

Daniel

[Quoted text hidden]

Daniel Paul <danielpaulconstruction@gmail.com>

Sun, Apr 2, 2017 at 10:43 PM

To: Jeanie Bourke <jmb@portlandmaine.gov>

Sorry, here they are.

Thanks!

Daniel

[Quoted text hidden]



260Park Rev.pdf
626K

Jeanie Bourke <jmb@portlandmaine.gov>

Mon, Apr 3, 2017 at 10:12 AM

To: Daniel Paul <danielpaulconstruction@gmail.com>

Hi Daniel,

Thank you, the code requires the extension, however there is some consideration if it is deemed as a protruding object it can then return to the post without the extension. This does seem to be protruding, so returning the rail to the post is acceptable without extension.

Jeanie

Jeanie Bourke

Code Enforcement Officer/Plan Reviewer

City of Portland

Permitting and Inspections Department

389 Congress St. Rm 315

Portland, ME 04101

jmb@portlandmaine.gov

(207)874-8715

[Quoted text hidden]

Daniel Paul <danielpaulconstruction@gmail.com>

Tue, Apr 4, 2017 at 4:15 PM

To: Jeanie Bourke <jmb@portlandmaine.gov>

Thanks Jeanie. Should we get you a revised set of drawings with the outer handrail stopping at the post?

Sent from my iPhone

[Quoted text hidden]

Jeanie Bourke <jmb@portlandmaine.gov>
To: Daniel Paul <danielpaulconstruction@gmail.com>

Wed, Apr 5, 2017 at 2:38 PM

I will include this email in the approved documents that confirms this approval. I will prepare the permit for approval, it will be emailed to you directly.

Jeanie

Jeanie Bourke
Code Enforcement Officer/Plan Reviewer

City of Portland
Permitting and Inspections Department
389 Congress St. Rm 315
Portland, ME 04101
jmb@portlandmaine.gov
(207)874-8715

[Quoted text hidden]