

---

**CITY OF PORTLAND**  
**DEPARTMENT OF PLANNING & URBAN DEVELOPMENT**

389 Congress Street  
Portland, Maine 04101

---

**Inspection Violations**

<b>Owner/Manager</b> JIT TEJINDER		<b>Inspector</b> Peter Merrow	<b>Inspection Date</b> 10/20/2005
<b>Location</b> 15 WEYMOUTH ST	<b>CBL</b> 053 B013001	<b>Status</b> Red Immediate	<b>Inspection Type</b> Complaint-Housing Inspection

<b>Code</b>	<b>Int/Ext</b>	<b>Floor</b>	<b>Unit No.</b>	<b>Area</b>	<b>Compliance Date</b>
1) 6-114.3	Interior	1	1	common area	
<b>Violation:</b> Maintenance of equipment.					
<b>Notes:</b> No Heat in building.					

---

**Comments:** Temp was at 65 Degrees F