Protection Professionals

Falmouth, ME 04105
Ph 207-775-5755
Fax 207-781-2064

Device Lis

Reviewed for Code Compliance
Inspections Division
Approved with Conditions

Date: 01/25/14

Bill To Name / Address	Job Site
Shamayel Kargar PO Box 6149 Falmouth, Maine 04105	185 Grant Street Portland, Maine 04101

CHANGING THIS DEVICE LIST DOES NOT ALTER THE ORIGINAL ESTIMATE
Attach copy to Purchase Order for accounting

Estimate No.

Item	Description	Qty To Order	Qty Ordered
	This system will require two Fairpoint lines or a long range radio system.		
	All devices inside the units which require local smoke and CO detection in the rooms shall be provided by others.		
FC901-U3	S54433-C105-A1 Cerberus-Pro fire alarm panel, 50 points, 170 watts	1	
FH901-R3	S54433-B103-A4; 50 Point system red enclosure	1	
Bat 12-12	Battery 12 VOLTS 12 AMP/HOURS SLA-1105	2	
IM-RJ31XSET	IM-RJ31XSET	2	
E120V-GT	Space Age 120V Surge Protector plus lockout and circuit breaker labels for FACP	1	
06-SSU00672	Fire Document box 12 inches wide X 13.1 inches high X 2.25 inches deep, CAT 30 keyed	1	
OP921	S54320-F4-A2, Optical Smoke Detector (stair landings)	6	
HI921	S54320-F5-A2 Heat detector (laundry room)	1	
500-094151FA	2 Wire Detector Base	7	
ED-281BPL	135 Fixed Temperature, rate of rise heat detector (one in each kitchen, bathroom, and living room)	20	
500-034850	HZM Conventional Zone Module (one in each apt for the heats)	4	
500-648507FA	Manual Pull Station (RMS-2T-LP-KL) DUAL STATION(6/27/13) (stair landings)	5	
500-034000	HTRI-M Mini-module (Pulls)	5	
500-636161	ZH-MC-R Horn/strobe, red, wall mount, Hi or Lo volume, 15cd, 30cd, 75cd, or 110cd (stair landings)	6	
500-636159	Horn, red, wall, double gang (inside the units)	4	
3261	Knox Box 3261 Hinged Door Black	1	
	State of Maine Sales Tax		

Ordered By: _____ **Date:** _____

Received By: _____ **Date:** _____