

City of Portland, Maine
Inspections Division
Inspection Results
All Results

Date	CBL	Business	Appl ID	Appl Type	Sch. Type	Status
03/11/2011	053 B017001		15937	Complaint	Inspection	Re-Inspect
185 GRANT ST		vacant building in disrepair.			building is vacant and all utilities have been shut off. I will post the building against occupancy. And follow up with fire and trades. NLA	
03/18/2011	053 B017001			Complaint	Inspection	
185 GRANT ST		SET TIME 900 AM RANDY FROM TRADES	899-9227			
03/18/2011	053 B017001		20223	Complaint	Housing Inspection	Violations E
185 GRANT ST		unk			Building is Posted against occupancy, Building is now owned by Bank of America. Send all invoicing to Bank of America Home Loan INC. ATTN: CA6-9190141 Violations 400 National Way Simi Vally, CA 93065	
06/06/2011	053 B017001		15937	Complaint	Inspection	
185 GRANT ST		vacant building in disrepair.			went to site with Capt Gautreau someone broke into building and building is no longer secured. Called Randy at trades he swung down with plywood to re secure the property. I will send invoice to owner NLA	
10/16/2012	053 B017001		23304	Complaint	Bldg w/o pmt & structure issue	Violations
185 GRANT ST		received via PPD, vacant building, premises unsecured			Per inspection and clearing of building with PPD, occupants have been removed and building has been secured.	
08/06/2013	053 B017001		25989	Complaint	Bldg w/o pmt & structure issue	Invalid Com
185 GRANT ST		Neighbor complaining people ripping and tearing throwing stuff on the lawn. Work with out permits. Told shamyil that any work she does needs to be permitted and inspected by Brian and a building inspector prior to starting any work.			Per inspection, crew was cleaning out the house. No work or remodel taking place.	
08/19/2013	053 B017001		201301815	Electrical	Pre-Construction Meeting	
185 GRANT ST		This is a walk through building has been vacant for almost 2 years - No power to building CMP wants confirmation from Brian okay to turn power on. Owner wants building inspections to give okay to move tenants in. - 838-0475 Bob - Please call, Paul Bob is on Vacation - Paul's # 632-7845 Please call in a.m. with time. W/BKL & Fire			Provide for Occupancy: Address Weather proof Handrail at stairs Code compliant plumbing Rated separations Note: 14' at rear to "1st" floor. "Basement" floor more than 1/2 above grade	