## CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

## **Inspection Violations**

| Owner/Manager     |             | Inspector          | Inspection Date      |  |
|-------------------|-------------|--------------------|----------------------|--|
| REDMOND GABRIEL & |             | Peter Merrow       | 04/11/2006           |  |
| Locatation        | CBL         | Status             | Inspection Type      |  |
| 182 GRANT ST      | 053 C005001 | Re-Inspect 30 Days | Complaint-Inspection |  |

|     | Code                            | Int/Ext   | Floor    | Unit No. | Area        | Compliance Date |
|-----|---------------------------------|---|----------|----------|-------------|-----------------|
| 1)  | 6-116.5<br>Violation:<br>Notes: | Interior Fire Protection Missing smoke detectors  | All      |          | Various loc | cations         |
| 2)  | 6-108.2<br>Violation:<br>Notes: | Interior Interior floors, walls, ceilings and doors Missing or broken ceiling tiles.          | 1        | 1        | Various loc | cations         |
| 3)  | 6-108.2<br>Violation:<br>Notes: | Interior Interior floors, walls, ceilings and doors Cabinets have fallen from the wall.       | 1        | 1        | Kitchen     |                 |
| 4)  | 6-111.4<br>Violation:<br>Notes: | Interior  Maintenance of plumbing fixtures.  Bathroom sink is removed from wall.              | 1        | 1        | Bathroom    |                 |
| 5)  | 6-108.3<br>Violation:<br>Notes: | Interior Exterior windows, doors and skylights Missing/broken tiles on floor.                 | 1        | 1        | Various loc | ations          |
| 6)  | 6-113.5<br>Violation:<br>Notes: | Interior  Maintenance of lighting fixtures  Missing light shield.                             | 1        | 1        | Bathroom    |                 |
| 7)  | 6-108.3<br>Violation:<br>Notes: | Exterior Exterior windows, doors and skylights Missing window screens.                        | 1        | 1        | Various loc | eations         |
| 8)  | 6-116.5<br>Violation:<br>Notes: | Interior Fire Protection Missing smoke detectors.   |          |          | Stairways   |                 |
| 9)  | 6-109.5<br>Violation:<br>Notes: | Exterior Rodent and vermin control. Trash not in rodent proof containers.                     |          |          | side yard   |                 |
| 10) | 6-108.1<br>Violation:<br>Notes: | Exterior Foundations cellars, exterior walls, roofs Foundation needs repointing in various lo | cations. |          | Various loc | cations         |

## CITY OF PORTLAND DEPARTMENT OF PLANNING & URBAN DEVELOPMENT

389 Congress Street Portland, Maine 04101

## **Inspection Violations**

| Owner/Manager REDMOND GABRIEL & |             | Inspector          | Inspection Date<br>04/11/2006 |  |
|---------------------------------|-------------|--------------------|-------------------------------|--|
|                                 |             | Peter Merrow       |                               |  |
| Locatation                      | CBL         | Status             | Inspection Type               |  |
| 182 GRANT ST                    | 053 C005001 | Re-Inspect 30 Days | Complaint-Inspection          |  |

**Comments:** Smoke detectors must be repaired with in 24 hours.