City of Portland, Maine - Building or Use Permit Application 389 Congress Street, 04101, Tel: (207) 874-8703, FAX: 874-8716

Location of Construction: 189 Grant St		Owner: F Bike Marris/Patrick Tinaman		Permit N9: 81061		
Owner Address: Le 645 Mashington Ave 04103	ssee/Buyer's Name:	Phone:	BusinessName	PERMIT ISSUED		
Contractor Name: Ac Sullivan Builders HC 75 Box 7014			2665 Call for Pick-Up	Permit Issued: SEP 2 2 1998		
Past Use: Pr	oposed Use:	COST OF WOR \$ 8,500.00				
6-£ 1.21		FIRE DEPT.	Approved INSPECTION: Denied Use Group: Type:	CITY OF PORTLAND		
		Signature: 7	Signature: Haff	Zone: CBL: 053-C-006		
Proposed Project Description:			CTIVITIES DISTRICT (P.A.D.) Approved	Zoning Approval:		
Hehab firedamaged section of build	ing		Approved with Conditions:	Shoreland		
		Signature:	Date:	Subdivision		
Permit Taken By:	Date Applied For:	15 Sept 98		Site Plan maj Ominor Omm O		
 This permit application does not preclude the Appl Building permits do not include plumbing, septic 		State and Federal rules.		Zoning Appeal		
 Building permits do not include prantonig, optic Building permits are void if work is not started wit tion may invalidate a building permit and stop all 	□ Conditional Use □ Interpretation □ Approved □ Denied					
CALL SHAWN SULLIVAN FOR PICK_UP	471-7117	J	PERMIT ISSUED WITH REQUIREMENTS	Historic Preservation		
I hereby certify that I am the owner of record of the nam authorized by the owner to make this application as his if a permit for work described in the application is issu areas covered by such permit at any reasonable hour to	Denied					
SIGNATURE OF APPLICANT	ADDRESS:	DATE:	PHONE:			
RESPONSIBLE PERSON IN CHARGE OF WORK, T	TLE		PHONE:			
White-Permit	Desk Green-Assessor's Ca	anary-D.P.W. Pink-Pu	blic File Ivory Card-Inspector	FIR		



CITY OF PORTLAND, MAINE Department of Building Inspection

Certificate of Occupancy

LOCATION 180 Grant Street 053-C-006

Issued to Make Harris/Patrick Timsman

Date of Issue March 1 2000

This is to certify that the building, premises, or part thereof, at the above location, built - altered

— changed as to use under Building Permit No. 981061 , has had final inspection, has been found to conform substantially to requirements of Zoning Ordinance and Building Code of the City, and is hereby approved for occupancy or use, limited or otherwise, as indicated below.

PORTION OF BUILDING OR PREMISES

APPROVED OCCUPANCY

Entire

Six Units use group R2 type 58 Bocs 96

Limiting Conditions:

This Certificat applies to work spacificly covered by this permit only. Collar stair dementions ok replace existing under Soca 96 1014.6

This certificate supersedes certificate issued

Approved:

Date

Inspector

Inspector of Buildings

Notice. This certificate identifies lawful use of building or premises, and ought to be transferred from owner to owner when property changes hands. Copy will be furnished to owner or lessee for one dollar.

THIS IS NOT A PERMIT/CONSTRUCTION CANNOT COMMENCE UNTIL THE PERMIT IS ISSUED

Building or Use Permit Pre-Application

Attached Single Family Dwellings/Two-Family Dwelling

Multi-Family or Commercial Structures and Additions Thereto

In the interest of processing your application in the quickest possible manner, please complete the Information below for a Building or Use Permit.

NOTE**If you or the property owner owes real estate or personal property taxes or user charges on ANY PROPERTY within the City, payment arrangements must be made before permits of any kind are accepted.

Location/Addressof Construction (include Portion of Building): 180 Grant St. Portland, Maine							
Total Square Footage of Proposed Structure 1363	Sq. Fq Square Footage o	fLot 2418 55 ft +1-					
Tax Assessor's Chart, Block & Lot Number Chart# 0.53 Block# C Lot# 0.06	Owner: Mike Harris Patrick Tinsmi	Immubela Telephone#: an 774-773.7					
Owner's Address: 645 Washington Ave Portland, Maine	Lessee/Buyer's Name (If Applicable) Cost Of Work: Fee \$ 8,500.00 \$ 65					
Proposed Project Description:(Please be as specific as possible)	Rehab firedamaged						
Ine Kon	h at						
Contractor's Name, Address & Telephone Sullivan Builders HC 75 Box NIA	Sebago, Maine 04029	207-787-2665 Ree'd By					
Current Use: 6 Unit APT. BLOG.	Proposed Use:	Same					

Separate permits are required for Internal & External Plumbing, HVAC and Electrical installation.

•All construction must be conducted in compliance with the 1996 B.O.C.A. Building Code as amended by Section 6-Art II. •All plumbing must be conducted in compliance with the State of Maine Plumbing Code.

•All Electrical Installation must comply with the 1996 National Electrical Code as amended by Section 6-Art III.

•HVAC(Heating, Ventililation and Air Conditioning) installation must comply with the 1993 BOCA Mechanical Code. You must Include the following with you application:

1) ACopy of Your Deed or Purchase and Sale Agreement CITY OF PORTLAND, ME

SEP

5 1998

2) A Copy of your Construction Contract, if available 3) A Plot Plan/Site Plan

Minor or Major site plan review will be required for the above proposed projects. The attached checklist outlines the minimum standards for a site plan.

4) Building Plans

Unless exempted by State Law, construction documents must be designed by a registered des

- A complete set of construction drawings showing all of the following elements of construction:
- Cross Sections w/Framing details (including porches, decks w/ railings, and accessory structures)
- Floor Plans & Elevations
- Window and door schedules
- Foundation plans with required drainage and dampproofing
- Electrical and plumbing layout. Mechanical drawings for any specialized equipment such as furnaces, chimneys, gas
 equipment, HVAC equipment (air handling) or other types of work that may require special review must be included.

Certification

I hereby certify that I am the Owner of record of the named property, or that the proposed work is authorized by the owner of record and that I have been authorized by the owner to make this application as his/her authorized agent. I agree to conform to all applicable laws of this jurisdiction. In addition, if a permit for work described in this application is issued, I certify that the Code Official's authorized representative shall have the authority to enter all areas covered by this permit at any reasonable hour to enforce the provisions of the codes applicable to this permit.

Signature of applicant:				Date:	0	124	19	\sim
	Mur la	rch	lu		01	C / /	(0

Building Permit Fee: \$25.00 for the 1st \$1000.cost plus \$5.00 per \$1,000.00 construction cost thereafter. Additional Site review and related fees are attached on a separate addendum

Will pick UP & Shawn Sullivan 471-7117

not more than 44 inclues (1118mm) above the floor All egress or rescue windows from sleeping rooms shall have a minimum net clear opening height dimension of 24 inches (610mm). The minimum net clear opening width dimension shall be 20 inches (508mm), and a minimum net clear opening of 5.7 sq. ft. (Section 1018.6)

- (13.) Each apartment shall have access to two (2) separate, remote and approved means of egress. A single exit is acceptable when it exits directly from the apartment to the building exterior with no communications to other apartment units. Section 1010.1
- (14) All vertical openings shall be enclosed with construction having a fire rating of at lest one (1)hour, including fire doors with self closer's. (Over 3 stories in height requirements for fire rating is two (2) hours.) Section 710.0
- The boiler shall be protected by enclosing with (1) hour fire-rated construction including fire doors and ceiling, or by providing automatic extinguishment. Table 302.1.1
- All single and multiple station smoke detectors shall be of an approved type and shall be installed in accordance with the provisions of the City's Building Code Chapter 9. Section 19, 920.3.2 (BOCA National Building Code/1996), and NFPA 101 Chapter 18 & 19. (Smoke detectors shall be installed and maintained at the following locations):
 - In the immediate vicinity of bedrooms
 - In all bedrooms
 - In each story within a dwelling unit, including basements

In addition to the required AC primary power source, required smoke detectors in occupancies in Use Groups R-2, R-3 and I-1 shall receive power from a battery when the AC primary power source is interrupted. (Interconnection is required) Section 920.3.2

- 17. A portable fire extinguisher shall be located as per NFPA ≠10. They shall bear the label of an approved agency and be of an approved type. Section 921.0
- 18. The Fire Alarm System shall be maintained to NFPA #72 Standard.
- 19. The Sprinkler System shall maintained to NFPA #13 Standard.
- 20. All exit signs, lights, and means of egress lighting shall be done in accordance with Chapter 10 Section & Subsections 1023, & 1024. Of the City's building code. (The BOCA National Building Code/1996)
- 21. Section 25-135 of the Municipal Code for the City of Portland states, "No person or utility shall be granted a permit to excavate or open any street or sidewalk from the time of November 15 of each year to April 15 of the following year".
- 22. The builder of a facility to which Section 4594-C of the Maine State Human Rights Act Title 5 MRSA refers, shall obtain a certification from a design professional that the plans commencing construction of the facility, the builder shall submit the certification to the Division of Inspection Services.
- 23. Ventilation shall meet the requirements of Chapter 12 Sections 1210. Of the City's Building Code. (crawl spaces & attics)
- All electrical, plumbing and HVAC permits must be obtained by a Master Licensed holders of their trade.
- $\frac{1}{125}$. All requirements must be met before a final Certificate of Occupancy is issued,
- All building elements shall meet the fastening schedule as per Table 2305.2 of the City's Building Code. (The BOCA National Building Code/1996).
- 27. Ventilation of spaces within a building shall be done in accordance with the City's Mechanical Code (The BOCA National Mechanical Code/1993). (Chapter M-16)

28. Please read and implement the attached Land Use-Zoning report requirements.

29.

30.

31.

32.

HoffAs. Exilding Inspector 17 743

cc: Lt McDougall.PFD Marge Schmuckal, Zoning Administrator





Sullivan Builders

HC 75 Box 701A

East Sebago, Maine 04029

Contract

Date Entered: Aug. 20, 1998

Mike Harris Washington Ave. Portland, Maine

For Work Done at... 180 Grant Street Portland, Maine

Contract

We hereby propose to furnish the material and perform the labor necessary for the completion of

- 1. Inspect and remove all fire damaged materials.
- 2. Install new floor joist and subfloor where needed.
- 3. Install new 2x4 walls where needed.
- 4. Install new vinyl replacement windows throughout building.
- 5. All flooring in burnt areas to be replaced with carpet or sheet vinyl flooring where required.

All material is guaranteed to be as specified, and the above work to be performed in accordance with

the drawings and specifications submitted for above work and completed in a substantial workmanlike

manner forthe sum of : Eight Thousand Five Hundred

Dollars (\$8500.00)

with payments to be made in thirds. Dates to be determined at a later date.

Respectfully submitted_

The above prices, specifications and conditions are satisfactory and are hereby accepted. You are authorized to do the work as specified. Payments will be made as outlined above.

Date Owner Date: 20/98 co-Owner:__



WILLIAM NEMMERS ASSOCIATES ARCHITECTS 424 FORE ST. PORTLAND, ME 04101 774-3683.

September 5, 1998

Mr Sam Hoffses, Building Inspector City of Portland Congress St. Portland, Maine 04101

Re 180 Grant Street- Portland, Maine

Dear Sam

I have reviewed the situation regarding the fire damage to the structure of this building and have specified the following corrective action

1) In the basement - replace the central carrying beam over the last two spans of 4'2" and 6'-4" use solid timber same dimension as existing or 4-2x10's. Since this beam also carries the central wall supporting the second floor, the second floor should be temporarily supported down through to the basement during the beam replacement and the joist replacement noted below.

2) In the basement replace the existing burned 2x8 joists at 16" OC with new 2x10 joists at 16" OC or 2x8 joists at 12" OC

3) At the 1st floor replace the subfloor with 3/4" plywood, and additional underlayment as needed to bring the floor level with the existing

 Replace the back stairway with new stair construction of 3-2x12 stringers tread and riser to match existing.

5) It does not appear that the fire damage extended to the second floor structure (except for some superficial damage in a small area around the stair which will be replaced with the new stair).

6) It does not appear that the fire damage extended to the support wall structure (although a small piece of siding on the back wall is scorched and should be replaced)

7) Additional problems may be exposed as the construction proceeds and I will inspect the work when the Contractor has demolished the fire damaged material

Sincerely

William Nemmers