

May 9, 2016

HARRIS RICHARD J &

103 LOUDEN RD

SACO, ME 04072

CBL: 053 C015001

Located at 863 CONGRESS ST

NOTICE OF INTENT TO PROSECUTE

Dear Owner/Manager/Occupant,

An inspection of the property located at the address referenced above revealed that the structure and premises fail to comply with NFPA 2009 Fire Code and/or NFPA Life Safety Codes. Attached is a list of those violations.

The above-referenced property is in violation of the Chapter 10, Fire Prevention and Protection, Article 1 of the Portland City Code (the "Code") and National Fire Protection Association (NFPA) 101 Life Safety Code. Please note that the Code is available online at www.portlandmaine.gov.

This is a notice of intent to prosecute. As such, the matter is being referred to the City of Portland Corporation Council for legal action and possible civil penalties as provided for in Chapter 10, Fire Prevention and Protection, 10-25 of the Code and in Title 30- A.M.R.S.A. 4452.

Please be advised that you will need to contact the Fire Prevention Bureau at 207-874-8400 before the court date on the attached Reference to Court letter to either schedule a re-inspection or to submit a plan of action to correct these violations.

Sincerely,

Portland Fire Department

CRI Cossey

Fire Prevention Bureau

353864

CITY OF PORTLAND PORTLAND FIRE DEPARTMENT

380 Congress Street Portland, Maine 04101

Inspection Violations

Owner/Manager HARRIS RICHARD J &				Inspector Daniel Dye	r	Inspection Date 5/6/2016
Location CBL			Status		Inspection Type	
863 CONGRESS ST 053 C015001			Failed		Fire Company-FP Routine Inspec	
Code		Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 73.20						
Violation:	NFPA 101- 31.3.7 FLOOR/ CEILINGS ASSEMBLY NOT SMOKE-TIGHT; IN BUILDINGS OTHER THAN THOSE MEETING THE REQUIREMENTS OF 31.3.7.1, 31.3.7.2, 31.3.7.3, 31.3.7.4, OR 31.3.7.5, IN ADDITION TO THE FOLLOWING CRITERIA TO BE MET.					
Notes:	BASEMENT ENTRY					
2) 91.15						
Violation:	NFPA 70- ARTICLE 110.12 B EXPOSED WIRING CONNECTIONS; Internal parts of electrical equipment, including busbars, wiring terminals, insulators, and other surfaces, shall not be damaged or contaminated by foreign materials such as paint, plaster, cleaners, abrasives, or corrosive residues. There shall be no damaged parts that may adversely affect safe operation or mechanical strength of the equipment such as parts that are broken; bent; cut; or deteriorated by corrosion, chemical reaction, or overheating.					
Notes:	BASEMENT NEAR COMPRESSORS					
3) 91.20						
Violation:	NFPA 70- 590.6 EXTENSION CORDS; Ground-fault protection for personnel for all temporary wiring installations shall be provided to comply with 590.6(A) and (B). This section shall apply only to temporary wiring installations used to supply temporary power to equipment used by personnel during construction, remodeling, maintenance, repair, or demolition of buildings, structures, equipment, or similar activities.					
Notes:	BASEMEN	r				
4) 1.125						
Violation:	NFPA 101- 7.10.1.1 EXITS CLEARLY VISIBLE OR CONSPICUOUSLY INDICATED; WHERE REQUIRED: MEANS OF EGRESS SHALL BE MARKED IN ACCORDANCE WITH SECTION 7.10 WHERE REQUIRED IN CHAPTERS 11 THROUGH 43.					
Notes:	REMOVE EXIT SIGN NEAR BASEMENT DOOR					
5) 7.011						
Violation:	NFPA 1- 19.1.2 INSIDE STORAGE NOT ORDERLY; PERSONS OWNING OR HAVING CONTROL OF ANY PROPERTY SHALL NOT ALLOW ANY COMBUSTIBLE WASTE MATERIAL TO ACCUMULATE IN ANY AREA OR IN ANY MANNER THAT CREATES A FIRE HAZARD TO LIFE OR PROPERTY.					
Notes:	BASEMENT	Γ				

Comments:

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

v.

Richard Harris Defendant

SUMMONS NUMBER:

353864

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 07/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 07/11/2016.

Dated: 5/12/16

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Counsel City of Portland 389 Congress St Portland, ME 04101

207-874-8480

DISTRICT COURT Location: Portland Docket No.

CITY OF PORTLAND and body politic and Corporate, located in the County of Cumberland and State of Maine,

Plantiff,

FIRE PREVENTION AND PROTECTION CODE VIOLATION

(M.R. CIV. P. 80H AND 80k)

V.

Richard Harris Defendant

SUMMONS NUMBER:

353864

This matter has been referred to the Corporation Counsel's Office for immediate legal action with respect to the code violations detailed in the attached letter. It has been assigned the above summons number and will be filed with the Portland District Court and will be assigned for an initial appearance at the Portland District Court 205 Newbury Street Portland, Maine 04101 at 8:30 A.M. on 07/11/2016. Please contact Tori Ross in Fire Prevention at (207)-874-8400 or via e-mail at meservev@portlandmaine.gov to set up an in-person meeting to meet with somebody in the Fire Prevention Bureau to resolve these issues or make alternative arrangements to relieve you of the requirement to appear in Court on 07/11/2016.

Dated: $\frac{5}{2} / \frac{2}{6}$

Adam R. Lee, Esq. Bar No. 4143 Associate Corporation Counsel City of Portland 389 Congress St Portland, ME 04101

207-874-8480