
CITY OF PORTLAND
DEPARTMENT OF PLANNING & URBAN DEVELOPMENT
389 Congress Street
Portland, Maine 04101

Inspection Violations

Owner/Manager 861 CONGRESS STREET LLC		Inspector Jeannie Bourke	Inspection Date 05/18/2006
Locatation 861 CONGRESS ST	CBL 053 C016001	Status re-Inspect 14 Days	Inspection Type Complaint-Social Services/Genera

Code	Int/Ext	Floor	Unit No.	Area	Compliance Date
1) 6-108.6					
Violation:	Required equipment and utilities				
Notes:	Electric service entrance cable is severely damage and not adequately secured to the building				

Comments: